



Electronic Multi-Measuring Instrument

Programming Manual (CC-Link)

For ver.2 remote device station

Model

ME96SSH-MB or ME96SSR-MB with Optional Plug-in Module: ME-0040C-SS96
ME96SSHA-MB or ME96SSRA-MB with Optional Plug-in Module: ME-0040C-SS96
ME96SSHB-MB or ME96SSRB-MB with Optional Plug-in Module: ME-0040C-SS96

CONTENTS

1.	General Description	3
2.	Specification	4
3.	Configuration Conditions of CC-Link System	5
3.1	Remote net ver.2 mode, remote net addional mode	5
4.	Programming.....	7
4.1	Programming Procedure.....	7
5.	Parameter Settings	8
5.1	Procedure from Parameter Settings to Data Link Startup.....	8
5.1.1	CPU Parameter Area and Master Module Parameter Memory.....	8
5.1.2	Procedure for Parameter Settings to Data Link Startup with GX Developer	8
5.2	Example of Parameter Settings with GX Developer (Remote net ver.2 mode)	9
5.2.1	Master Station Network Parameter Settings	9
6.	Communication Between the Master Station and ME96	13
6.1	Communication Guideline.....	13
6.2	Initial Communication	14
6.3	Error Communication.....	14
6.4	Normal Communication	15
6.4.1	Monitoring by Pattern.....	15
6.4.2	Monitoring by Command(1H).....	16
6.4.3	Setting by Command(2H)	17
7.	Remote I/O and Remote Register	18
7.1	Remote Input RX, Remote Output RY.....	18
7.1.1	Remote input RX.....	18
7.1.2	Remote Output RY.....	20
7.2	Remote Register (RWr, RWw)	22
7.2.1	When Monitoring by Pattern	25
7.2.2	When Monitoring by Command(1H)	28
7.2.3	When Setting by Command(2H).....	42
7.2.4	Data format of Monitoring by Command(1H) and Setting by Command(2H)	45
7.2.5	Multiplying factor	56
7.2.6	About Error Occurrence	57
8.	Abbreviations and Special Terms.....	58
9.	Program Example	59
9.1	Program Content.....	59
9.2	System Configuration	59
9.3	Parameter Settings	60
9.3.1	Network Parameter Settings and Auto Refresh Parameter Settings	60
9.3.2	Operational Settings	61
9.3.3	Station Information Settings.....	61
9.4	Device Allocation.....	62
9.5	Program Example	64
10.	Test Mode.....	69
10.1	ME96SSH/SSR/SSHA/SSRA/SSHB/SSRB-MB	69

1. General Description

This manual describes the programming methods that should be created by the user for monitoring measurement value of the Electronic Multi-Measuring Instrument (called ME96 from here on) with the CC-Link (in remote net ver2 mode or remote net additional mode).

In programming, read the following related manuals in addition to this manual.

Table 1.1 Related Manuals

Manual Name	Manual No.
CC-Link System Master/Local Module User's Manual type QJ61BT11N	SH-080394E (13JR64)
User's Manual for ME96	Supplied with product or download.

NOTICE

When using ME96, Optional Plug-in Module "ME-0040C-SS96" is necessary. CC-Link communication is not available without the optional plug-in module. In this manual, "ME96SSH-MB", "ME96SSR-MB", "ME96SSHA-MB", "ME96SSRA-MB", "ME96SSHB-MB" or "ME96SSRB-MB" means the main device of ME96 with the optional plug-in module.

POINT

The ME96 must be handled after setting of the remote device station version. Set the remote device station version with the "Setting Menu 2" of the ME96.

Use the following as a guideline in setting the remote device station version and set the version at ME96.

Mode select setting	Guideline for selection
Ver.1 remote device station (Ver.1 compatible slave station)	Select this when utilizing the conventional program, because of compatibility with ME96NSR.
Ver.2 remote device station (Ver.2 compatible slave station)	Select this when configuring a new system or the being newly added to the existing system in combination with the applicable master module.

This programming manual is for ver.2 remote device station.

For use in the ver.1 remote device station (Ver.1 compatible slave station), refer to the following manual.

- Electronic Multi-Measuring Instrument Programming Manual (CC-Link)(For ver.1 remote device station)


..... LEN080334

2. Specification

CC-Link specification is shown in Table 2.1 when ME96 is set the "Ver2.00" (ver.2 remote device station).

Table 2.1 CC-Link Specification (For Ver2.00)

Item	Specification
CC-Link station type	Remote device station (ver.2 remote device station)
Number of occupied stations	1 station (Expanded cyclic setting: Octuple)
Maximum number of stations per master station	42 stations (In case of connecting only remote device station occupied by 1 station(Octuple).)
Transmission speed	156kbps/625kbps/2.5Mbps/5Mbps/10Mbps
Remote I/O (RX, RY)	128 points each
Remote register (RWw, RWr)	32 points each




3. Configuration Conditions of CC-Link System

3.1 Remote net ver.2 mode, remote net additional mode

A total of 64 remote I/O stations, remote device stations, local stations, standby master stations, or intelligent device stations can be connected to a single master station.

However, the following conditions must all be satisfied.


Condition 1	$\{(a+a_2+a_4+a_8) + (b+b_2+b_4+b_8) \times 2 + (c+c_2+c_4+c_8) \times 3 + (d+d_2+d_4+d_8) \times 4\} \leq 64$	a: The total number of ver.1 compatible slave stations that occupy 1 station, and ver.2 compatible slave stations that occupy 1 station which are set to "Single". b: The total number of ver.1 compatible slave stations that occupy 2 stations, and ver.2 compatible slave stations that occupy 2 stations which are set to "Single". c: The total number of ver.1 compatible slave stations that occupy 3 stations, and ver.2 compatible slave stations that occupy 3 stations which are set to "Single". d: The total number of ver.1 compatible slave stations that occupy 4 stations, and ver.2 compatible slave stations that occupy 4 stations which are set to "Single".
Condition 2	$\{[(a \times 32) + (a_2 \times 32) + (a_4 \times 64) + (a_8 \times 128)] + [(b \times 64) + (b_2 \times 96) + (b_4 \times 192) + (b_8 \times 384)] + [(c \times 96) + (c_2 \times 160) + (c_4 \times 320) + (c_8 \times 640)] + [(d \times 128) + (d_2 \times 224) + (d_4 \times 448) + (d_8 \times 896)]\} \leq 8192$	a2: The number of ver.2 compatible stations that occupy 1 station which are set to "Double". b2: The number of ver.2 compatible stations that occupy 2 stations which are set to "Double". c2: The number of ver.2 compatible stations that occupy 3 stations which are set to "Double". d2: The number of ver.2 compatible stations that occupy 4 stations which are set to "Double".
Condition 3	$\{[(a \times 4) + (a_2 \times 8) + (a_4 \times 16) + (a_8 \times 32)] + [(b \times 8) + (b_2 \times 16) + (b_4 \times 32) + (b_8 \times 64)] + [(c \times 12) + (c_2 \times 24) + (c_4 \times 48) + (c_8 \times 96)] + [(d \times 16) + (d_2 \times 32) + (d_4 \times 64) + (d_8 \times 128)]\} \leq 2048$	a4: The number of ver.2 compatible stations that occupy 1 station which are set to "Quadruple". b4: The number of ver.2 compatible stations that occupy 2 stations which are set to "Quadruple". c4: The number of ver.2 compatible stations that occupy 3 stations which are set to "Quadruple". d4: The number of ver.2 compatible stations that occupy 4 stations which are set to "Quadruple". a8: The number of ver.2 compatible stations that occupy 1 station which are set to "Octuple". (ME96 is applied) b8: The number of ver.2 compatible stations that occupy 2 stations which are set to "Octuple". c8: The number of ver.2 compatible stations that occupy 3 stations which are set to "Octuple". d8: The number of ver.2 compatible stations that occupy 4 stations which are set to "Octuple".
Condition 4	$\{(16 \times A) + (54 \times B) + (88 \times C)\} \leq 2304$	A: Number of remote I/O stations ≤ 64 B: Number of remote device stations (ME96 is applied) ≤ 42 C: Number of local stations, standby master stations and intelligent device stations ≤ 26



4. Programming

4.1 Programming Procedure

Create a program which executes the “Monitoring of the measurement value” by following the procedure below:



5. Parameter Settings

5.1 Procedure from Parameter Settings to Data Link Startup

The following explains the procedure from setting the parameters to starting the data link.

5.1.1 CPU Parameter Area and Master Module Parameter Memory


(1) CPU Parameter Area

This area is used to set the basic values for controlling the programmable controller system and the network parameters that control the CC-Link system.

(2) Master Station Parameter Memory


This area stores the network parameters for the CC-Link system.

When the module is powered OFF or the programmable controller CPU is reset, the network parameters are erased.




5.1.2 Procedure for Parameter Settings to Data Link Startup with GX Developer

Follow the procedure below for parameter settings to data link startup:



5.2 Example of Parameter Settings with GX Developer (Remote net ver.2 mode)


This section explains the parameter settings using the GX Developer. For more details on the GX Developer operation, refer to the GX Developer Operating Manual. The explanations in this section are based on the following example of the system configuration.



5.2.1 Master Station Network Parameter Settings

- 1) Double-click on the “Network param”.
- 2) Double-click on the “CC-Link” on the “Network parameter” screen.
- 3) Set the parameters as required.

The following describes an example of the parameter settings.



Setting Item	Description	Example for settings	Remarks
No.of boards in module	Set the "No. of boards in module " for which the network parameters are to be set.	1	
Start I/O No	Set the "Start I/O No." for the master station.	0000	
Operational settings	Set the following: ·Parameter name ·Data link err station setting ·Case of CPU Stop setting ·Block data assurance per station	Refer to next page.	Even if the Parameter name is not set, this will not affect the operation of the CC-Link system
Type	Set the station type.	Master station	
Mode	Set the CC-Link mode.	Remote net (Ver.2 mode)	
All connect count	Set the total number of connected stations in the CC-Link system including reserved stations.	2 (modules)	
Remote input (RX)	Set the remote input (RX) refresh device.	X1000	Device name - Select from X, M, L, B, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote output (RY)	Set the remote output (RY) refresh device.	Y1000	Device name - Select from Y, M, L, B, T, C, ST, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RW _r)	Set the remote register (RW _r) refresh device.	W0	Device name - Select from M, L, B, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RW _w)	Set the remote register (RW _w) refresh device.	W1000	Device name - Select from M, L, B, T, C, ST, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Special relay (SB)	Set the link special relay (SB) refresh device.	SB0	Device name - Select from M, L, B, D, W, R, SB or ZR. Device number - Within the range of the device points that the CPU has.
Special register (SW)	Set the link special register (SW) refresh device.	SW0	Device name - Select from M, L, B, D, W, R, SW or ZR. Device number - Within the range of the device points that the CPU has.
Retry count	Set the number of retries for "Retry count", when a communication error occurs.	3	
Automatic reconnection station count	Set the number of modules that can return to system operation by a single link scan.	1	
Standby master station No.	Set the station number for the standby master station	Blank	Blank: No standby master station specified.
PLC down select	Set the data link status for "PLC down select", when a master station programmable controller CPU error occurs.	Stop	
Scan mode setting	Set whether the link scan for the sequence scan is synchronous or asynchronous.	Asynchronous	
Delay information setting	Set for the link scan delay time.	0	
Station information settings	Set the station data.	Refer to the next page.	


POINT

(1) For the automatic refresh parameter setting, set the start device only. Devices are automatically assigned until the last station number including reserved stations and occupied stations.

In the example of the system configuration in this section, the last station number is "2". Therefore, total of remote I/O points is 256 points ($128 \times 2 = 256$) and total of remote registers points is 64 points ($32 \times 2 = 64$). If refresh device of remote input (RX) is set to "X1000" and that of remote registers (RWr) is set to "W0", the end devices will be "X10FF" and "W3F" respectively.


(2) When setting X, Y, B, W, SB and SW as refresh devices, make setting so that they do not overlap with the device numbers used on the other networks, etc.

《Example for Operational settings》



Setting Item	Description	Example for settings	Remarks
Parameter name	Set the Parameter name.	"SAMPLE"	Even if the Parameter name is not set, this will not affect the operation of the CC-Link system
Data link disorder station setting	Set the input status for the data link error station.	Clear ("Hold input data" not checked)	
Case of CPU Stop setting	Set the slave station refresh/compulsory clear setting at programmable controller CPU STOP.	Refresh ("Clears compulsorily" not checked)	
Block data assurance per station	Set the block guarantee of cyclic data per station.	Disable ("Enable setting" not checked)	

《Example for Station information settings》



Setting Item	Description	Example for settings	Remarks
Station type	Set the station data.	Ver2. Remote device station	Set the "ver2.00" in Setting Menu 7 of ME96.
Expanded cyclic setting		octuple	ME96 cannot use other than "octuple".
Number of occupied stations *		Occupies 1 station	Set the "Occupies 1 station" in case of the ME96.
Remote station points		128 points	Set the "128 points" in case of the ME96.
Reserved/invalid station select		No setting	

* "Number of exclusive stations" on the screen is described as "Number of occupied stations" in this manual.

"Exclusive station 1" on the screen is described as "Occupies 1 station" in this manual

6. Communication Between the Master Station and ME96

6.1 Communication Guideline

There are three communication statuses (Initial Communication, Normal Communication, Error Communication) between the Master station and ME96.

In the normal communication, alarm status and digital input status of ME96 can be monitored using bit data (remote input RX). Furthermore, the following can be performed by using remote input, remote output and remote registers.

- Monitoring by Pattern
- Monitoring by Command(1H).
- Setting by Command(2H).

For a monitoring by pattern, some measuring values can be monitored by selecting a bit of RY. Measuring values which can be monitored have been already grouping in ME96 in advance. Please select the necessary group in a bit of RY.


For a monitoring by command(1H), you can select any measurement items to be monitored. ME96 has unique codes (called unit No., group No. and channel No.) for each measurement items. You can monitor the selected measurement items by writing these codes to the remote registers.

For a setting by command(2H), you can set for ME96 settings.

* All measuring items can be monitored even when it is not displayed in ME96.


6.2 Initial Communication

Initial communication is performed at the beginning after the power supply is turned on or hardware is reset. Refer to section 7.1 about the remote input RX and the remote output RY.



- ① After the power supply is turned on, or hardware is reset, the initial data processing request flag is turned on by ME96.
- ② After the initial data processing request flag is turned on, turn on the initial data setting completion flag.
- ③ After the initial data setting completion flag is turned on, the initial data processing request flag is turned off and the remote READY is turned on.
- ④ After the initial data processing request flag is turned off, turned off the initial data setting completion flag.

6.3 Error Communication



- ① When an error occurs in ME96, error status flag is turned on and the remote READY is turned off.
- ② When the error status flag is turned on, read the error code from the remote register RWr. Eliminate the cause of the error while referring to the red error code. When resuming communication with ME96, turn on the error reset request flag.
- ③ After the error reset request flag is turned on, the error status flag is turned off.
- ④ After the error status flag is turned off, turn off the error reset request flag.
- ⑤ After the error reset request flag is turned off, the remote READY is turned on and normal communication is resumed.


Note: Refer to "7.2.6 About error occurrence" for error code.

6.4 Normal Communication

After initial data processing is complete, allows the monitoring by pattern, monitoring by command(1H) and setting by command(2H).

6.4.1 Monitoring by Pattern

Up to 16 measuring values can be monitored by setting a bit of RY. Measuring values which can be monitored have been already grouped in ME96 in advance. Therefore, select the necessary group in a bit of RY. (Refer to section 7.1.2)



(1) Start of monitor

- ① Turns on monitor pattern setting flag(RY(n+1)m) which will be monitored.
- ② Corresponding setting completion flag(RX(n+1)m) is turned on when the measuring values can be monitored at ME96. At this time, Measuring values are stored in remote registers(RWr) each time the measuring data of ME96 is updating.


(2) End of monitor

- ③ Turns off monitor pattern setting flag(RY(n+1)m).
- ④ Corresponding setting completion flag(RX(n+1)m) is turned off and remote registers are 00h.

Note: When turns on multiple monitor pattern setting flag(RY(n+1)*), setting completion flag is not turned on. At this time, error status flag(RX(n+7)A) is turned on, and remote READY(RX(n+7)B) is turned off.

6.4.2 Monitoring by Command(1H)

Up to 8 measuring values can be monitored by setting the unique codes (called unit No., group No. and channel No.).




(1) Start of monitor

- ① Writes the Unit No., group No and channel No. for measuring items to be monitored to remote registers(RWw).
- ② Turns on monitor pattern setting flag(RY(n+1)0).
- ③ When the measuring values can be monitored with ME96, corresponding setting completion flag(RX(n+1)0) is turned on. At this time, Measuring values are stored in remote registers(RWr) each time the measuring data of ME96 is updating.

(2) End of monitor


- ④ Turns off monitor pattern setting flag(RY(n+1)0).
- ⑤ Corresponding setting completion flag(RX(n+1)m) is turned off and remote registers are 00h.

Note: When monitor pattern setting flag(RY(n+1)0) remains on, measuring items in remote registers(RWr) is not reflected if remote registers(RWw) is changed. To change measuring items, turns on monitor pattern setting flag(RY(n+1)0) after changing remote registers(RWw).



6.4.3 Setting by Command(2H)

A setting item of ME96 can be set by setting the unique codes (called unit No., group No. and channel No.) and setting data.



(1) Setting

- ① Writes the Unit No., group No, channel No. and setting data to remote registers(RWw).
- ② Turns on monitor pattern setting flag(RY(n+1)0).
- ③ After checking for data at ME96, corresponding setting completion flag(RX(n+1)0) is turned on. At this time, response data are stored in remote registers(RWr).

(2) End of setting

- ④ Turns off monitor pattern setting flag(RY(n+1)0).
- ⑤ Corresponding setting completion flag(RX(n+1)m) is turned off and remote registers are 00h.

Note: When monitor pattern setting flag(RY(n+1)0) remains on, setting data of ME96 is not reflected if remote registers(RWw) is changed. To change setting data, turns on monitor pattern setting flag(RY(n+1)0) after writing remote registers(RWw).

7. Remote I/O and Remote Register

7.1 Remote Input RX, Remote Output RY

The remote input RX and remote output RY are used to communicate for bit data between the master station and ME96.

7.1.1 Remote input RX

The allocation of the remote input RX of ME96 is shown in the table below.

Device No.	Signal name	ME96SSR	ME96SSH ME96SSHA ME96SSRA ME96SSHB ME96SSRB	Description		Note
				OFF(0)	ON(1)	
RXn0	Digital Input 1 (DI1)	○	○	—	—	
RXn1	Digital Input 2 (DI2)	○	○	—	—	
RXn2	Digital Input 3 (DI3)	○	○	Non-Alarm state	Alarm state	
RXn3	Digital Input 4 (DI4)	○	○	Non-Alarm state	Alarm state	
RXn4	Reserved	—	—	OFF	ON	
RXn5	Alarm (Total)	○	○	Non-Alarm state	Alarm state	
RXn6	Alarm of Current Demand	○	○	OFF	ON	*2
RXn7	Alarm of Rolling Demand (Total)	—	○	OFF	ON	*2,*3
RXn8	Alarm of Voltage	○	○	Non-Alarm state	Alarm state	*2
RXn9	Alarm of Current	○	○	Non-Alarm state	Alarm state	*2
RXnA	Alarm of Active power	○	○	Non-Alarm state	Alarm state	*2
RXnB	Alarm of Reactive power	○	○	Non-Alarm state	Alarm state	*2
RXnC	Alarm of Frequency	○	○	Non-Alarm state	Alarm state	*2
RXnD	Alarm of Power factor	○	○	Non-Alarm state	Alarm state	*2
RXnE	Alarm of T.H.D (Voltage)	○	○	Non-Alarm state	Alarm state	*2
RXnF	Alarm of harmonic current	○	○	Non-Alarm state	Alarm state	*2
RX(n+1)0	Setting completion flag P00	○	○	Not receiving	Receiving	
RX(n+1)1 to RX(n+1)7	Reserved	—	—	—	—	
RX(n+1)8	Setting completion flag P08	○	○	Not receiving	Receiving	
RX(n+1)9	Setting completion flag P09	○	○	Not receiving	Receiving	
RX(n+1)A	Setting completion flag P10	○	○	Not receiving	Receiving	
RX(n+1)B	Setting completion flag P11	○	○	Not receiving	Receiving	
RX(n+1)C	Setting completion flag P12	○	○	Not receiving	Receiving	
RX(n+1)D to RX(n+7)7	Reserved	—	—	—	—	
RX(n+7)8	Initial data processing request flag	○	○	Power OFF, remote READY ON, or error status flag ON	Power supply is turned ON or hardware reset	*1
RX(n+7)9	Reserved	—	—	—	—	
RX(n+7)A	Error status flag	○	○	No error occurrence	Error occurrence	*1
RX(n+7)B	Remote READY	○	○	Monitoring or setting are not possible	Normally communication status	*1
RX(n+7)C to RX(n+7)F	Reserved	—	—	—	—	


*1: For the details, refer to "6.Communication Between the Master Station and ME96"

*2: "ON(1)" shows the state where the upper limit or the lower limit is exceeded.

*3: In case of ME96SSHA/ME96SSRA/ME96SSHB/ME96SSRB, the alarm state is total of the rolling demand W/var/VA.

Note: "n" in the table is determined by the station number of ME96.

- (1) Relationships between programmable controller CPU, master module and ME96(RX)
- 1) The input status of ME96 is stored automatically (for each link scan) in the master station's "remote input RX" buffer memory.
 - 2) The input status stored in the "remote input RX" buffer memory is stored in the CPU device set with the automatic refresh parameters.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	X1000 to X107F	15	X1700 to X177F	29	X1E00 to X1E7F
2	X1080 to X10FF	16	X1780 to X17FF	30	X1E80 to X1EFF
3	X1100 to X117F	17	X1800 to X187F	31	X1F00 to X1F7F
4	X1180 to X11FF	18	X1880 to X18FF	32	X1F80 to X1FFF
5	X1200 to X127F	19	X1900 to X197F	33	X2000 to X207F
6	X1280 to X12FF	20	X1980 to X19FF	34	X2080 to X20FF
7	X1300 to X137F	21	X1A00 to X1A7F	35	X2100 to X217F
8	X1380 to X13FF	22	X1A80 to X1AFF	36	X2180 to X21FF
9	X1400 to X147F	23	X1B00 to X1B7F	37	X2200 to X227F
10	X1480 to X14FF	24	X1B80 to X1BFF	38	X2280 to X22FF
11	X1500 to X157F	25	X1C00 to X1C7F	39	X2300 to X237F
12	X1580 to X15FF	26	X1C80 to X1CFF	40	X2380 to X23FF
13	X1600 to X167F	27	X1D00 to X1D7F	41	X2400 to X247F
14	X1680 to X16FF	28	X1D80 to X1DFF	42	X2480 to X24FF

Device No. is determined to "X1000 to X24FF" if refresh device of remote input (RX) is set to "X1000".

7.1.2 Remote Output RY

The allocation of the remote output RY of ME96 is shown in the table below.

Device No.	Signal name	Description		Note
		ON(1)→OFF(0)	OFF(0)→ON(1)	
RYn0 to RYnF	Reserved	—	—	
RY(n+1)0	Monitor pattern setting flag P00	Not setting	Setting	
RY(n+1)1 to RY(n+1)7	Reserved	—	—	
RY(n+1)8	Monitor pattern setting flag P08	Not setting	Setting	
RY(n+1)9	Monitor pattern setting flag P09	Not setting	Setting	
RY(n+1)A	Monitor pattern setting flag P10	Not setting	Setting	
RY(n+1)B	Monitor pattern setting flag P11	Not setting	Setting	
RY(n+1)C	Monitor pattern setting flag P12	Not setting	Setting	
RY(n+1)D to RY(n+7)7	Reserved	—	—	
RY(n+7)8	Initial data setting completion flag	Cancel normal communication request	Normal communication request	*1
RY(n+7)9	Unusable	—	—	
RY(n+7)A	Error reset request flag	Cancel error reset request	Error reset request	*1
RY(n+7)B to RY(n+7)F	Unusable	—	—	


*1: For the details, refet to “6.Communication Between the Master Station and ME96”

Note: The “n” in the table is determined by the station number of ME96.

Warning

Do not read or write to reserved remote registers. If reading or writing is performed, the functions of ME96 are not guaranteed.

- (1) Relationships between programmable controller CPU, master module and ME96(RY)
- 1) The on/off data of the CPU device set with the automatic refresh parameters is stored in the "remote output RY" buffer memory.
 - 2) Remote output RY is automatically set to on/off (for each link scan) according to the output status stored in the "remote output RY" buffer memory.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	Y1000 to Y107F	15	Y1700 to Y177F	29	Y1E00 to Y1E7F
2	Y1080 to Y10FF	16	Y1780 to Y17FF	30	Y1E80 to Y1EFF
3	Y1100 to Y117F	17	Y1800 to Y187F	31	Y1F00 to Y1F7F
4	Y1180 to Y11FF	18	Y1880 to Y18FF	32	Y1F80 to Y1FFF
5	Y1200 to Y127F	19	Y1900 to Y197F	33	Y2000 to Y207F
6	Y1280 to Y12FF	20	Y1980 to Y19FF	34	Y2080 to Y20FF
7	Y1300 to Y137F	21	Y1A00 to Y1A7F	35	Y2100 to Y217F
8	Y1380 to Y13FF	22	Y1A80 to Y1AFF	36	Y2180 to Y21FF
9	Y1400 to Y147F	23	Y1B00 to Y1B7F	37	Y2200 to Y227F
10	Y1480 to Y14FF	24	Y1B80 to Y1BFF	38	Y2280 to Y22FF
11	Y1500 to Y157F	25	Y1C00 to Y1C7F	39	Y2300 to Y237F
12	Y1580 to Y15FF	26	Y1C80 to Y1CFF	40	Y2380 to Y23FF
13	Y1600 to Y167F	27	Y1D00 to Y1D7F	41	Y2400 to Y247F
14	Y1680 to Y16FF	28	Y1D80 to Y1DFF	42	Y2480 to Y24FF

Device No. is determined to "Y1000 to Y24FF" if refresh device of remote output (RY) is set to "Y1000".


7.2 Remote Register (RWr, RWw)

The remote registers RWr and RWw are used to communicate word data between the master station and ME96. Because it occupies 1 station(Expanded cyclic setting: octuple), the remote registers RWr and RWw each have 32 words in length.

For monitoring by pattern, it is not necessary to use remote registers(RWw). Selected measuring values which are set a bit of RY are stored in remote registers(RWr).

For monitoring by command(1H) and setting by command(2H), it is necessary to use remote registers(RWw). ME96 has unique codes (called unit No., group No. and channel No.) for each measurement items and setting items. It becomes possible to monitor each measurement values or set each parameters by writing into the remote registers(RWw) of the master station command and the related data allocated to the item you want to monitor or set.


- (1) Relationships between programmable controller CPU, master module and ME96(RWr)
- 1) The remote registers RWr data of a remote device station is automatically stored in the "remote registers RWr" buffer memory of the master station.
 - 2) The remote registers RWr data of ME96 stored in the "remote registers RWr" buffer memory is stored in the CPU device set with the automatic refresh parameters.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	W0000 to W001F	15	W01C0 to W01DF	29	W0380 to W039F
2	W0020 to W003F	16	W01E0 to W01FF	30	W03A0 to W03BF
3	W0040 to W005F	17	W0200 to W021F	31	W03C0 to W03DF
4	W0060 to W007F	18	W0220 to W023F	32	W03E0 to W03FF
5	W0080 to W009F	19	W0240 to W025F	33	W0400 to W041F
6	W00A0 to W00BF	20	W0260 to W027F	34	W0420 to W043F
7	W00C0 to W00DF	21	W0280 to W029F	35	W0440 to W045F
8	W00E0 to W00FF	22	W02A0 to W02BF	36	W0460 to W047F
9	W0100 to W011F	23	W02C0 to W02DF	37	W0480 to W049F
10	W0120 to W013F	24	W02E0 to W02FF	38	W04A0 to W04BF
11	W0140 to W015F	25	W0300 to W031F	39	W04C0 to W04DF
12	W0160 to W017F	26	W0320 to W033F	40	W04E0 to W04FF
13	W0180 to W019F	27	W0340 to W035F	41	W0500 to W051F
14	W01A0 to W01BF	28	W0360 to W037F	42	W0520 to W053F

Device No. is determined to "W0000 to W053F" if refresh device of remote registers (RWr) is set to "W0".

- (2) Relationships between programmable controller CPU, master module and ME96(RWw)
- 1) The transmission data of the CPU device set with the automatic refresh parameters is stored in the "remote registers RWw" buffer memory.
 - 2) The data stored in the "remote registers RWw" buffer memory is automatically sent to the remote registers RWw of each remote device station.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	W1000 to W101F	15	W11C0 to W11DF	29	W1380 to W139F
2	W1020 to W103F	16	W11E0 to W11FF	30	W13A0 to W13BF
3	W1040 to W105F	17	W1200 to W121F	31	W13C0 to W13DF
4	W1060 to W107F	18	W1220 to W123F	32	W13E0 to W13FF
5	W1080 to W109F	19	W1240 to W125F	33	W1400 to W141F
6	W10A0 to W10BF	20	W1260 to W127F	34	W1420 to W143F
7	W10C0 to W10DF	21	W1280 to W129F	35	W1440 to W145F
8	W10E0 to W10FF	22	W12A0 to W12BF	36	W1460 to W147F
9	W1100 to W111F	23	W12C0 to W12DF	37	W1480 to W149F
10	W1120 to W113F	24	W12E0 to W12FF	38	W14A0 to W14BF
11	W1140 to W115F	25	W1300 to W131F	39	W14C0 to W14DF
12	W1160 to W117F	26	W1320 to W133F	40	W14E0 to W14FF
13	W1180 to W119F	27	W1340 to W135F	41	W1500 to W151F
14	W11A0 to W11BF	28	W1360 to W137F	42	W1520 to W153F

Device No. is determined to "W1000 to W153F" if refresh device of remote registers (RWw) is set to "W1000".

7.2.1 When Monitoring by Pattern

The following table shows correspondence between RY and grouped measuring items.

Table 7.1 Correspondence between RY and grouped measuring items

device.	P08	P09	P10	P11	P12
	RY(n+1)8	RY(n+1)9	RY(n+1)A	RY(n+1)B	RY(n+1)C
RWr00	Phase 1 current (Inst.)[A]	Phase 1 current demand (Inst.)[A]	Phase N current (Inst.)[A]	Phase 1 current (Inst.)[A]	Phase N current (Inst.)[A]
RWr01				Phase 2 current (Inst.)[A]	Phase N current demand (Inst.)[A]
RWr02	Phase 2 current (Inst.)[A]	Phase 2 current demand (Inst.)[A]	Phase N current demand (Inst.)[A]	Phase 3 current (Inst.)[A]	1-N Voltage (Inst.)[V]
RWr03				Phase 1 current demand (Inst.)[A]	2-N Voltage (Inst.)[V]
RWr04	Phase 3 current (Inst.)[A]	Phase 3 current demand (Inst.)[A]	1-N Voltage (Inst.)[V]	Phase 2 current demand (Inst.)[A]	3-N Voltage (Inst.)[V]
RWr05				Phase 3 current demand (Inst.)[A]	Average current (Inst.)[A]
RWr06	1-2 Voltage (Inst.)[V]	Total rolling demand (Last)[kW] *1	2-N Voltage (Inst.)[V]	1-2 Voltage (Inst.)[V]	Average current demand (Inst.)[A]
RWr07				2-3 Voltage (Inst.)[V]	Average L-L voltage (Inst.)[V]
RWr08	2-3 Voltage (Inst.)[V]	Total power factor (Inst.)[%]	3-N Voltage (Last)[V]	3-1 Voltage (Inst.)[V]	Average L-N voltage (Inst.)[V]
RWr09				Total active power (Inst.)[kW]	00h (No items)
RWr0A	3-1 Voltage (Inst.)[V]	Frequency (Inst.)[Hz]	00h (No items)	Total rolling demand (Inst.)[kW] *1	00h (No items)
RWr0B				Total reactive power (Inst.)[kvar]	00h (No items)
RWr0C	Total active power (Inst.)[kW]	Total reactive power (Inst.)[kvar]	00h (No items)	Total power factor (Inst.)[%]	00h (No items)
RWr0D				Frequency (Inst.)[Hz]	00h (No items)
RWr0E	Active energy import[kWh]	Reactive energy import lag [kvarh]	00h (No items)	Active energy import[kWh]	00h (No items)
RWr0F				Reactive energy import lag [kvarh]	00h (No items)
RWr10	Group format	①	①	①	②
RWr11		①	①	①	②
RWr12		①	①	①	②
RWr13		①	①	①	②
RWr14		①	①	①	②
RWr15		①	①	①	②
RWr16		①	①	①	②
RWr17		①	①	①	②
RWr18		①	①	①	②
RWr19		①	①	①	②
RWr1A		①	①	①	②
RWr1B		①	①	①	②
RWr1C		①	①	①	②
RWr1D		①	①	①	②
RWr1E		①	①	①	②
RWr1F		①	①	①	②
Group format	①	①	①	①	②

Inst.: Instantaneous value

*1: Applicable only when ME96SSH-MB/ME96SSHA-MB/ME96SSRA-MB/ME96SSHB-MB/ME96SSRB-MB.

("Last" means the rolling demand value of the latest interval time completed.)

Note: "["]" in the above table indicate the unit of measuring items.

Note: P10 and P12 can be used for 3P4W only. In others, the error will occur.

Note: For the active power (demand) and reactive power, ±1638.3MW(Mvar) becomes the upper(lower) value.

Note: For the power factor, "+" is showed lag, "-" is showed lead as with ME96's display.

Note: Measurement data correspond as follows according to setting of phase wiring.

Name of channel	Phase wiring			
	3P3W	1P3W(1N3)	1P3W(1N2)	1P2W
1-2 voltage	1-2 voltage	1-N voltage	1-N voltage	Voltage
2-3 voltage	2-3 voltage	3-N voltage	2-N voltage	-
3-1 voltage	3-1 voltage	1-3 voltage	1-3 voltage	-
Phase 1 current	Phase 1 current	Phase 1 current	Phase 1 current	Current
Phase 2 current	Phase 2 current	Phase N current	Phase N current	-
Phase 3 current	Phase 3 current	Phase 3 current	Phase 2 current	-

(1) Group format ①

For group format ①, Up to 8 measuring items can be monitored per a group. Measuring items are expressed in 4 words.

Group format ①			
RWr00	b15	b8	b7 b0
RWr00	Channel No.	Group No.	
RWr01	Index number	00h	
RWr02	Low data		
RWr03	High data		
RWr04	Channel No.	Group No.	
RWr05	Index number	00h	
RWr06	Low data		
RWr07	High data		
RWr08	Channel No.	Group No.	
RWr09	Index number	00h	
RWr0A	Low data		
RWr0B	High data		
RWr0C	Channel No.	Group No.	
RWr0D	Index number	00h	
RWr0E	Low data		
RWr0F	High data		
RWr10	Channel No.	Group No.	
RWr11	Index number	00h	
RWr12	Low data		
RWr13	High data		
RWr14	Channel No.	Group No.	
RWr15	Index number	00h	
RWr16	Low data		
RWr17	High data		
RWr18	Channel No.	Group No.	
RWr19	Index number	00h	
RWr1A	Low data		
RWr1B	High data		
RWr1C	Channel No.	Group No.	
RWr1D	Index number	00h	
RWr1E	Low data		
RWr1F	High data		


<Channel No., Group No.>
ME96 returns fixed data determined for each measuring items. (About fixed data, refer to Table 7.2 to Table 7.13)
(Example: When selected phase 1 current (Inst), channel No. is 21h, group No. is 01h.)

<Multiplying factor>
Multiplying factor is fixed for each items according to phase wire system, primary voltage and primary current.(For details, refer to Table 7.23)

■ Correspondence of index number and multiplying factor.

Index number	Multiplying factor	Remarks
02H	$\times 10^2$	Actual value = Numerical value \times Multiplying factor
01H	$\times 10$	
00H	$\times 1$	
FFH	$\times 10^{-1}$	
FEH	$\times 10^{-2}$	
FDH	$\times 10^{-3}$	
FCH	$\times 10^{-4}$	

<Numerical value>



Numerical value: 32-bit integer with a sign
 $-2147483648 \sim 2147483647$
 $(80000000H \sim 7FFFFFFFH)$

■ Example: Active power


Index number	Data (Numerical value)	Actual value
FFH	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kW}]$
00H	FFFFFFFFFFH $\Rightarrow -255$	$-255 \times 1 = -255[\text{kW}]$

■ Example: power factor

Index number	Data (Numerical value)	Actual value
FFH	000003E3H $\Rightarrow 995$	$995 \times 10^{-1} = 99.5[\%]$
FFH	FFFFFC1DH $\Rightarrow -995$	$-995 \times 10^{-1} = -99.5[\%]$

(2) Group format ②

For group format ②, Up to 16 measuring items can be monitored per a group. Measuring items are expressed in 2 words. However, it is necessary to be multiplied by using Table 7.23 because there is no multiplying factor data .




7.2.2 When Monitoring by Command(1H)

Up to 8 measuring values can be monitored by setting the unit No., group No. and channel No. to remote registers(RWw). Monitor pattern setting flag(RX(n+1)0) is used to send the command. (For details, refer to section 6.4.2)

The command can be sent only when the remote READY(RX(n+7)B) is ON.

1H	Data Monitor																																																																																																																								
<table border="1"> <thead> <tr> <th colspan="4">Remote register RWw (Programmable controller → ME96)</th> </tr> <tr> <th></th><th>b15</th><th>b8</th><th>b7 b0</th></tr> </thead> <tbody> <tr> <td>RWw00</td><td>Group No.</td><td>Unit No.</td><td>1H</td></tr> <tr> <td>RWw01</td><td>00H</td><td>Channel No.</td><td></td></tr> <tr> <td>RWw02</td><td>00H</td><td>00H</td><td></td></tr> <tr> <td>RWw03</td><td>00H</td><td>00H</td><td></td></tr> <tr> <td>RWw04</td><td>Group No.</td><td>Unit No.</td><td>1H</td></tr> <tr> <td>RWw05</td><td>00H</td><td>Channel No.</td><td></td></tr> <tr> <td>RWw06</td><td>00H</td><td>00H</td><td></td></tr> <tr> <td>RWw07</td><td>00H</td><td>00H</td><td></td></tr> <tr> <td>to</td><td>to</td><td></td><td></td></tr> <tr> <td>RWw1C</td><td>Group No.</td><td>Unit No.</td><td>1H</td></tr> <tr> <td>RWw1D</td><td>00H</td><td>Channel No.</td><td></td></tr> <tr> <td>RWw1E</td><td>00H</td><td>00H</td><td></td></tr> <tr> <td>RWw1F</td><td>00H</td><td>00H</td><td></td></tr> </tbody> </table>	Remote register RWw (Programmable controller → ME96)					b15	b8	b7 b0	RWw00	Group No.	Unit No.	1H	RWw01	00H	Channel No.		RWw02	00H	00H		RWw03	00H	00H		RWw04	Group No.	Unit No.	1H	RWw05	00H	Channel No.		RWw06	00H	00H		RWw07	00H	00H		to	to			RWw1C	Group No.	Unit No.	1H	RWw1D	00H	Channel No.		RWw1E	00H	00H		RWw1F	00H	00H		<table border="1"> <thead> <tr> <th colspan="4">Remote register RWw (ME96 → Programmable controller)</th> </tr> <tr> <th></th><th>b15</th><th>b8</th><th>b7 b0</th></tr> </thead> <tbody> <tr> <td>RWr00</td><td>Channel No.</td><td>Group No.</td><td></td></tr> <tr> <td>RWr01</td><td>Index number</td><td>(Error code)</td><td></td></tr> <tr> <td>RWr02</td><td>Low data</td><td></td><td></td></tr> <tr> <td>RWr03</td><td>High data</td><td></td><td></td></tr> <tr> <td>RWr04</td><td>Channel No.</td><td>Group No.</td><td></td></tr> <tr> <td>RWr05</td><td>Index number</td><td>(Error code)</td><td></td></tr> <tr> <td>RWr06</td><td>Low data</td><td></td><td></td></tr> <tr> <td>RWr07</td><td>High data</td><td></td><td></td></tr> <tr> <td>to</td><td>to</td><td></td><td></td></tr> <tr> <td>RWr1C</td><td>Channel No.</td><td>Group No.</td><td></td></tr> <tr> <td>RWr1D</td><td>Index number</td><td>(Error code)</td><td></td></tr> <tr> <td>RWr1E</td><td>Low data</td><td></td><td></td></tr> <tr> <td>RWr1F</td><td>High data</td><td></td><td></td></tr> </tbody> </table>	Remote register RWw (ME96 → Programmable controller)					b15	b8	b7 b0	RWr00	Channel No.	Group No.		RWr01	Index number	(Error code)		RWr02	Low data			RWr03	High data			RWr04	Channel No.	Group No.		RWr05	Index number	(Error code)		RWr06	Low data			RWr07	High data			to	to			RWr1C	Channel No.	Group No.		RWr1D	Index number	(Error code)		RWr1E	Low data			RWr1F	High data		
Remote register RWw (Programmable controller → ME96)																																																																																																																									
	b15	b8	b7 b0																																																																																																																						
RWw00	Group No.	Unit No.	1H																																																																																																																						
RWw01	00H	Channel No.																																																																																																																							
RWw02	00H	00H																																																																																																																							
RWw03	00H	00H																																																																																																																							
RWw04	Group No.	Unit No.	1H																																																																																																																						
RWw05	00H	Channel No.																																																																																																																							
RWw06	00H	00H																																																																																																																							
RWw07	00H	00H																																																																																																																							
to	to																																																																																																																								
RWw1C	Group No.	Unit No.	1H																																																																																																																						
RWw1D	00H	Channel No.																																																																																																																							
RWw1E	00H	00H																																																																																																																							
RWw1F	00H	00H																																																																																																																							
Remote register RWw (ME96 → Programmable controller)																																																																																																																									
	b15	b8	b7 b0																																																																																																																						
RWr00	Channel No.	Group No.																																																																																																																							
RWr01	Index number	(Error code)																																																																																																																							
RWr02	Low data																																																																																																																								
RWr03	High data																																																																																																																								
RWr04	Channel No.	Group No.																																																																																																																							
RWr05	Index number	(Error code)																																																																																																																							
RWr06	Low data																																																																																																																								
RWr07	High data																																																																																																																								
to	to																																																																																																																								
RWr1C	Channel No.	Group No.																																																																																																																							
RWr1D	Index number	(Error code)																																																																																																																							
RWr1E	Low data																																																																																																																								
RWr1F	High data																																																																																																																								
	<p>* At normal communication, Error code is 00h. About the other error code, refer to Table 7.24.</p>																																																																																																																								

* It is described as 8 bits data by combining the unit No. (high 4 bits) and the command (low 4 bits)



For example, When the unit No. is 0H and the command is 1H, it becomes "01H".

- ME96 can monitor the value of measurement items which are not displayed.
- The measurement items are assigned Unit No., Group No. and Channel No. (Refer to Table 7.2 to Table 7.13)
- Store the unused space to 00H when monitoring items are under 8.
- The details of data format are shown in the Table 7.15 to Table 7.22
- The monitoring items are changed with the model and the setting of phase wire system.(Refer to Table 7.2 to Table 7.13) If the invalid item is monitored, the error code will be reply.
- When combined command(2H), an error occurs.
- In case of monitoring the present value and its maximum continuously according to the renewal data timing of ME96, the maximum may be smaller than the present value.

Table 7.2 Group Channel List (1/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note	
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W	1P2W	
0	F0	02	Model code			○	○	○	○	○	○	○	○	⑥
0	E0	11	Primary current			○	○	○	○	○	○	○	○	⑤
0	E0	12	Primary voltage(L-L)			- (*6)	○	○	○	- (*6)	○	○	○	⑤
0	E0	18	Primary voltage(L-N)			○	-	-	○	-	-	-	-	⑤
0	E0	1C	Secondary voltage(L-N)			○	○	○	○	○	○	○	○	⑤
0	E0	13	Phase & Wiring			○	○	○	○	○	○	○	○	⑥
0	E0	1D	Frequency			○	○	○	○	○	○	○	○	⑤
0	E0	1E	Secondary current			○	○	○	○	○	○	○	○	⑤
0	E0	18	Alarm items			○	○	○	○	○	○	○	○	⑦
0	E0	19	Byte monitor			○	○	○	○	○	○	○	○	⑥
0	E0	1A	Attribute monitor			○	○	○	○	○	○	○	○	⑥
0	02	E0	Time constant for current demand	sec.		○	○	○	○	○	○	○	○	⑥
0	08	E4	Interval time constant	min.		○	○	○	○	○(*4)	○(*4)	○(*4)	○(*4)	⑥
0	08	E5	Subinterval time constant	min.		○	○	○	○	○(*4)	○(*4)	○(*4)	○(*4)	⑥
0	01	01	Average current	A	Inst.	○	○	-	○	○	○	-	-	①
0	01	21	Phase 1 current	A	Inst.	○	○	○	○	○	○	○	○	①
0	01	41	Phase 2 current	A	Inst.	○	○	-	○	○	○	-	-	①
0	01	61	Phase 3 current	A	Inst.	○	○	-	○	○	○	-	-	①
0	01	81	Phase N current	A	Inst.	○	-	-	○	-	-	-	-	①
0	01	02	Average current	A	max.	○	○	-	○	○	○	-	-	①
0	01	22	Phase 1 current	A	max.	○	○	○	○	○	○	○	○	①
0	01	42	Phase 2 current	A	max.	○	○	-	○	○	○	-	-	①
0	01	62	Phase 3 current	A	max.	○	○	-	○	○	○	-	-	①
0	01	82	Phase N current	A	max.	○	-	-	○	-	-	-	-	①
0	01	05	Average current	A	min.	○	○	-	○	○	○	-	-	①
0	01	25	Phase 1 current	A	min.	○	○	○	○	○	○	○	○	①
0	01	45	Phase 2 current	A	min.	○	○	-	○	○	○	-	-	①
0	01	65	Phase 3 current	A	min.	○	○	-	○	○	○	-	-	①
0	01	85	Phase N current	A	min.	○	-	-	○	-	-	-	-	①
0	02	01	Average current demand	A	Inst.	○	○	-	○	○	○	-	-	①
0	02	21	Phase 1 current demand	A	Inst.	○	○	○	○	○	○	○	○	①
0	02	41	Phase 2 current demand	A	Inst.	○	○	-	○	○	○	-	-	①
0	02	61	Phase 3 current demand	A	Inst.	○	○	-	○	○	○	-	-	①
0	02	81	Phase N current demand	A	Inst.	○	-	-	○	-	-	-	-	①
0	02	02	Average current demand	A	max.	○	○	-	○	○	○	-	-	①
0	02	22	Phase 1 current demand	A	max.	○	○	○	○	○	○	○	○	①
0	02	42	Phase 2 current demand	A	max.	○	○	-	○	○	○	-	-	①
0	02	62	Phase 3 current demand	A	max.	○	○	-	○	○	○	-	-	①
0	02	82	Phase N current demand	A	max.	○	-	-	○	-	-	-	-	①
0	02	05	Average current demand	A	min.	○	○	-	○	○	○	-	-	①
0	02	25	Phase 1 current demand	A	min.	○	○	○	○	○	○	○	○	①
0	02	45	Phase 2 current demand	A	min.	○	○	-	○	○	○	-	-	①
0	02	65	Phase 3 current demand	A	min.	○	○	-	○	○	○	-	-	①
0	02	85	Phase N current demand	A	min.	○	-	-	○	-	-	-	-	①
0	05	01	Average L-L voltage	V	Inst.	○	○	-	○	○	○	-	-	①
0	05	21	1-2 voltage	V	Inst.	○	○	○	○	○	○	○	○	①
0	05	41	2-3 voltage	V	Inst.	○	○	-	○	○	○	-	-	①
0	05	61	3-1 voltage	V	Inst.	○	○	-	○	○	○	-	-	①
0	05	02	Average L-L voltage	V	max.	○	○	-	○	○	○	-	-	①
0	05	22	1-2 voltage	V	max.	○	○	○	○	○	○	○	○	①
0	05	42	2-3 voltage	V	max.	○	○	-	○	○	○	-	-	①
0	05	62	3-1 voltage	V	max.	○	○	-	○	○	○	-	-	①
0	05	05	Average L-L voltage	V	min.	○	○	-	○	○	○	-	-	①
0	05	25	1-2 voltage	V	min.	○	○	○	○	○	○	○	○	①
0	05	45	2-3 voltage	V	min.	○	○	-	○	○	○	-	-	①
0	05	65	3-1 voltage	V	min.	○	○	-	○	○	○	-	-	①

Note: Measurement data correspond as follows according to setting of phase wiring. (Maximum / Minimum data and harmonic data are same.)

Name of channel	Phase wiring			
	3P3W	1P3W(1N3)	1P3W(1N2)	1P2W
1-2 voltage	1-2 voltage	1-N voltage	1-N voltage	Voltage
2-3 voltage	2-3 voltage	3-N voltage	2-N voltage	-
3-1 voltage	3-1 voltage	1-3 voltage	1-2 voltage	-
Phase 1 current	Phase 1 current	Phase 1 current	Phase 1 current	Current
Phase 2 current	Phase 2 current	Phase N current	Phase N current	-
Phase 3 current	Phase 3 current	Phase 3 current	Phase 2 current	-

Table 7.3 Group Channel List (2/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note		
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W			
0	03	01	Average L-N voltage	V	Inst.		○	-	-	○	-	-	①		
0	03	21	1-N voltage	V	Inst.		○	-	-	○	-	-	①		
0	03	41	2-N voltage	V	Inst.		○	-	-	○	-	-	①		
0	03	61	3-N voltage	V	Inst.		○	-	-	○	-	-	①		
0	03	02	Average L-N voltage	V	max.		○	-	-	○	-	-	①		
0	03	22	1-N voltage	V	max.		○	-	-	○	-	-	①		
0	03	42	2-N voltage	V	max.		○	-	-	○	-	-	①		
0	03	62	3-N voltage	V	max.		○	-	-	○	-	-	①		
0	03	05	Average L-N voltage	V	min.		○	-	-	○	-	-	①		
0	03	25	1-N voltage	V	min.		○	-	-	○	-	-	①		
0	03	45	2-N voltage	V	min.		○	-	-	○	-	-	①		
0	03	65	3-N voltage	V	min.		○	-	-	○	-	-	①		
0	07	01	Total active power	kW	Inst.		○	○	○	○	○	○	①		
0	07	21	Phase 1 active power	kW	Inst.		○	-	-	○	-	-	①		
0	07	41	Phase 2 active power	kW	Inst.		○	-	-	○	-	-	①		
0	07	61	Phase 3 active power	kW	Inst.		○	-	-	○	-	-	①		
0	07	02	Total active power	kW	max.		○	-	-	○	-	-	①		
0	07	22	Phase 1 active power	kW	max.		○	○	○	○	○	○	①		
0	07	42	Phase 2 active power	kW	max.		○	-	-	○	-	-	①		
0	07	62	Phase 3 active power	kW	max.		○	-	-	○	-	-	①		
0	07	05	Total active power	kW	min.		○	○	○	○	○	○	①		
0	07	25	Phase 1 active power	kW	min.		○	-	-	○	-	-	①		
0	07	45	Phase 2 active power	kW	min.		○	-	-	○	-	-	①		
0	07	65	Phase 3 active power	kW	min.		○	-	-	○	-	-	①		
0	08	01	Total rolling demand(kW)	kW	Last		○	○	○	○(*4)	○(*4)	○(*4)	①	*7	
0	08	02	Total rolling demand(kW)	kW	max.		○	○	○	○(*4)	○(*4)	○(*4)	①		
2	08	20	Total rolling demand(kW)	kW	Present		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		
2	08	21	Total rolling demand(kW)	kW	Predict		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		
0	09	01	Total reactive power	kvar	Inst.		○	○	○	○	○	○	①		
0	09	21	Phase 1 reactive power	kvar	Inst.		○	-	-	○	-	-	①		
0	09	41	Phase 2 reactive power	kvar	Inst.		○	-	-	○	-	-	①		
0	09	61	Phase 3 reactive power	kvar	Inst.		○	-	-	○	-	-	①		
0	09	02	Total reactive power	kvar	max.		○	○	○	○	○	○	①		
0	09	22	Phase 1 reactive power	kvar	max.		○	-	-	○	-	-	①		
0	09	42	Phase 2 reactive power	kvar	max.		○	-	-	○	-	-	①		
0	09	62	Phase 3 reactive power	kvar	max.		○	-	-	○	-	-	①		
0	09	05	Total reactive power	kvar	min.		○	○	○	○	○	○	①		
0	09	25	Phase 1 reactive power	kvar	min.		○	-	-	○	-	-	①		
0	09	45	Phase 2 reactive power	kvar	min.		○	-	-	○	-	-	①		
0	09	65	Phase 3 reactive power	kvar	min.		○	-	-	○	-	-	①		
0	0A	01	Total rolling demand(kvar)	kvar	Last		○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①	*7	
0	0A	02	Total rolling demand(kvar)	kvar	max.		○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①		
2	0A	20	Total rolling demand(kvar)	kvar	Present		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		
2	0A	21	Total rolling demand(kvar)	kvar	Predict		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		
1	0B	01	Total apparent power	kVA	Inst.		○	○(*4)	○(*4)	○	○	○(*4)	○(*4)	①	
1	0B	21	Phase 1 apparent power	kVA	Inst.		○	-	-	○	-	-	①		
1	0B	41	Phase 2 apparent power	kVA	Inst.		○	-	-	○	-	-	①		
1	0B	61	Phase 3 apparent power	kVA	Inst.		○	-	-	○	-	-	①		
1	0B	02	Total apparent power	kVA	max.		○	○(*4)	○(*4)	○	○	○(*4)	○(*4)	①	
1	0B	22	Phase 1 apparent power	kVA	max.		○	-	-	○	-	-	①		
1	0B	42	Phase 2 apparent power	kVA	max.		○	-	-	○	-	-	①		
1	0B	62	Phase 3 apparent power	kVA	max.		○	-	-	○	-	-	①		
1	0B	05	Total apparent power	kVA	min.		○	○(*4)	○(*4)	○	○	○(*4)	○(*4)	①	
1	0B	25	Phase 1 apparent power	kVA	min.		○	-	-	○	-	-	①		
1	0B	45	Phase 2 apparent power	kVA	min.		○	-	-	○	-	-	①		
1	0B	65	Phase 3 apparent power	kVA	min.		○	-	-	○	-	-	①		
0	0C	01	Total rolling demand(kVA)	kVA	Last		○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①	*7	
0	0C	02	Total rolling demand(kVA)	kVA	max.		○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①		
2	0C	20	Total rolling demand(kVA)	kVA	Present		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		
2	0C	21	Total rolling demand(kVA)	kVA	Predict		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①		

Table 7.4 Group Channel List (3/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note	
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W		
0	0D	01	Total power factor	%	Inst.		○	○	○	○	○	○	○	①
0	0D	21	Phase 1 power factor	%	Inst.		○	-	-	○	-	-	-	①
0	0D	41	Phase 2 power factor	%	Inst.		○	-	-	○	-	-	-	①
0	0D	61	Phase 3 power factor	%	Inst.		○	-	-	○	-	-	-	①
0	0D	02	Total power factor	%	max.		○	○	○	○	○	○	○	①
0	0D	22	Phase 1 power factor	%	max.		○	-	-	○	-	-	-	①
0	0D	42	Phase 2 power factor	%	max.		○	-	-	○	-	-	-	①
0	0D	62	Phase 3 power factor	%	max.		○	-	-	○	-	-	-	①
0	0D	05	Total power factor	%	min.		○	○	○	○	○	○	○	①
0	0D	25	Phase 1 power factor	%	min.		○	-	-	○	-	-	-	①
0	0D	45	Phase 2 power factor	%	min.		○	-	-	○	-	-	-	①
0	0D	65	Phase 3 power factor	%	min.		○	-	-	○	-	-	-	①
0	0F	01	Frequency	Hz	Inst.		○	○	○	○	○	○	○	①
0	0F	02	Frequency	Hz	max.		○	○	○	○	○	○	○	①
0	0F	05	Frequency	Hz	min.		○	○	○	○	○	○	○	①
0	63	21	1-2 harmonic voltage	V	Inst.	Total	-	○	○	-	○	○	○	①
0	4D	21	1-2 harmonic voltage	V	Inst.	1st	-	○	○	-	○	○	○	①
0	4F	21	1-2 harmonic voltage	V	Inst.	3rd	-	○	○	-	○	○	○	①
0	51	21	1-2 harmonic voltage	V	Inst.	5th	-	○	○	-	○	○	○	①
0	53	21	1-2 harmonic voltage	V	Inst.	7th	-	○	○	-	○	○	○	①
0	55	21	1-2 harmonic voltage	V	Inst.	9th	-	○	○	-	○	○	○	①
0	57	21	1-2 harmonic voltage	V	Inst.	11th	-	○	○	-	○	○	○	①
0	59	21	1-2 harmonic voltage	V	Inst.	13th	-	○	○	-	○	○	○	①
1	5B	21	1-2 harmonic voltage	V	Inst.	15th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	5D	21	1-2 harmonic voltage	V	Inst.	17th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	5F	21	1-2 harmonic voltage	V	Inst.	19th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	61	21	1-2 harmonic voltage	V	Inst.	21st	-	○	○	-	-	-	-	①
1	79	02	1-2 harmonic voltage	V	Inst.	23rd	-	○	○	-	-	-	-	①
1	79	04	1-2 harmonic voltage	V	Inst.	25th	-	○	○	-	-	-	-	①
1	79	06	1-2 harmonic voltage	V	Inst.	27th	-	○	○	-	-	-	-	①
1	79	08	1-2 harmonic voltage	V	Inst.	29th	-	○	○	-	-	-	-	①
1	79	0A	1-2 harmonic voltage	V	Inst.	31st	-	○	○	-	-	-	-	①
0	76	86	1-2 voltage THD	%	Inst.	Total	-	○	○	-	○	○	○	①
0	76	73	1-2 voltage harmonic distortion	%	Inst.	3rd	-	○	○	-	○	○	○	①
0	76	75	1-2 voltage harmonic distortion	%	Inst.	5th	-	○	○	-	○	○	○	①
0	76	77	1-2 voltage harmonic distortion	%	Inst.	7th	-	○	○	-	○	○	○	①
0	76	79	1-2 voltage harmonic distortion	%	Inst.	9th	-	○	○	-	○	○	○	①
0	76	7B	1-2 voltage harmonic distortion	%	Inst.	11th	-	○	○	-	○	○	○	①
0	76	7D	1-2 voltage harmonic distortion	%	Inst.	13th	-	○	○	-	○	○	○	①
1	76	7F	1-2 voltage harmonic distortion	%	Inst.	15th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	76	81	1-2 voltage harmonic distortion	%	Inst.	17th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	76	83	1-2 voltage harmonic distortion	%	Inst.	19th	-	○	○	-	○(*4)	○(*4)	○(*4)	①
1	76	85	1-2 voltage harmonic distortion	%	Inst.	21st	-	○	○	-	-	-	-	①
1	79	72	1-2 voltage harmonic distortion	%	Inst.	23rd	-	○	○	-	-	-	-	①
1	79	74	1-2 voltage harmonic distortion	%	Inst.	25th	-	○	○	-	-	-	-	①
1	79	76	1-2 voltage harmonic distortion	%	Inst.	27th	-	○	○	-	-	-	-	①
1	79	78	1-2 voltage harmonic distortion	%	Inst.	29th	-	○	○	-	-	-	-	①
1	79	7A	1-2 voltage harmonic distortion	%	Inst.	31st	-	○	○	-	-	-	-	①

Table 7.5 Group Channel List (4/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note
						3P4W	3P3W	1P2W	3P4W	3P3W	1P2W		
0	63	41	2-3 harmonic voltage	V	Inst.	Total	-	○	-	-	○	-	①
0	4D	41	2-3 harmonic voltage	V	Inst.	1st	-	○	-	-	○	-	①
0	4F	41	2-3 harmonic voltage	V	Inst.	3rd	-	○	-	-	○	-	①
0	51	41	2-3 harmonic voltage	V	Inst.	5th	-	○	-	-	○	-	①
0	53	41	2-3 harmonic voltage	V	Inst.	7th	-	○	-	-	○	-	①
0	55	41	2-3 harmonic voltage	V	Inst.	9th	-	○	-	-	○	-	①
0	57	41	2-3 harmonic voltage	V	Inst.	11th	-	○	-	-	○	-	①
0	59	41	2-3 harmonic voltage	V	Inst.	13th	-	○	-	-	○	-	①
1	5B	41	2-3 harmonic voltage	V	Inst.	15th	-	○	-	-	○(*4)	-	①
1	5D	41	2-3 harmonic voltage	V	Inst.	17th	-	○	-	-	○(*4)	-	①
1	5F	41	2-3 harmonic voltage	V	Inst.	19th	-	○	-	-	○(*4)	-	①
1	61	41	2-3 harmonic voltage	V	Inst.	21st	-	○	-	-	-	-	①
1	79	18	2-3 harmonic voltage	V	Inst.	23rd	-	○	-	-	-	-	①
1	79	1A	2-3 harmonic voltage	V	Inst.	25th	-	○	-	-	-	-	①
1	79	1C	2-3 harmonic voltage	V	Inst.	27th	-	○	-	-	-	-	①
1	79	1E	2-3 harmonic voltage	V	Inst.	29th	-	○	-	-	-	-	①
1	79	20	2-3 harmonic voltage	V	Inst.	31st	-	○	-	-	-	-	①
0	76	9C	2-3 voltage THD	%	Inst.	Total	-	○	-	-	○	-	①
0	76	89	2-3 voltage harmonic distortion	%	Inst.	3rd	-	○	-	-	○	-	①
0	76	8B	2-3 voltage harmonic distortion	%	Inst.	5th	-	○	-	-	○	-	①
0	76	8D	2-3 voltage harmonic distortion	%	Inst.	7th	-	○	-	-	○	-	①
0	76	8F	2-3 voltage harmonic distortion	%	Inst.	9th	-	○	-	-	○	-	①
0	76	91	2-3 voltage harmonic distortion	%	Inst.	11th	-	○	-	-	○	-	①
0	76	93	2-3 voltage harmonic distortion	%	Inst.	13th	-	○	-	-	○	-	①
1	76	95	2-3 voltage harmonic distortion	%	Inst.	15th	-	○	-	-	○(*4)	-	①
1	76	97	2-3 voltage harmonic distortion	%	Inst.	17th	-	○	-	-	○(*4)	-	①
1	76	99	2-3 voltage harmonic distortion	%	Inst.	19th	-	○	-	-	○(*4)	-	①
1	76	9B	2-3 voltage harmonic distortion	%	Inst.	21st	-	○	-	-	-	-	①
1	79	88	2-3 voltage harmonic distortion	%	Inst.	23rd	-	○	-	-	-	-	①
1	79	8A	2-3 voltage harmonic distortion	%	Inst.	25th	-	○	-	-	-	-	①
1	79	8C	2-3 voltage harmonic distortion	%	Inst.	27th	-	○	-	-	-	-	①
1	79	8E	2-3 voltage harmonic distortion	%	Inst.	29th	-	○	-	-	-	-	①
1	79	90	2-3 voltage harmonic distortion	%	Inst.	31st	-	○	-	-	-	-	①
0	76	DE	L-L voltage THD	%	max.	Total	-	○	○	-	○	○	①
0	4D	A2	L-L harmonic voltage	V	max.	1st	-	○	○	-	○	○	①
0	76	CB	L-L voltage harmonic distortion	%	max.	3rd	-	○	○	-	○	○	①
0	76	CD	L-L voltage harmonic distortion	%	max.	5th	-	○	○	-	○	○	①
0	76	CF	L-L voltage harmonic distortion	%	max.	7th	-	○	○	-	○	○	①
0	76	D1	L-L voltage harmonic distortion	%	max.	9th	-	○	○	-	○	○	①
0	76	D3	L-L voltage harmonic distortion	%	max.	11th	-	○	○	-	○	○	①
0	76	D5	L-L voltage harmonic distortion	%	max.	13th	-	○	○	-	○	○	①
1	76	D7	L-L voltage harmonic distortion	%	max.	15th	-	○	○	-	○(*4)	○(*4)	①
1	76	D9	L-L voltage harmonic distortion	%	max.	17th	-	○	○	-	○(*4)	○(*4)	①
1	76	DB	L-L voltage harmonic distortion	%	max.	19th	-	○	○	-	○(*4)	○(*4)	①
1	76	DD	L-L voltage harmonic distortion	%	max.	21st	-	○	○	-	-	-	①
1	79	CA	L-L voltage harmonic distortion	%	max.	23rd	-	○	○	-	-	-	①
1	79	CC	L-L voltage harmonic distortion	%	max.	25th	-	○	○	-	-	-	①
1	79	CE	L-L voltage harmonic distortion	%	max.	27th	-	○	○	-	-	-	①
1	79	D0	L-L voltage harmonic distortion	%	max.	29th	-	○	○	-	-	-	①
1	79	D2	L-L voltage harmonic distortion	%	max.	31st	-	○	○	-	-	-	①

Table 7.6 Group Channel List (5/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB ME96SSHA-MB ME96SSHB-MB			ME96SSR-MB ME96SSRA-MB ME96SSRB-MB			Data type	Note
						3P4W	3P3W	1P2W	3P4W	3P3W	1P2W		
0	4B	21	1-N harmonic voltage	V	Inst.	Total	○	-	-	○	-	-	①
0	35	21	1-N harmonic voltage	V	Inst.	1st	○	-	-	○	-	-	①
1	37	21	1-N harmonic voltage	V	Inst.	3rd	○	-	-	○	-	-	①
1	39	21	1-N harmonic voltage	V	Inst.	5th	○	-	-	○	-	-	①
1	3B	21	1-N harmonic voltage	V	Inst.	7th	○	-	-	○	-	-	①
1	3D	21	1-N harmonic voltage	V	Inst.	9th	○	-	-	○	-	-	①
1	3F	21	1-N harmonic voltage	V	Inst.	11th	○	-	-	○	-	-	①
1	41	21	1-N harmonic voltage	V	Inst.	13th	○	-	-	○	-	-	①
1	43	21	1-N harmonic voltage	V	Inst.	15th	○	-	-	○(*4)	-	-	①
1	45	21	1-N harmonic voltage	V	Inst.	17th	○	-	-	○(*4)	-	-	①
1	47	21	1-N harmonic voltage	V	Inst.	19th	○	-	-	○(*4)	-	-	①
1	49	21	1-N harmonic voltage	V	Inst.	21st	○	-	-	-	-	-	①
1	7A	02	1-N harmonic voltage	V	Inst.	23rd	○	-	-	-	-	-	①
1	7A	04	1-N harmonic voltage	V	Inst.	25th	○	-	-	-	-	-	①
1	7A	06	1-N harmonic voltage	V	Inst.	27th	○	-	-	-	-	-	①
1	7A	08	1-N harmonic voltage	V	Inst.	29th	○	-	-	-	-	-	①
1	7A	0A	1-N harmonic voltage	V	Inst.	31st	○	-	-	-	-	-	①
0	77	86	1-N voltage THD	%	Inst.	Total	○	-	-	○	-	-	①
0	77	73	1-N voltage harmonic distortion	%	Inst.	3rd	○	-	-	○	-	-	①
0	77	75	1-N voltage harmonic distortion	%	Inst.	5th	○	-	-	○	-	-	①
0	77	77	1-N voltage harmonic distortion	%	Inst.	7th	○	-	-	○	-	-	①
0	77	79	1-N voltage harmonic distortion	%	Inst.	9th	○	-	-	○	-	-	①
0	77	7B	1-N voltage harmonic distortion	%	Inst.	11th	○	-	-	○	-	-	①
0	77	7D	1-N voltage harmonic distortion	%	Inst.	13th	○	-	-	○	-	-	①
1	77	7F	1-N voltage harmonic distortion	%	Inst.	15th	○	-	-	○(*4)	-	-	①
1	77	81	1-N voltage harmonic distortion	%	Inst.	17th	○	-	-	○(*4)	-	-	①
1	77	83	1-N voltage harmonic distortion	%	Inst.	19th	○	-	-	○(*4)	-	-	①
1	77	85	1-N voltage harmonic distortion	%	Inst.	21st	○	-	-	-	-	-	①
1	7A	72	1-N voltage harmonic distortion	%	Inst.	23rd	○	-	-	-	-	-	①
1	7A	74	1-N voltage harmonic distortion	%	Inst.	25th	○	-	-	-	-	-	①
1	7A	76	1-N voltage harmonic distortion	%	Inst.	27th	○	-	-	-	-	-	①
1	7A	78	1-N voltage harmonic distortion	%	Inst.	29th	○	-	-	-	-	-	①
1	7A	7A	1-N voltage harmonic distortion	%	Inst.	31st	○	-	-	-	-	-	①
0	4B	41	2-N harmonic voltage	V	Inst.	Total	○	-	-	○	-	-	①
0	35	41	2-N harmonic voltage	V	Inst.	1st	○	-	-	○	-	-	①
1	37	41	2-N harmonic voltage	V	Inst.	3rd	○	-	-	○	-	-	①
1	39	41	2-N harmonic voltage	V	Inst.	5th	○	-	-	○	-	-	①
1	3B	41	2-N harmonic voltage	V	Inst.	7th	○	-	-	○	-	-	①
1	3D	41	2-N harmonic voltage	V	Inst.	9th	○	-	-	○	-	-	①
1	3F	41	2-N harmonic voltage	V	Inst.	11th	○	-	-	○	-	-	①
1	41	41	2-N harmonic voltage	V	Inst.	13th	○	-	-	○	-	-	①
1	43	41	2-N harmonic voltage	V	Inst.	15th	○	-	-	○(*4)	-	-	①
1	45	41	2-N harmonic voltage	V	Inst.	17th	○	-	-	○(*4)	-	-	①
1	47	41	2-N harmonic voltage	V	Inst.	19th	○	-	-	○(*4)	-	-	①
1	49	41	2-N harmonic voltage	V	Inst.	21st	○	-	-	-	-	-	①
1	7A	18	2-N harmonic voltage	V	Inst.	23rd	○	-	-	-	-	-	①
1	7A	1A	2-N harmonic voltage	V	Inst.	25th	○	-	-	-	-	-	①
1	7A	1C	2-N harmonic voltage	V	Inst.	27th	○	-	-	-	-	-	①
1	7A	1E	2-N harmonic voltage	V	Inst.	29th	○	-	-	-	-	-	①
1	7A	20	2-N harmonic voltage	V	Inst.	31st	○	-	-	-	-	-	①

Table 7.7 Group Channel List (6/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note	
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W	1P2W	
0	77	9C	2-N voltage THD	%	Inst.	Total	○	-	-	○	-	-	-	①
0	77	89	2-N voltage harmonic distortion	%	Inst.	3rd	○	-	-	○	-	-	-	①
0	77	8B	2-N voltage harmonic distortion	%	Inst.	5th	○	-	-	○	-	-	-	①
0	77	8D	2-N voltage harmonic distortion	%	Inst.	7th	○	-	-	○	-	-	-	①
0	77	8F	2-N voltage harmonic distortion	%	Inst.	9th	○	-	-	○	-	-	-	①
0	77	91	2-N voltage harmonic distortion	%	Inst.	11th	○	-	-	○	-	-	-	①
0	77	93	2-N voltage harmonic distortion	%	Inst.	13th	○	-	-	○	-	-	-	①
1	77	95	2-N voltage harmonic distortion	%	Inst.	15th	○	-	-	○(*4)	-	-	-	①
1	77	97	2-N voltage harmonic distortion	%	Inst.	17th	○	-	-	○(*4)	-	-	-	①
1	77	99	2-N voltage harmonic distortion	%	Inst.	19th	○	-	-	○(*4)	-	-	-	①
1	77	9B	2-N voltage harmonic distortion	%	Inst.	21st	○	-	-	-	-	-	-	①
1	7A	88	2-N voltage harmonic distortion	%	Inst.	23rd	○	-	-	-	-	-	-	①
1	7A	8A	2-N voltage harmonic distortion	%	Inst.	25th	○	-	-	-	-	-	-	①
1	7A	8C	2-N voltage harmonic distortion	%	Inst.	27th	○	-	-	-	-	-	-	①
1	7A	8E	2-N voltage harmonic distortion	%	Inst.	29th	○	-	-	-	-	-	-	①
1	7A	90	2-N voltage harmonic distortion	%	Inst.	31st	○	-	-	-	-	-	-	①
0	4B	61	3-N harmonic voltage	V	Inst.	Total	○	-	-	○	-	-	-	①
0	35	61	3-N harmonic voltage	V	Inst.	1st	○	-	-	○	-	-	-	①
1	37	61	3-N harmonic voltage	V	Inst.	3rd	○	-	-	○	-	-	-	①
1	39	61	3-N harmonic voltage	V	Inst.	5th	○	-	-	○	-	-	-	①
1	3B	61	3-N harmonic voltage	V	Inst.	7th	○	-	-	○	-	-	-	①
1	3D	61	3-N harmonic voltage	V	Inst.	9th	○	-	-	○	-	-	-	①
1	3F	61	3-N harmonic voltage	V	Inst.	11th	○	-	-	○	-	-	-	①
1	41	61	3-N harmonic voltage	V	Inst.	13th	○	-	-	○	-	-	-	①
1	43	61	3-N harmonic voltage	V	Inst.	15th	○	-	-	○(*4)	-	-	-	①
1	45	61	3-N harmonic voltage	V	Inst.	17th	○	-	-	○(*4)	-	-	-	①
1	47	61	3-N harmonic voltage	V	Inst.	19th	○	-	-	○(*4)	-	-	-	①
1	49	61	3-N harmonic voltage	V	Inst.	21st	○	-	-	-	-	-	-	①
1	7A	2E	3-N harmonic voltage	V	Inst.	23rd	○	-	-	-	-	-	-	①
1	7A	30	3-N harmonic voltage	V	Inst.	25th	○	-	-	-	-	-	-	①
1	7A	32	3-N harmonic voltage	V	Inst.	27th	○	-	-	-	-	-	-	①
1	7A	34	3-N harmonic voltage	V	Inst.	29th	○	-	-	-	-	-	-	①
1	7A	36	3-N harmonic voltage	V	Inst.	31st	○	-	-	-	-	-	-	①
0	77	B2	3-N voltage THD	%	Inst.	Total	○	-	-	○	-	-	-	①
0	77	9F	3-N voltage harmonic distortion	%	Inst.	3rd	○	-	-	○	-	-	-	①
0	77	A1	3-N voltage harmonic distortion	%	Inst.	5th	○	-	-	○	-	-	-	①
0	77	A3	3-N voltage harmonic distortion	%	Inst.	7th	○	-	-	○	-	-	-	①
0	77	A5	3-N voltage harmonic distortion	%	Inst.	9th	○	-	-	○	-	-	-	①
0	77	A7	3-N voltage harmonic distortion	%	Inst.	11th	○	-	-	○	-	-	-	①
0	77	A9	3-N voltage harmonic distortion	%	Inst.	13th	○	-	-	○	-	-	-	①
1	77	AB	3-N voltage harmonic distortion	%	Inst.	15th	○	-	-	○(*4)	-	-	-	①
1	77	AD	3-N voltage harmonic distortion	%	Inst.	17th	○	-	-	○(*4)	-	-	-	①
1	77	AF	3-N voltage harmonic distortion	%	Inst.	19th	○	-	-	○(*4)	-	-	-	①
1	77	B1	3-N voltage harmonic distortion	%	Inst.	21st	○	-	-	-	-	-	-	①
1	7A	9E	3-N voltage harmonic distortion	%	Inst.	23rd	○	-	-	-	-	-	-	①
1	7A	A0	3-N voltage harmonic distortion	%	Inst.	25th	○	-	-	-	-	-	-	①
1	7A	A2	3-N voltage harmonic distortion	%	Inst.	27th	○	-	-	-	-	-	-	①
1	7A	A4	3-N voltage harmonic distortion	%	Inst.	29th	○	-	-	-	-	-	-	①
1	7A	A6	3-N voltage harmonic distortion	%	Inst.	31st	○	-	-	-	-	-	-	①

Table 7.8 Group Channel List (7/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note	
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W	1P2W	
0	77	DE	L-N voltage THD	%	max.	Total	○	-	-	○	-	-	-	①
0	35	A2	L-N harmonic voltage	V	max.	1st	○	-	-	○	-	-	-	①
0	77	CB	L-N voltage harmonic distortion	%	max.	3rd	○	-	-	○	-	-	-	①
0	77	CD	L-N voltage harmonic distortion	%	max.	5th	○	-	-	○	-	-	-	①
0	77	CF	L-N voltage harmonic distortion	%	max.	7th	○	-	-	○	-	-	-	①
0	77	D1	L-N voltage harmonic distortion	%	max.	9th	○	-	-	○	-	-	-	①
0	77	D3	L-N voltage harmonic distortion	%	max.	11th	○	-	-	○	-	-	-	①
0	77	D5	L-N voltage harmonic distortion	%	max.	13th	○	-	-	○	-	-	-	①
1	77	D7	L-N voltage harmonic distortion	%	max.	15th	○	-	-	○(*4)	-	-	-	①
1	77	D9	L-N voltage harmonic distortion	%	max.	17th	○	-	-	○(*4)	-	-	-	①
1	77	DB	L-N voltage harmonic distortion	%	max.	19th	○	-	-	○(*4)	-	-	-	①
1	77	DD	L-N voltage harmonic distortion	%	max.	21st	○	-	-	-	-	-	-	①
1	7A	CA	L-N voltage harmonic distortion	%	max.	23rd	○	-	-	-	-	-	-	①
1	7A	CC	L-N voltage harmonic distortion	%	max.	25th	○	-	-	-	-	-	-	①
1	7A	CE	L-N voltage harmonic distortion	%	max.	27th	○	-	-	-	-	-	-	①
1	7A	D0	L-N voltage harmonic distortion	%	max.	29th	○	-	-	-	-	-	-	①
1	7A	D2	L-N voltage harmonic distortion	%	max.	31st	○	-	-	-	-	-	-	①
0	33	21	Phase 1 harmonic current	A	Inst.	Total	○	○	○	○	○	○	○	①
0	1D	21	Phase 1 harmonic current	A	Inst.	1st	○	○	○	○	○	○	○	①
0	1F	21	Phase 1 harmonic current	A	Inst.	3rd	○	○	○	○	○	○	○	①
0	21	21	Phase 1 harmonic current	A	Inst.	5th	○	○	○	○	○	○	○	①
0	23	21	Phase 1 harmonic current	A	Inst.	7th	○	○	○	○	○	○	○	①
0	25	21	Phase 1 harmonic current	A	Inst.	9th	○	○	○	○	○	○	○	①
0	27	21	Phase 1 harmonic current	A	Inst.	11th	○	○	○	○	○	○	○	①
0	29	21	Phase 1 harmonic current	A	Inst.	13th	○	○	○	○	○	○	○	①
1	2B	21	Phase 1 harmonic current	A	Inst.	15th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	2D	21	Phase 1 harmonic current	A	Inst.	17th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	2F	21	Phase 1 harmonic current	A	Inst.	19th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	31	21	Phase 1 harmonic current	A	Inst.	21st	○	○	○	-	-	-	-	①
1	78	02	Phase 1 harmonic current	A	Inst.	23rd	○	○	○	-	-	-	-	①
1	78	04	Phase 1 harmonic current	A	Inst.	25th	○	○	○	-	-	-	-	①
1	78	06	Phase 1 harmonic current	A	Inst.	27th	○	○	○	-	-	-	-	①
1	78	08	Phase 1 harmonic current	A	Inst.	29th	○	○	○	-	-	-	-	①
1	78	0A	Phase 1 harmonic current	A	Inst.	31st	○	○	○	-	-	-	-	①
0	75	86	Phase 1 current THD	%	Inst.	Total	○	○	○	○	○	○	○	①
1/0	75	73	Phase 1 current harmonic distortion	%	Inst.	3rd	○	○	○	○	○	○	○	① *2
1/0	75	75	Phase 1 current harmonic distortion	%	Inst.	5th	○	○	○	○	○	○	○	① *2
1/0	75	77	Phase 1 current harmonic distortion	%	Inst.	7th	○	○	○	○	○	○	○	① *2
1/0	75	79	Phase 1 current harmonic distortion	%	Inst.	9th	○	○	○	○	○	○	○	① *2
1/0	75	7B	Phase 1 current harmonic distortion	%	Inst.	11th	○	○	○	○	○	○	○	① *2
1/0	75	7D	Phase 1 current harmonic distortion	%	Inst.	13th	○	○	○	○	○	○	○	① *2
1	75	7F	Phase 1 current harmonic distortion	%	Inst.	15th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	75	81	Phase 1 current harmonic distortion	%	Inst.	17th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	75	83	Phase 1 current harmonic distortion	%	Inst.	19th	○	○	○	○	○(*4)	○(*4)	○(*4)	①
1	75	85	Phase 1 current harmonic distortion	%	Inst.	21st	○	○	○	-	-	-	-	①
1	78	72	Phase 1 current harmonic distortion	%	Inst.	23rd	○	○	○	-	-	-	-	①
1	78	74	Phase 1 current harmonic distortion	%	Inst.	25th	○	○	○	-	-	-	-	①
1	78	76	Phase 1 current harmonic distortion	%	Inst.	27th	○	○	○	-	-	-	-	①
1	78	78	Phase 1 current harmonic distortion	%	Inst.	29th	○	○	○	-	-	-	-	①
1	78	7A	Phase 1 current harmonic distortion	%	Inst.	31st	○	○	○	-	-	-	-	①

Table 7.9 Group Channel List (8/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note	
						3P4W	3P3W	1P2W	3P4W	3P3W	1P2W			
0	33	41	Phase 2 harmonic current	A	Inst.	Total	○	△	-	○	△	-	①	*1
0	1D	41	Phase 2 harmonic current	A	Inst.	1st	○	△	-	○	△	-	①	*1
0	1F	41	Phase 2 harmonic current	A	Inst.	3rd	○	△	-	○	△	-	①	*1
0	21	41	Phase 2 harmonic current	A	Inst.	5th	○	△	-	○	△	-	①	*1
0	23	41	Phase 2 harmonic current	A	Inst.	7th	○	△	-	○	△	-	①	*1
0	25	41	Phase 2 harmonic current	A	Inst.	9th	○	△	-	○	△	-	①	*1
0	27	41	Phase 2 harmonic current	A	Inst.	11th	○	△	-	○	△	-	①	*1
0	29	41	Phase 2 harmonic current	A	Inst.	13th	○	△	-	○	△	-	①	*1
1	2B	41	Phase 2 harmonic current	A	Inst.	15th	○	△	-	○(*4)	△(*4)	-	①	*1
1	2D	41	Phase 2 harmonic current	A	Inst.	17th	○	△	-	○(*4)	△(*4)	-	①	*1
1	2F	41	Phase 2 harmonic current	A	Inst.	19th	○	△	-	○(*4)	△(*4)	-	①	*1
1	31	41	Phase 2 harmonic current	A	Inst.	21st	○	△	-	-	-	-	①	*1
1	78	18	Phase 2 harmonic current	A	Inst.	23rd	○	△	-	-	-	-	①	*1
1	78	1A	Phase 2 harmonic current	A	Inst.	25th	○	△	-	-	-	-	①	*1
1	78	1C	Phase 2 harmonic current	A	Inst.	27th	○	△	-	-	-	-	①	*1
1	78	1E	Phase 2 harmonic current	A	Inst.	29th	○	△	-	-	-	-	①	*1
1	78	20	Phase 2 harmonic current	A	Inst.	31st	○	△	-	-	-	-	①	*1
0	75	9C	Phase 2 current THD	%	Inst.	Total	○	△	-	○	△	-	①	*1
1/0	75	89	Phase 2 current harmonic distortion	%	Inst.	3rd	○	△	-	○	△	-	①	*1,*2
1/0	75	8B	Phase 2 current harmonic distortion	%	Inst.	5th	○	△	-	○	△	-	①	*1,*2
1/0	75	8D	Phase 2 current harmonic distortion	%	Inst.	7th	○	△	-	○	△	-	①	*1,*2
1/0	75	8F	Phase 2 current harmonic distortion	%	Inst.	9th	○	△	-	○	△	-	①	*1,*2
1/0	75	91	Phase 2 current harmonic distortion	%	Inst.	11th	○	△	-	○	△	-	①	*1,*2
1/0	75	93	Phase 2 current harmonic distortion	%	Inst.	13th	○	△	-	○	△	-	①	*1,*2
1	75	95	Phase 2 current harmonic distortion	%	Inst.	15th	○	△	-	○(*4)	△(*4)	-	①	*1
1	75	97	Phase 2 current harmonic distortion	%	Inst.	17th	○	△	-	○(*4)	△(*4)	-	①	*1
1	75	99	Phase 2 current harmonic distortion	%	Inst.	19th	○	△	-	○(*4)	△(*4)	-	①	*1
1	75	9B	Phase 2 current harmonic distortion	%	Inst.	21st	○	△	-	-	-	-	①	*1
1	78	88	Phase 2 current harmonic distortion	%	Inst.	23rd	○	△	-	-	-	-	①	*1
1	78	8A	Phase 2 current harmonic distortion	%	Inst.	25th	○	△	-	-	-	-	①	*1
1	78	8C	Phase 2 current harmonic distortion	%	Inst.	27th	○	△	-	-	-	-	①	*1
1	78	8E	Phase 2 current harmonic distortion	%	Inst.	29th	○	△	-	-	-	-	①	*1
1	78	90	Phase 2 current harmonic distortion	%	Inst.	31st	○	△	-	-	-	-	①	*1
0	33	61	Phase 3 harmonic current	A	Inst.	Total	○	○	-	○	○	-	①	
0	1D	61	Phase 3 harmonic current	A	Inst.	1st	○	○	-	○	○	-	①	
0	1F	61	Phase 3 harmonic current	A	Inst.	3rd	○	○	-	○	○	-	①	
0	21	61	Phase 3 harmonic current	A	Inst.	5th	○	○	-	○	○	-	①	
0	23	61	Phase 3 harmonic current	A	Inst.	7th	○	○	-	○	○	-	①	
0	25	61	Phase 3 harmonic current	A	Inst.	9th	○	○	-	○	○	-	①	
0	27	61	Phase 3 harmonic current	A	Inst.	11th	○	○	-	○	○	-	①	
0	29	61	Phase 3 harmonic current	A	Inst.	13th	○	○	-	○	○	-	①	
1	2B	61	Phase 3 harmonic current	A	Inst.	15th	○	○	-	○(*4)	○(*4)	-	①	
1	2D	61	Phase 3 harmonic current	A	Inst.	17th	○	○	-	○(*4)	○(*4)	-	①	
1	2F	61	Phase 3 harmonic current	A	Inst.	19th	○	○	-	○(*4)	○(*4)	-	①	
1	31	61	Phase 3 harmonic current	A	Inst.	21st	○	○	-	-	-	-	①	
1	78	2E	Phase 3 harmonic current	A	Inst.	23rd	○	○	-	-	-	-	①	
1	78	30	Phase 3 harmonic current	A	Inst.	25th	○	○	-	-	-	-	①	
1	78	32	Phase 3 harmonic current	A	Inst.	27th	○	○	-	-	-	-	①	
1	78	34	Phase 3 harmonic current	A	Inst.	29th	○	○	-	-	-	-	①	
1	78	36	Phase 3 harmonic current	A	Inst.	31st	○	○	-	-	-	-	①	

Table 7.10 Group Channel List (9/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB ME96SSHA-MB ME96SSHB-MB			ME96SSR-MB ME96SSRA-MB ME96SSRB-MB			Data type	Note	
						3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W	1P2W	
0	75	B2	Phase 3 current THD	%	Inst.	Total	○	○	-	○	○	-	-	①
1/0	75	9F	Phase 3 current harmonic distortion	%	Inst.	3rd	○	○	-	○	○	-	-	① *2
1/0	75	A1	Phase 3 current harmonic distortion	%	Inst.	5th	○	○	-	○	○	-	-	① *2
1/0	75	A3	Phase 3 current harmonic distortion	%	Inst.	7th	○	○	-	○	○	-	-	① *2
1/0	75	A5	Phase 3 current harmonic distortion	%	Inst.	9th	○	○	-	○	○	-	-	① *2
1/0	75	A7	Phase 3 current harmonic distortion	%	Inst.	11th	○	○	-	○	○	-	-	① *2
1/0	75	A9	Phase 3 current harmonic distortion	%	Inst.	13th	○	○	-	○	○	-	-	① *2
1	75	AB	Phase 3 current harmonic distortion	%	Inst.	15th	○	○	-	○(*4)	○(*4)	-	-	①
1	75	AD	Phase 3 current harmonic distortion	%	Inst.	17th	○	○	-	○(*4)	○(*4)	-	-	①
1	75	AF	Phase 3 current harmonic distortion	%	Inst.	19th	○	○	-	○(*4)	○(*4)	-	-	①
1	75	B1	Phase 3 current harmonic distortion	%	Inst.	21st	○	○	-	-	-	-	-	①
1	78	9E	Phase 3 current harmonic distortion	%	Inst.	23rd	○	○	-	-	-	-	-	①
1	78	A0	Phase 3 current harmonic distortion	%	Inst.	25th	○	○	-	-	-	-	-	①
1	78	A2	Phase 3 current harmonic distortion	%	Inst.	27th	○	○	-	-	-	-	-	①
1	78	A4	Phase 3 current harmonic distortion	%	Inst.	29th	○	○	-	-	-	-	-	①
1	78	A6	Phase 3 current harmonic distortion	%	Inst.	31st	○	○	-	-	-	-	-	①
0	33	81	Phase N harmonic current	A	Inst.	Total	○	-	-	○	-	-	-	①
0	1D	81	Phase N harmonic current	A	Inst.	1st	○	-	-	○	-	-	-	①
0	1F	81	Phase N harmonic current	A	Inst.	3rd	○	-	-	○	-	-	-	①
0	21	81	Phase N harmonic current	A	Inst.	5th	○	-	-	○	-	-	-	①
0	23	81	Phase N harmonic current	A	Inst.	7th	○	-	-	○	-	-	-	①
0	25	81	Phase N harmonic current	A	Inst.	9th	○	-	-	○	-	-	-	①
0	27	81	Phase N harmonic current	A	Inst.	11th	○	-	-	○	-	-	-	①
0	29	81	Phase N harmonic current	A	Inst.	13th	○	-	-	○	-	-	-	①
1	2B	81	Phase N harmonic current	A	Inst.	15th	○	-	-	○(*4)	-	-	-	①
1	2D	81	Phase N harmonic current	A	Inst.	17th	○	-	-	○(*4)	-	-	-	①
1	2F	81	Phase N harmonic current	A	Inst.	19th	○	-	-	○(*4)	-	-	-	①
1	31	81	Phase N harmonic current	A	Inst.	21st	○	-	-	-	-	-	-	①
1	78	44	Phase N harmonic current	A	Inst.	23rd	○	-	-	-	-	-	-	①
1	78	46	Phase N harmonic current	A	Inst.	25th	○	-	-	-	-	-	-	①
1	78	48	Phase N harmonic current	A	Inst.	27th	○	-	-	-	-	-	-	①
1	78	4A	Phase N harmonic current	A	Inst.	29th	○	-	-	-	-	-	-	①
1	78	4C	Phase N harmonic current	A	Inst.	31st	○	-	-	-	-	-	-	①
1	33	82	Phase N current THD	A	max.	Total	○	-	-	○	-	-	-	①
1	1D	82	Phase N current harmonic distortion	A	max.	1st	○	-	-	○	-	-	-	①
1	1F	82	Phase N current harmonic distortion	A	max.	3rd	○	-	-	○	-	-	-	①
1	21	82	Phase N current harmonic distortion	A	max.	5th	○	-	-	○	-	-	-	①
1	23	82	Phase N current harmonic distortion	A	max.	7th	○	-	-	○	-	-	-	①
1	25	82	Phase N current harmonic distortion	A	max.	9th	○	-	-	○	-	-	-	①
1	27	82	Phase N current harmonic distortion	A	max.	11th	○	-	-	○	-	-	-	①
1	29	82	Phase N current harmonic distortion	A	max.	13th	○	-	-	○	-	-	-	①
1	2B	82	Phase N current harmonic distortion	A	max.	15th	○	-	-	○(*4)	-	-	-	①
1	2D	82	Phase N current harmonic distortion	A	max.	17th	○	-	-	○(*4)	-	-	-	①
1	2F	82	Phase N current harmonic distortion	A	max.	19th	○	-	-	○(*4)	-	-	-	①
1	31	82	Phase N current harmonic distortion	A	max.	21st	○	-	-	-	-	-	-	①
1	7B	44	Phase N current harmonic distortion	A	max.	23rd	○	-	-	-	-	-	-	①
1	7B	46	Phase N current harmonic distortion	A	max.	25th	○	-	-	-	-	-	-	①
1	7B	48	Phase N current harmonic distortion	A	max.	27th	○	-	-	-	-	-	-	①
1	7B	4A	Phase N current harmonic distortion	A	max.	29th	○	-	-	-	-	-	-	①
1	7B	4C	Phase N current harmonic distortion	A	max.	31st	○	-	-	-	-	-	-	①

Table 7.11 Group Channel List (10/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel			ME96SSH-MB			ME96SSR-MB			Data type	Note
						3P4W	3P3W	1P2W	3P4W	3P3W	1P2W		
0	33	A2	Harmonic current	A	max.	Total	○	○	○	○	○	○	①
0	1D	A2	Harmonic current	A	max.	1st	○	○	○	○	○	○	①
0	1F	A2	Harmonic current	A	max.	3rd	○	○	○	○	○	○	①
0	21	A2	Harmonic current	A	max.	5th	○	○	○	○	○	○	①
0	23	A2	Harmonic current	A	max.	7th	○	○	○	○	○	○	①
0	25	A2	Harmonic current	A	max.	9th	○	○	○	○	○	○	①
0	27	A2	Harmonic current	A	max.	11th	○	○	○	○	○	○	①
0	29	A2	Harmonic current	A	max.	13th	○	○	○	○	○	○	①
1	2B	A2	Harmonic current	A	max.	15th	○	○	○	○(*4)	○(*4)	○(*4)	①
1	2D	A2	Harmonic current	A	max.	17th	○	○	○	○(*4)	○(*4)	○(*4)	①
1	2F	A2	Harmonic current	A	max.	19th	○	○	○	○(*4)	○(*4)	○(*4)	①
1	31	A2	Harmonic current	A	max.	21st	○	○	○	-	-	-	①
1	78	5A	Harmonic current	A	max.	23rd	○	○	○	-	-	-	①
1	78	5C	Harmonic current	A	max.	25th	○	○	○	-	-	-	①
1	78	5E	Harmonic current	A	max.	27th	○	○	○	-	-	-	①
1	78	60	Harmonic current	A	max.	29th	○	○	○	-	-	-	①
1	78	62	Harmonic current	A	max.	31st	○	○	○	-	-	-	①
1	01	1E	Current unbalance	%	Inst.		○(*5)	○(*5)	-	○(*5)	○(*5)	-	①
1	01	24	Current unbalance	%	max.		○(*5)	○(*5)	-	○(*5)	○(*5)	-	①
1	03	1E	Voltage unbalance	%	Inst.		○(*5)	○(*5)	-	○(*5)	○(*5)	-	①
1	03	24	Voltage unbalance	%	max.		○(*5)	○(*5)	-	○(*5)	○(*5)	-	①

Table 7.12 Group Channel List (11/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel				ME96SSH-MB			ME96SSR-MB			Data type	Note	
							3P4W	3P3W	1P3W	1P2W	3P4W	3P3W	1P3W	1P2W	
0	80	01	Active energy import	kWh	count		○	○	○	○	○	○	○	○	② *3
0	80	63	Active energy export	kWh	count		○	○	○	○	○	○	○	○	② *3
0	80	64	Active energy import	kWh	count	expand	○	○	○	○	○	○	○	○	② *3
0	80	65	Active energy export	kWh	count	expand	○	○	○	○	○	○	○	○	② *3
0	81	01	Reactive energy import lag	kvarh	count		○	○	○	○	○	○	○	○	② *3
0	81	63	Reactive energy export lag	kvarh	count		○	○	○	○	○	○	○	○	② *3
0	81	64	Reactive energy import lead	kvarh	count		○	○	○	○	○	○	○	○	② *3
0	81	65	Reactive energy export lead	kvarh	count		○	○	○	○	○	○	○	○	② *3
0	81	66	Reactive energy import lag	kvarh	count	expand	○	○	○	○	○	○	○	○	② *3
0	81	67	Reactive energy export lag	kvarh	count	expand	○	○	○	○	○	○	○	○	② *3
0	81	68	Reactive energy import lead	kvarh	count	expand	○	○	○	○	○	○	○	○	② *3
0	81	69	Reactive energy export lead	kvarh	count	expand	○	○	○	○	○	○	○	○	② *3
0	82	01	Apparent energy	kVAh	count		○	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	② *3
0	8B	01	Periodic active energy(Period 1)	kWh	count		○	○	○	○	○	○	○	○	② *3
0	8C	01	Periodic active energy(Period 2)	kWh	count		○	○	○	○	○	○	○	○	② *3
1	92	01	Periodic active energy(Period 3)	kWh	count		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	② *3
0	87	01	Operating time1	h	count		○	○	○	○	○	○	○	○	②
0	88	01	Operating time2	h	count		○	○	○	○	○	○	○	○	②
0	80	6A	CO2 equivalent	kg	count		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	② *8
1	B0	01	Active energy import	Wh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	04	Active energy export	Wh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	07	Reactive energy import lag	varh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0A	Reactive energy export lag	varh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0D	Reactive energy import lead	varh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	10	Reactive energy export lead	varh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	13	Apparent energy	VAh	count	unit fixed	○	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	③ *3
1	B0	16	Periodic active energy(Period 1)	Wh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	19	Periodic active energy(Period 2)	Wh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	1C	Periodic active energy(Period 3)	Wh	count	unit fixed	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	② *3
1	B0	02	Active energy import	kWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	05	Active energy export	kWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	08	Reactive energy import lag	kvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0B	Reactive energy export lag	kvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0E	Reactive energy import lead	kvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	11	Reactive energy export lead	kvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	14	Apparent energy	kVAh	count	unit fixed	○	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	③ *3
1	B0	17	Periodic active energy(Period 1)	kWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	1A	Periodic active energy(Period 2)	kWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	1D	Periodic active energy(Period 3)	kWh	count	unit fixed	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	② *3
1	B0	03	Active energy import	MWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	06	Active energy export	MWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	09	Reactive energy import lag	Mvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0C	Reactive energy export lag	Mvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	0F	Reactive energy import lead	Mvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	12	Reactive energy export lead	Mvarh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	15	Apparent energy	MVAh	count	unit fixed	○	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	③ *3
1	B0	18	Periodic active energy(Period 1)	MWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	1B	Periodic active energy(Period 2)	MWh	count	unit fixed	○	○	○	○	○	○	○	○	③ *3
1	B0	1E	Periodic active energy(Period 3)	MWh	count	unit fixed	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	② *3

Table 7.13 Group Channel List (12/12)

Unit No.	Group (h)	Channel (h)	Name of Cannel				ME96SSH-MB			ME96SSR-MB			Data type	Note
							3P4W	3P3W	1P2W	3P4W	3P3W	1P2W		
0	01	14	Current upper limit	A	Alarm		○	○	○	○	○	○	○	①
0	01	15	Current lower limit	A	Alarm		○	○	○	○	○	○	○	①
0	01	94	Current upper limit	A	Alarm	PhaseN	○	-	-	○	-	-	○	①
0	02	14	Current demand upper limit	A	Alarm		○	○	○	○	○	○	○	①
0	02	15	Current demand lower limit	A	Alarm		○	○	○	○	○	○	○	①
0	02	94	Current demand upper limit	A	Alarm	PhaseN	○	-	-	○	-	-	○	①
0	05	14	Voltage upper limit(L-L)	V	Alarm		○	○	○	○	○	○	○	①
0	05	15	Voltage lower limit(L-L)	V	Alarm		○	○	○	○	○	○	○	①
0	03	14	Voltage upper limit(L-N)	V	Alarm		○	○	○	○	○	○	○	①
0	03	15	Voltage lower limit(L-N)	V	Alarm		○	○	○	○	○	○	○	①
0	07	14	Active power upper limit	kW	Alarm		○	○	○	○	○	○	○	①
0	07	15	Active power lower limit	kW	Alarm		○	○	○	○	○	○	○	①
0	08	14	Rolling demand(kW) upper limit	kW	Alarm	Last	○	○	○	○(*4)	○(*4)	○(*4)	○	*7
2	08	22	Rolling demand(kW) upper limit	kW	Alarm	Present	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
2	08	23	Rolling demand(kW) upper limit	kW	Alarm	Predict	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
0	09	14	Reactive power upper limit	kvar	Alarm		○	○	○	○	○	○	○	①
0	09	15	Reactive power lower limit	kvar	Alarm		○	○	○	○	○	○	○	①
0	0A	14	Rolling demand(kvar) upper limit	kvar	Alarm	Last	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①
2	0A	22	Rolling demand(kvar) upper limit	kvar	Alarm	Present	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
2	0A	23	Rolling demand(kvar) upper limit	kvar	Alarm	Predict	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
0	0C	14	Rolling demand(kVA) upper limit	kVA	Alarm	Last	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	○(*4)	①
2	0C	22	Rolling demand(kVA) upper limit	kVA	Alarm	Present	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
2	0C	23	Rolling demand(kVA) upper limit	kVA	Alarm	Predict	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
0	0D	14	Power factor upper limit	%	Alarm		○	○	○	○	○	○	○	①
0	0D	15	Power factor lower limit	%	Alarm		○	○	○	○	○	○	○	①
0	0F	14	Frequency upper limit	Hz	Alarm		○	○	○	○	○	○	○	①
0	0F	15	Frequency lower limit	Hz	Alarm		○	○	○	○	○	○	○	①
0	77	E1	H.V(L-N) upper limit	%	Alarm	Total	○	○	○	○	○	○	○	①
0	76	E1	H.V(L-L) upper limit	%	Alarm	Total	○	○	○	○	○	○	○	①
0	75	E1	H.A upper limit	A	Alarm	Total	○	○	○	○	○	○	○	①
0	75	F1	H.A upper limit(Phase N)	A	Alarm	Total	○	-	-	○	-	-	○	①
1	01	25	Current unbalance limit	%			○(*5)	○(*5)	-	○(*5)	○(*5)	-	○	①
1	03	25	Voltage unbalance limit	%			○(*5)	○(*5)	-	○(*5)	○(*5)	-	○	①
0	80	E4	CO2 equivalent rate				○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	①
0	A0	31	Alarm state1		Alarm		○	○	○	○	○	○	○	④
0	A0	35	Alarm state2		Alarm		○	○	○	○	○	○	○	④
0	A0	34	Alarm state3		Alarm		○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	○(*5)	④

Inst.: Instantaneous value,

max.: maximum value,

min.: minimum value.

(Refer to next page for notes.)

*1: △ in the table means that it is applicable when the setting of phase wiring is 3P3W_3CT only.

*2: Unit number is "0" when the setting of phase wiring is 1P2W, 1P3W or 3P3W.

*3: About the reply data of active energy(Wh), reactive energy(varh) and apparent energy(VAh), refer to follows.

Example) In case of active energy(import) data is 876,543,210,987,654,321mWh, each reply data are follows.

				Data=	8	7	6	5	4	3	2	1	0	9	8	7	6	5	4	3	2	1		
Unit No.	Group (h)	Channel (h)	Name of Channel	Total power[kW]																				Note
0	80	01	Active energy import	less than 10										0	9	8	7	6	5				note1	
				10 or more and less than 100									1	0	9	8	7	6						
				100 or more and less than 1000								2	1	0	9	8	7							
				1000 or more and less than 10000							3	2	1	0	9	8								
				10000 or more and less than 100000						4	3	2	1	0	9									
				100000 or more					5	4	3	2	1	0										
0	80	64	Active energy import (expand)	less than 10														7	6	5	4	3	2	note1
				10 or more and less than 100														8	7	6	5	4	3	
				100 or more and less than 1000											9	8	7	6	5	4				
				1000 or more and less than 10000										0	9	8	7	6	5					
				10000 or more and less than 100000									1	0	9	8	7	6						
				100000 or more								2	1	0	9	8	7							
1	B0	01	Active energy import (unit fixed: Wh)	-								2	1	0	9	8	7	6	5	4			note2	
1	B0	02	Active energy import (unit fixed: kWh)	-						5	4	3	2	1	0	9	8	7						
1	B0	03	Active energy import (unit fixed: MWh)	-		8	7	6	5	4	3	2	1	0										

note1: The data of energy will change according to the total load setting of ME96. Multiplying the receiving data by the multiplying factor of section gives the actual value (unit:kWh).

note2: The data of energy of selected unit will reply regardless to the total load setting of ME96. (This matches to the additional display(9 digits) of ME96SSH/ME96SSR/ME96SSHA/ME96SSRA/ME96SSHB/ME96SSRB.

*4: Applicable only when ME96SSHA-MB/ME96SSRA-MB/ME96SSHB-MB/ME96SSRB-MB.

*5: Applicable only when ME96SSHB-MB/ME96SSRB-MB.

*6: Not applicable only when ME96SSHB-MB/ME96SSRB-MB.

*7: "Last" means the rolling demand value of the latest interval time completed.

*8: About the reply data of CO2 equivalent, refer to follows.

				Data=	2	3	4	5	6	7	8	9	0	1	2	kg	g							
			Item	Total power [kW]																				Note
CO2 equivalent (Reply data)				less than 10									7	8	9	0	1	2						note1
				10 or more and less than 100									6	7	8	9	0	1						
				100 or more and less than 1000								5	6	7	8	9	0							
				1000 or more and less than 10000					4	5	6	7	8	9										
				10000 or more and less than 100000		3	4	5	6	7	8													
				100000 or more	2	3	4	5	6	7														
CO2 equivalent (LCD display)				less than 10									7	8	9	0	1	2						Unit:kg
				10 or more and less than 100									6	7	8	9	0	1						
				100 or more and less than 1000								5	6	7	8	9	0							
				1000 or more and less than 10000					4	5	6	7	8	9	0	1	2							
				10000 or more and less than 100000		3	4	5	6	7	8	9	0	1										
				100000 or more	2	3	4	5	6	7	8	9	0											

note1: The data will change according to the total load setting of ME96. Multiplying the receiving data by the multiplying factor of section 7.2.5 gives the actual value (unit:kg).

7.2.3 When Setting by Command(2H)

Settings of ME96 can be set by communication.

Monitor pattern setting flag(RX(n+1)0) is used to send the command. (For details, refer to section 6.4.2)

The command can be sent only when the remote READY(RX(n+7)B) is ON.

2H	Data Set																																																																																																																								
<table border="1"> <thead> <tr> <th colspan="4">Remote register RWw(Programmable controller→ME96)</th> </tr> <tr> <th></th><th>b15</th><th>b8</th><th>b7 b0</th></tr> </thead> <tbody> <tr> <td>RWw00</td><td>Group No.</td><td>0H</td><td>2H</td></tr> <tr> <td>RWw01</td><td>Index number</td><td colspan="2">Channel No.</td></tr> <tr> <td>RWw02</td><td colspan="3">Low data</td></tr> <tr> <td>RWw03</td><td colspan="3">High data</td></tr> <tr> <td>RWw04</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw05</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw06</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw07</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>to</td><td colspan="3">to</td></tr> <tr> <td>RWw1C</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw1D</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw1E</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWw1F</td><td>00H</td><td colspan="2">00H</td></tr> </tbody> </table>	Remote register RWw(Programmable controller→ME96)					b15	b8	b7 b0	RWw00	Group No.	0H	2H	RWw01	Index number	Channel No.		RWw02	Low data			RWw03	High data			RWw04	00H	00H		RWw05	00H	00H		RWw06	00H	00H		RWw07	00H	00H		to	to			RWw1C	00H	00H		RWw1D	00H	00H		RWw1E	00H	00H		RWw1F	00H	00H		<table border="1"> <thead> <tr> <th colspan="4">Remote register RWw(ME96→Programmable controller)</th> </tr> <tr> <th></th><th>b15</th><th>b8</th><th>b7 b0</th></tr> </thead> <tbody> <tr> <td>RWr00</td><td>Channel No.</td><td colspan="2">Group No.</td></tr> <tr> <td>RWr01</td><td>00H</td><td colspan="2">(Error code)</td></tr> <tr> <td>RWr02</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr03</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr04</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr05</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr06</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr07</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>to</td><td colspan="3">to</td></tr> <tr> <td>RWr1C</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr1D</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr1E</td><td>00H</td><td colspan="2">00H</td></tr> <tr> <td>RWr1F</td><td>00H</td><td colspan="2">00H</td></tr> </tbody> </table>	Remote register RWw(ME96→Programmable controller)					b15	b8	b7 b0	RWr00	Channel No.	Group No.		RWr01	00H	(Error code)		RWr02	00H	00H		RWr03	00H	00H		RWr04	00H	00H		RWr05	00H	00H		RWr06	00H	00H		RWr07	00H	00H		to	to			RWr1C	00H	00H		RWr1D	00H	00H		RWr1E	00H	00H		RWr1F	00H	00H	
Remote register RWw(Programmable controller→ME96)																																																																																																																									
	b15	b8	b7 b0																																																																																																																						
RWw00	Group No.	0H	2H																																																																																																																						
RWw01	Index number	Channel No.																																																																																																																							
RWw02	Low data																																																																																																																								
RWw03	High data																																																																																																																								
RWw04	00H	00H																																																																																																																							
RWw05	00H	00H																																																																																																																							
RWw06	00H	00H																																																																																																																							
RWw07	00H	00H																																																																																																																							
to	to																																																																																																																								
RWw1C	00H	00H																																																																																																																							
RWw1D	00H	00H																																																																																																																							
RWw1E	00H	00H																																																																																																																							
RWw1F	00H	00H																																																																																																																							
Remote register RWw(ME96→Programmable controller)																																																																																																																									
	b15	b8	b7 b0																																																																																																																						
RWr00	Channel No.	Group No.																																																																																																																							
RWr01	00H	(Error code)																																																																																																																							
RWr02	00H	00H																																																																																																																							
RWr03	00H	00H																																																																																																																							
RWr04	00H	00H																																																																																																																							
RWr05	00H	00H																																																																																																																							
RWr06	00H	00H																																																																																																																							
RWr07	00H	00H																																																																																																																							
to	to																																																																																																																								
RWr1C	00H	00H																																																																																																																							
RWr1D	00H	00H																																																																																																																							
RWr1E	00H	00H																																																																																																																							
RWr1F	00H	00H																																																																																																																							

* At normal communication, Error code is 00h.
About the other error code, refer to Table 7.24.

* It is described as 8 bits data by combining the unit No. (high 4 bits) and the command (low 4 bits)

For example, When the unit No. is 0H and the command is 2H, it becomes "02H".

- A setting item of ME96 can be set by storing Group No., Channel No. and setting data to remote register(RWw).
- About Group No. and Channel No., refer to Table 7.14)
- The details of data format are shown in the Table 7.15 to Table 7.22

* After writing the set-up value, about 2 seconds (max 4 seconds) is needed to restart the measurement based on new set-up value.

Table 7.14 List of Group and Channel for Setting

Unit No.	Group (h)	Channel (h)	Name of Cannel	Setting range	ME96SSH-MB	ME96SSR-MB	ME96SSRA-MB	ME96SSRB-MB	Data type	Note
					3P4W 1P3W	3P3W 1P2W	3P4W 1P3W	3P3W 1P2W		
0	E0	11	Primary current	1.0A to 30000.0A	○	○	○	○	○	⑤ *1
0	E0	12	Primary voltage(L-L)	60V to 75000V	- (*11)	○	○	- (*11)	○	○
0	E0	1B	Primary voltage(L-N)	60V to 75000V	○	-	-	○	-	⑤ *3
0	E0	1C	Secondary voltage	(Refer to *4)	○	○	○	○	○	⑤ *4
0	E0	13	Phase wiring	Refer to data type ⑥	○	○	○	○	○	⑥
0	E0	1D	Frequency	50Hz, 60Hz	○	○	○	○	○	⑤
0	E0	1E	Secondary current	5A, 1A	○	○	○	○	○	⑤
0	E0	18	Alarm items	Refer to data type ⑦	○	○	○	○	○	⑦
0	02	E0	Time constant for current demand	0 to 1800 sec.	○	○	○	○	○	⑥ *5
0	08	E4	Interval time constant	1 to 60 min	○	○	○	○	○	⑥ *6
0	08	E5	Subinterval time constant	1 to 60 min	○	○	○	○	○	⑥ *6
0	80	01	Active energy import	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	80	63	Active energy export	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	81	01	Reactive energy import lag	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	81	63	Reactive energy export lag	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	81	64	Reactive energy import lead	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	81	65	Reactive energy export lead	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	82	01	Apparent energy	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	8B	01	Periodic active energy(Period 1)	0 to 999999 x Multiplying	○	○	○	○	○	② *7
0	8C	01	Periodic active energy(Period 2)	0 to 999999 x Multiplying	○	○	○	○	○	② *7
1	92	01	Periodic active energy(Period 3)	0 to 999999 x Multiplying	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	② *7
0	01	14	Current upper limit	5 to 120% (1% step)	○	○	○	○	○	⑤ *8
0	01	15	Current lower limit	3 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	01	94	Current upper limit(Phase N)	5 to 120% (1% step)	○	-	-	○	-	⑤ *8
0	02	14	Current demand upper limit	5 to 120% (1% step)	○	○	○	○	○	⑤ *8
0	02	15	Current demand lower limit	3 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	02	94	Current demand upper limit (Phase N)	5 to 120% (1% step)	○	-	-	○	-	⑤ *8
0	05	14	Voltage upper limit(L-L)	25 to 135% (1% step)	○	○	○	○	○	⑤ *8
0	05	15	Voltage lower limit(L-L)	20 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	03	14	Voltage upper limit(L-N)	25 to 135% (1% step)	○	○	○	○	○	⑤ *8
0	03	15	Voltage lower limit(L-N)	20 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	07	14	Active power upper limit	-95 to 120% (1% step)	○	○	○	○	○	⑤ *8
0	07	15	Active power lower limit	-120 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	08	14	Rolling demand (kW) upper limit (Last)	5 to 120% (1% step)	○	○	○	○	○	⑤ *8
2	08	22	Rolling demand (kW) upper limit (Present)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
2	08	23	Rolling demand (kW) upper limit (Predict)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
0	09	14	Reactive power upper limit	-95 to 120% (1% step)	○	○	○	○	○	⑤ *8
0	09	15	Reactive power lower limit	-120 to 95% (1% step)	○	○	○	○	○	⑤ *8
0	0A	14	Rolling demand (kvar) upper limit (Last)	5 to 120% (1% step)	○(*9)	○(*9)	○(*9)	○(*9)	○(*9)	⑤ *8
2	0A	22	Rolling demand (kvar) upper limit (Present)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
2	0A	23	Rolling demand (kvar) upper limit (Predict)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
0	0C	14	Rolling demand (kVA) upper limit (Last)	5 to 120% (1% step)	○(*9)	○(*9)	○(*9)	○(*9)	○(*9)	⑤ *8
2	0C	22	Rolling demand (kVA) upper limit (Present)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
2	0C	23	Rolling demand (kVA) upper limit (Predict)	5 to 120% (1% step)	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤ *8
0	0D	14	Power factor upper limit	-0.05 to 1 to 0.05 (0.05 step)	○	○	○	○	○	⑤ *8
0	0D	15	Power factor lower limit	-0.05 to 1 to 0.05 (0.05 step)	○	○	○	○	○	⑤ *8
0	0F	14	Frequency upper limit	45 to 65Hz (1Hz step)	○	○	○	○	○	⑤ *8
0	0F	15	Frequency lower limit	45 to 65Hz (1Hz step)	○	○	○	○	○	⑤ *8
0	77	E1	H.V(L-N) upper limit	0.5 to 20% (0.5% step)	○	○	○	○	○	⑤ *8
0	76	E1	H.V(L-L) upper limit	0.5 to 20% (0.5% step)	○	○	○	○	○	⑤ *8
0	75	E1	H.A upper limit	1 to 120% (1% step)	○	○	○	○	○	⑤ *8
0	75	F1	H.A upper limit(Phase N)	1 to 120% (1% step)	○	-	-	○	-	⑤ *8
1	01	25	Current unbalance limit	1 to 99% (1% step)	○(*10)	○(*10)	-	○(*10)	○(*10)	-
1	03	25	Voltage unbalance limit	1 to 99% (1% step)	○(*10)	○(*10)	-	○(*10)	○(*10)	-
0	80	E4	CO2 equivalent rate	0.000 to 0.999	○(*10)	○(*10)	○(*10)	○(*10)	○(*10)	⑤
0	A1	3A	16bit set register 1	Refer to data type ⑧	○	○	○	○	○	⑧
0	A1	3B	16bit set register 2	Refer to data type ⑧	○	○	○	○	○	⑧

*1: In details of setting data and setting ranges, please refer each user's manuals.

*2: Effective value of primary voltage(L-L) is follows.

- 3P4W
 Use the primary voltage value (L-N) (*3).
- 3P3W or 1P2W
 - In details of setting data and setting ranges, please refer each user's manuals.
 - If setting value is a direct voltage value (Ex. 110V, 220V or 440V), it is set "Direct input", and set the primary voltage which is transmitted as the direct input voltage. In other case, it is set "With VT".
- 1P3W
 110V or 220V is valid only.

*3: Effective value of primary voltage(L-N) is follows.

- 3P4W
 - In details of setting data and setting ranges, please refer each user's manuals.
 - If setting value is a direct voltage value (Ex. 63.5V, 100V, 110V, 220V, 230V, 240V, 254V or 277V), it is set "Direct input", and set the primary voltage which is transmitted as the direct input voltage. In other case, it is set "With VT".
 -
- 3P3W, 1P3W or 1P2W
 It is unsupported. Use the primary voltage value (L-L) (*2).

*4: Effective value of secondary voltage is follows.

- 3P4W, 3P3W or 1P2W

 About setting range, please refer to each user's manuals.

 In case of 3P4W, set the voltage of L-N. In case of 3P3W, set the voltage of L-L. If the setting of ME96 is "Direct voltage", the setting is changed "With VT" and set the secondary voltage. Furthermore, the setting of the primary voltage is changed to the initial value or the previous value.

- 1P3W

 It is unsupported.

*5: The set value is the second unit value. (For example of 2 minutes, sets as 120 seconds.) About setting range, please refer to each user's manuals.

*6: When the interval time constant is changed, the subinterval time constant is changed to 1 min. When the subinterval is changed, if the interval time constant cannot be divided by subinterval time constant, it will be the error of illegal data value.

*7: Multiplying factor differs according to settings of phase wiring, primary voltage and primary current. For details, refer to 7.2.5.

*8: About setting of upper/lower limit value.

- About setting range, please refer to each user's manuals.
- Setting of upper/lower limit value is not a percentage value of maximum scale but a direct value.
(In case of current harmonic and phase N current harmonic, use a percentage value for the maximum scale.)
- When the setting value is other than setting step, it is rounded according to following calculation.
 Calculate: Setting value via CC-Link / maximum scale (± 0 step) $\times 100 \rightarrow$ Rounds to the whole number.
 Example: In case of setting value is 55.5kW, maximum scale (± 0 step) is 100kW.
 $55.5\text{kW} / 100\text{kW} \times 100 = 55.5\% \rightarrow 56\%$
- When out of range is set, the error code of invalid data is replied, and setting value is not changed.
- If the upper/lower limit value of W, var, DW, Dvar and DVA exceeds $\pm 1638.3\text{MW(Mvar)}$, please set by the main device.

*9: Applicable only when ME96SSHA-MB/ME96SSRA-MB/ME96SSHB-MB/ME96SSRB-MB.

*10: Applicable only when ME96SSHB-MB/ME96SSRB-MB.

*11: Not applicable only when ME96SSHB-MB/ME96SSRB-MB.

7.2.4 Data format of Monitoring by Command(1H) and Setting by Command(2H)

Table 7.15 Data Format (1/8)

Data Measurement Items	Data Format ①																							
Current, Voltage, Active power, Reactive power, Apparent power, Power factor, Frequency, etc.	<p>Multiplying</p> <p>Numerical value</p> <p>Index number</p> <p>Low data</p> <p>High data</p> <p>b15 b8 b7 b0</p> <p>b31 b24 b23 b16 b15 b8 b7 b0</p> <p>Numerical value: 32-bit integer with a sign -2147483648 ~ 2147483647 (80000000H ~ 7FFFFFFFH)</p>																							
Format①	<p><Multiplying factor></p> <p>Multiplying factor is fixed according to settings of primary current, primary voltage, and phase wiring. (Refer to 7.2.5.)</p> <table border="1"> <thead> <tr> <th>Index number</th> <th>Multiplying factor</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>02H</td> <td>$\times 10^2$</td> <td rowspan="6">Actual value = Numerical value \times Multiplying factor</td> </tr> <tr> <td>01H</td> <td>$\times 10$</td> </tr> <tr> <td>00H</td> <td>$\times 1$</td> </tr> <tr> <td>FFH</td> <td>$\times 10^{-1}$</td> </tr> <tr> <td>FEH</td> <td>$\times 10^{-2}$</td> </tr> <tr> <td>FDH</td> <td>$\times 10^{-3}$</td> </tr> </tbody> </table>								Index number	Multiplying factor	Remarks	02H	$\times 10^2$	Actual value = Numerical value \times Multiplying factor	01H	$\times 10$	00H	$\times 1$	FFH	$\times 10^{-1}$	FEH	$\times 10^{-2}$	FDH	$\times 10^{-3}$
Index number	Multiplying factor	Remarks																						
02H	$\times 10^2$	Actual value = Numerical value \times Multiplying factor																						
01H	$\times 10$																							
00H	$\times 1$																							
FFH	$\times 10^{-1}$																							
FEH	$\times 10^{-2}$																							
FDH	$\times 10^{-3}$																							
	<p><Example: Active power></p> <table border="1"> <thead> <tr> <th>Multiplying factor</th> <th>Numerical value</th> <th>Actual value</th> </tr> </thead> <tbody> <tr> <td>FFH $\Rightarrow \times 10^{-1}$</td> <td>000000FFH $\Rightarrow 255$</td> <td>$255 \times 10^{-1} = 25.5[\text{kW}]$</td> </tr> <tr> <td>00H $\Rightarrow \times 1$</td> <td>000000FFH $\Rightarrow 255$</td> <td>$255 \times 1 = 255[\text{kW}]$</td> </tr> <tr> <td>FFH $\Rightarrow \times 10^{-1}$</td> <td>FFFFFFFFFF01H $\Rightarrow -255$</td> <td>$-255 \times 10^{-1} = -25.5[\text{kW}]$</td> </tr> <tr> <td>00H $\Rightarrow \times 1$</td> <td>FFFFFFFFFF01H $\Rightarrow -255$</td> <td>$-255 \times 1 = -255[\text{kW}]$</td> </tr> </tbody> </table>								Multiplying factor	Numerical value	Actual value	FFH $\Rightarrow \times 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kW}]$	00H $\Rightarrow \times 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kW}]$	FFH $\Rightarrow \times 10^{-1}$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 10^{-1} = -25.5[\text{kW}]$	00H $\Rightarrow \times 1$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 1 = -255[\text{kW}]$	
Multiplying factor	Numerical value	Actual value																						
FFH $\Rightarrow \times 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kW}]$																						
00H $\Rightarrow \times 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kW}]$																						
FFH $\Rightarrow \times 10^{-1}$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 10^{-1} = -25.5[\text{kW}]$																						
00H $\Rightarrow \times 1$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 1 = -255[\text{kW}]$																						
	<p>Note: For the active power (demand) and reactive power, $\pm 1638.3\text{MW}(\text{Mvar})$ becomes the upper(lower) value.</p> <p>Note: For the power factor, "+" is showed lag, "-" is showed lead as with ME96's display.</p>																							

Table 7.16 Data Format (2/8)

Data	Data Format ②																																	
<p>Measurement Items Active energy, Reactive energy, Apparent energy, Operation time, CO2 equivalent , etc.</p> <p>Format②</p>	<p><Multiplying factor></p> <p>Multiplying factor is fixed according to settings of primary current, primary voltage, and phase wire system. (Refer to 7.2.5.)</p> <table border="1"> <thead> <tr> <th>Index number</th> <th>Multiplying factor</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>03H</td> <td>x10³</td> <td rowspan="9">Actual value = Numerical value × Multiplying factor</td> </tr> <tr> <td>02H</td> <td>x10²</td> </tr> <tr> <td>01H</td> <td>x10</td> </tr> <tr> <td>00H</td> <td>x1</td> </tr> <tr> <td>FFH</td> <td>x10⁻¹</td> </tr> <tr> <td>FEH</td> <td>x10⁻²</td> </tr> <tr> <td>FDH</td> <td>x10⁻³</td> </tr> <tr> <td>FCH</td> <td>x10⁻⁴</td> </tr> <tr> <td>FBH</td> <td>x10⁻⁵</td> </tr> </tbody> </table> <p><Example: Active Energy></p> <table border="1"> <thead> <tr> <th>Multiplying factor</th> <th>Numerical value</th> <th>Actual value</th> </tr> </thead> <tbody> <tr> <td>FFH⇒x10⁻¹</td> <td>000000FFH⇒255</td> <td>255×10⁻¹ = 25.5[kWh]</td> </tr> <tr> <td>00H⇒x1</td> <td>000000FFH⇒255</td> <td>255×1 = 255[kWh]</td> </tr> </tbody> </table> <p>Note: For active energy (export), reactive energy (export/Lag) and reactive energy (export/Lead), the reply data are unsigned although the display of main device has a “-”(negative) sign.</p>	Index number	Multiplying factor	Remarks	03H	x10 ³	Actual value = Numerical value × Multiplying factor	02H	x10 ²	01H	x10	00H	x1	FFH	x10 ⁻¹	FEH	x10 ⁻²	FDH	x10 ⁻³	FCH	x10 ⁻⁴	FBH	x10 ⁻⁵	Multiplying factor	Numerical value	Actual value	FFH⇒x10 ⁻¹	000000FFH⇒255	255×10 ⁻¹ = 25.5[kWh]	00H⇒x1	000000FFH⇒255	255×1 = 255[kWh]	b15 b8 b7 b0 Index number Low data High data High data Low data b31 b24 b23 b16 b15 b8 b7 b0 Numerical value: 32-bit integer with a sign However, the effective numerical value is 0 to 999999(0H to F423FH) Data changes 999998 → 999999 → 0 → 1 → (Operation time stops at 999999.)	
Index number	Multiplying factor	Remarks																																
03H	x10 ³	Actual value = Numerical value × Multiplying factor																																
02H	x10 ²																																	
01H	x10																																	
00H	x1																																	
FFH	x10 ⁻¹																																	
FEH	x10 ⁻²																																	
FDH	x10 ⁻³																																	
FCH	x10 ⁻⁴																																	
FBH	x10 ⁻⁵																																	
Multiplying factor	Numerical value	Actual value																																
FFH⇒x10 ⁻¹	000000FFH⇒255	255×10 ⁻¹ = 25.5[kWh]																																
00H⇒x1	000000FFH⇒255	255×1 = 255[kWh]																																

Table 7.17 Data Format (3/8)

Data	Data Format ③																														
<p>Measurement Items Active energy, Reactive energy, Apparent energy, (unit fixed)</p> <p>Format③</p>	<p>Multiplying factor</p> <p>Numerical value</p> <p>High data Low data</p> <p>b31 b24 b23 b16 b15 b8 b7 b0</p> <p>Numerical value: 32-bit integer with a sign However, the effective numerical value is 0 to 999999999 (0H to 3B9AC9FFH) Data changes 999999998 → 999999999 → 0 → 1 → ...</p> <p><Multiplying factor> Multiplying factor is fixed by the channel number.</p> <table border="1"> <thead> <tr> <th></th> <th>Index number</th> <th>Multiplying factor</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>MWh, Mvarh, MVAh unit fixed</td> <td>03H</td> <td>x10³</td> <td rowspan="3">Actual value = Numerical value x Multiplying factor [kWh],[kvarh],[kVAh]</td> </tr> <tr> <td>kWh, kvarh, kVAh unit fixed</td> <td>00H</td> <td>x1</td> </tr> <tr> <td>Wh, varh, VAh unit fixed</td> <td>FDH</td> <td>x10⁻³</td> </tr> </tbody> </table> <p><Example : Active energy unit fixed:Wh></p> <table border="1"> <thead> <tr> <th>Multiplying factor</th> <th>Numerical value</th> <th>Actual value</th> </tr> </thead> <tbody> <tr> <td>FDH → x10⁻³</td> <td>FD3ADE68B1H → 987654321</td> <td>987654321[Wh] × 10⁻³ = 987654.321[kWh]</td> </tr> </tbody> </table> <p><Example : Active energy unit fixed:kWh></p> <table border="1"> <thead> <tr> <th>Multiplying factor</th> <th>Numerical value</th> <th>Actual value</th> </tr> </thead> <tbody> <tr> <td>00H → x1</td> <td>FD3ADE68B1H → 987654321</td> <td>987654321[KWh] × 1 = 987654321[kWh]</td> </tr> </tbody> </table> <p>Note: For active energy (export), reactive energy (export/Lag) and reactive energy (export/Lead), the reply data are unsigned although the display of main device has a “-”(negative) sign.</p>		Index number	Multiplying factor	Remarks	MWh, Mvarh, MVAh unit fixed	03H	x10 ³	Actual value = Numerical value x Multiplying factor [kWh],[kvarh],[kVAh]	kWh, kvarh, kVAh unit fixed	00H	x1	Wh, varh, VAh unit fixed	FDH	x10 ⁻³	Multiplying factor	Numerical value	Actual value	FDH → x10 ⁻³	FD3ADE68B1H → 987654321	987654321[Wh] × 10 ⁻³ = 987654.321[kWh]	Multiplying factor	Numerical value	Actual value	00H → x1	FD3ADE68B1H → 987654321	987654321[KWh] × 1 = 987654321[kWh]	b15 b8 b7 b0	Index number	Low data	High data
	Index number	Multiplying factor	Remarks																												
MWh, Mvarh, MVAh unit fixed	03H	x10 ³	Actual value = Numerical value x Multiplying factor [kWh],[kvarh],[kVAh]																												
kWh, kvarh, kVAh unit fixed	00H	x1																													
Wh, varh, VAh unit fixed	FDH	x10 ⁻³																													
Multiplying factor	Numerical value	Actual value																													
FDH → x10 ⁻³	FD3ADE68B1H → 987654321	987654321[Wh] × 10 ⁻³ = 987654.321[kWh]																													
Multiplying factor	Numerical value	Actual value																													
00H → x1	FD3ADE68B1H → 987654321	987654321[KWh] × 1 = 987654321[kWh]																													

Table 7.18 Data Format (4/8)

Data	Data Format ④				
Alarm state 1 Format④	<p>Unused (00H fixed) ← Index number</p> <p>Unused (0000H fixed) ← Low data</p> <p>High data</p> <p>High data</p> <p>b15 b8 b7 b0</p> <p>b15 b8 b7 b0</p> <p>High data</p> <p>Alarm state</p>				

<The allocation of the alarm state 1>

Bit	Content	Data		ME96SSH/ SSHA/SSRA/ SSHB/SSRB	ME96SSR
		OFF(0)	ON(1)		
b0	Digital Input 1	OFF	ON	○	○
b1	Digital Input 2	OFF	ON	○	○
b2	Digital Input 3	OFF	ON	○	○
b3	Digital Input 4	OFF	ON	○	○
b4	Reserved	—	—	—	—
b5	Alarm (Total)	Non-Alarm	Alarm	○	○
b6	Alarm of Current Demand	Non-Alarm	Alarm	○	○
b7	Alarm of Rolling Demand (Total)	Non-Alarm	Alarm	○*3	—
b8	Alarm of Voltage	Non-Alarm	Alarm	○	○
b9	Alarm of Current	Non-Alarm	Alarm	○	○
b10	Alarm of Active power	Non-Alarm	Alarm	○	○
b11	Alarm of Reactive power	Non-Alarm	Alarm	○	○
b12	Alarm of Frequency	Non-Alarm	Alarm	○	○
b13	Alarm of Power factor	Non-Alarm	Alarm	○	○
b14	Alarm of T.H.D (Voltage)	Non-Alarm	Alarm	○	○
b15	Alarm of Harmonic current	Non-Alarm	Alarm	○	○

Alarm judging items of each phase wiring are shown as follows.

Upper/lower limit alarm element	Monitored phase			
	3P4W	3P3W(3CT,2CT)	1P3W(1N2)	1P3W(1N3)
Upper limit current, current demand	1, 2, 3	1, 2, 3	1, N, 2	1, N, 3
Lower limit current, current demand	1, 2, 3	1, 2, 3	1, 2	1, 3
Upper limit N-phase current, N-phase current demand	N	—	—	—
Lower limit N-phase current, N-phase current demand	N	—	—	—
Upper limit voltage (L-L) (*1)	12, 23, 31	12, 23, 31	1N, 2N, 12	1N, 3N, 13
Lower limit voltage (L-L) (*1)	12, 23, 31	12, 23, 31	1N, 2N, 12	1N, 3N, 13
Upper limit voltage (L-N)	1N, 2N, 3N	—	—	—
Lower limit voltage (L-N)	1N, 2N, 3N	—	—	—
Upper limit active power, reactive power, power factor	Total	Total	Total	Total
Lower limit active power, reactive power, power factor	Total	Total	Total	Total
Upper limit frequency	1N	12	1N	1N
Lower limit frequency	1N	12	1N	1N
Harmonic current total RMS value	1, 2, 3	1, 2, 3 (*2)	1, 2	1, 3
Harmonic current total RMS value N-phase	N	—	—	—
Harmonic voltage total distortion ratio	1N, 2N, 3N	12, 23	1N, 2N	1N, 3N
Upper limit rolling demand	Total	Total	Total	Total

*1: For phase 12 (or phase 31) at 1-phase 3-wire, alarm monitoring is executed using a value that is two times the set upper/lower limit alarm value.

*2: Only 3P3W (3CT) is measured for the phase 2 harmonic current.

*3: In case of ME96SSHA/SSRA/SSHB/SSRB, the alarm state is total of the rolling demand W/var/VA.

<Continuation>

Data	Data Format ④			
Alarm state 2	<p>The diagram illustrates the structure of Data Format ④. It shows a 16-bit register divided into three fields: Index number (bits b15 to b8), Low data (bits b7 to b0), and High data (bits b15 to b8). The High data field is further expanded to show 16 bits b15 to b0, which are labeled as the 'Alarm state'. Arrows point from the text labels to their corresponding bit positions in the register.</p>			

Format④

<The allocation of the alarm state 2>

Bit	Data			ME96SSH/SSR ME96SSHA/SSRA ME96SSHB/SSRB
	Content	OFF(0)	ON(1)	
b0	Upper limit alarm of current (phase 1)	Non-Alarm	Alarm	○
b1	Upper limit alarm of current (phase 2)	Non-Alarm	Alarm	○
b2	Upper limit alarm of current (phase 3)	Non-Alarm	Alarm	○
b3	Upper limit alarm of current (phase N)	Non-Alarm	Alarm	○
b4	Upper limit alarm of current (total)	Non-Alarm	Alarm	○
b5	Lower limit alarm of current (total)	Non-Alarm	Alarm	○
b6	Upper limit alarm of L-L voltage (total)	Non-Alarm	Alarm	○
b7	Lower limit alarm of L-L voltage (total)	Non-Alarm	Alarm	○
b8	Upper limit alarm of L-N voltage (1-N)	Non-Alarm	Alarm	○
b9	Upper limit alarm of L-N voltage (2-N)	Non-Alarm	Alarm	○
b10	Upper limit alarm of L-N voltage (3-N)	Non-Alarm	Alarm	○
b11	Upper limit alarm of L-N voltage (total)	Non-Alarm	Alarm	○
b12	Lower limit alarm of L-N voltage (1-N)	Non-Alarm	Alarm	○
b13	Lower limit alarm of L-N voltage (2-N)	Non-Alarm	Alarm	○
b14	Lower limit alarm of L-N voltage (3-N)	Non-Alarm	Alarm	○
b15	Lower limit alarm of L-N voltage (total)	Non-Alarm	Alarm	○

<Continuation>

Data	Data Format ④				
<p style="margin-left: 100px;">Unused (00H fixed) ← Index number</p> <p style="margin-left: 100px;">Unused (0000H fixed) ← Low data</p> <p style="margin-left: 100px;">High data</p> <p style="margin-left: 100px;">↓</p> <p style="margin-left: 100px;">High data</p> <p style="margin-left: 100px;">b15 b8 b7 b0</p> <p style="margin-left: 100px;">[] [] [] []</p> <p style="margin-left: 100px;">b15 b8 b7 b0</p> <p style="margin-left: 100px;">[] [] [] []</p> <p style="margin-left: 100px;">[] [] [] []</p> <p style="margin-left: 100px;">↓</p> <p style="margin-left: 100px;">Alarm state</p>	<p style="text-align: right;">b15 b8 b7 b0</p>				

Format④

<The allocation of the alarm state 3>

Bit	Data			ME96SSHB/SSRB
	Content	OFF(0)	ON(1)	
b0	Reserved	-	-	-
b1	Reserved	-	-	-
b2	Reserved	-	-	-
b3	Reserved	-	-	-
b4	Reserved	-	-	-
b5	Reserved	-	-	-
b6	Upper limit alarm of Current unbalance	Non-Alarm	Alarm	○
b7	Upper limit alarm of Voltage unbalance	Non-Alarm	Alarm	○
b8	Reserved	-	-	-
b9	Reserved	-	-	-
b10	Reserved	-	-	-
b11	Reserved	-	-	-
b12	Reserved	-	-	-
b13	Reserved	-	-	-
b14	Reserved	-	-	-
b15	Reserved	-	-	-

Table 7.19 Data Format (5/8)

Data	Data Format ⑤																																										
<p>Setting Items</p> <p>Primary current, Primary Voltage, Secondary current, Secondary Voltage, Frequency, Upper/lower limit, CO2 equivalent rate, etc.</p> <p>Format⑤</p>	<p>Multiplying factor</p> <p>Numerical value</p> <p>Numerical value: 32-bit integer with a sign -2147483648 to 2147483647 (80000000H to 7FFFFFFFH)</p> <p><Multiplying factor> Multiplying factor is fixed according to setting of the phase wiring, primary voltage and primary current. (Refer to 7.2.5). Numerical value is changed into integer according to the significant digits, the multiplying factor is changed.</p> <table border="1"> <thead> <tr> <th>Multiplying factor</th> <th>Index number</th> <th>Numerical value</th> </tr> </thead> <tbody> <tr> <td>$\times 10^{-4}$</td> <td>FCH</td> <td>Integer data</td> </tr> <tr> <td>$\times 10^{-3}$</td> <td>FDH</td> <td>Integer data</td> </tr> <tr> <td>$\times 10^{-2}$</td> <td>FEH</td> <td>Integer data</td> </tr> <tr> <td>$\times 10^{-1}$</td> <td>FFH</td> <td>Integer data</td> </tr> <tr> <td>x1</td> <td>00H</td> <td>Integer data</td> </tr> <tr> <td>x10</td> <td>01H</td> <td>Integer data</td> </tr> <tr> <td>$\times 10^2$</td> <td>02H</td> <td>Integer data</td> </tr> </tbody> </table> <p><Example: Primary current ></p> <table border="1"> <thead> <tr> <th>Setting data</th> <th>Multiplying factor</th> <th>Numerical value</th> </tr> </thead> <tbody> <tr> <td>Setting data = 100.0A</td> <td>$\times 10^{-1} \Rightarrow FFH$</td> <td>1000 $\Rightarrow 000003E8H$</td> </tr> <tr> <td>Setting data = 400A</td> <td>$\times 1 \Rightarrow 00H$</td> <td>400 $\Rightarrow 00000190H$</td> </tr> </tbody> </table> <p><Example: Primary voltage></p> <table border="1"> <thead> <tr> <th>Setting data</th> <th>Multiplying factor</th> <th>Numerical value</th> </tr> </thead> <tbody> <tr> <td>Setting data = 110.0V</td> <td>$\times 10^{-1} \Rightarrow FFH$</td> <td>1100 $\Rightarrow 0000044CH$</td> </tr> <tr> <td>Setting data = 3300V</td> <td>$\times 1 \Rightarrow 00H$</td> <td>3300 $\Rightarrow 0000CE4H$</td> </tr> </tbody> </table>	Multiplying factor	Index number	Numerical value	$\times 10^{-4}$	FCH	Integer data	$\times 10^{-3}$	FDH	Integer data	$\times 10^{-2}$	FEH	Integer data	$\times 10^{-1}$	FFH	Integer data	x1	00H	Integer data	x10	01H	Integer data	$\times 10^2$	02H	Integer data	Setting data	Multiplying factor	Numerical value	Setting data = 100.0A	$\times 10^{-1} \Rightarrow FFH$	1000 $\Rightarrow 000003E8H$	Setting data = 400A	$\times 1 \Rightarrow 00H$	400 $\Rightarrow 00000190H$	Setting data	Multiplying factor	Numerical value	Setting data = 110.0V	$\times 10^{-1} \Rightarrow FFH$	1100 $\Rightarrow 0000044CH$	Setting data = 3300V	$\times 1 \Rightarrow 00H$	3300 $\Rightarrow 0000CE4H$
Multiplying factor	Index number	Numerical value																																									
$\times 10^{-4}$	FCH	Integer data																																									
$\times 10^{-3}$	FDH	Integer data																																									
$\times 10^{-2}$	FEH	Integer data																																									
$\times 10^{-1}$	FFH	Integer data																																									
x1	00H	Integer data																																									
x10	01H	Integer data																																									
$\times 10^2$	02H	Integer data																																									
Setting data	Multiplying factor	Numerical value																																									
Setting data = 100.0A	$\times 10^{-1} \Rightarrow FFH$	1000 $\Rightarrow 000003E8H$																																									
Setting data = 400A	$\times 1 \Rightarrow 00H$	400 $\Rightarrow 00000190H$																																									
Setting data	Multiplying factor	Numerical value																																									
Setting data = 110.0V	$\times 10^{-1} \Rightarrow FFH$	1100 $\Rightarrow 0000044CH$																																									
Setting data = 3300V	$\times 1 \Rightarrow 00H$	3300 $\Rightarrow 0000CE4H$																																									

Table 7.20 Data Format (6/8)

Data	Data Format ⑥																																																																				
<p>Setting Items</p> <p>Phase wiring, Time constant for current demand, Interval time, Subinterval time etc.</p> <p>Format⑥</p>	<p>Numerical value: 32-bit integer with a sign -2147483648 to 2147483647 (80000000H to 7FFFFFFFH)</p> <p><Data(Numerical value)></p> <ol style="list-style-type: none"> 1) Phase wiring <table border="1"> <thead> <tr> <th>Setting data</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>Single phase 2 wire (1P2W)</td><td>00000001H</td><td></td></tr> <tr><td>Single phase 3 wire (1P3W)(1N3 display)</td><td>00000002H</td><td></td></tr> <tr><td>Three phase 3 wire (3P3W_2CT)</td><td>00000003H</td><td></td></tr> <tr><td>Three phase 4 wire (3P4W)</td><td>00000004H</td><td></td></tr> <tr><td>Single phase 3 wire (1P3W)(1N2 display)</td><td>00000005H</td><td></td></tr> <tr><td>Three phase 3 wire (3P3W_3CT)</td><td>00000006H</td><td></td></tr> </tbody> </table> <ol style="list-style-type: none"> 2) Time constant for current demand <table border="1"> <thead> <tr> <th>Example</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>2 minutes = 120 seconds</td><td>00000078H</td><td></td></tr> </tbody> </table> <ol style="list-style-type: none"> 3) Interval time / Subinterval time <table border="1"> <thead> <tr> <th>Example</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>15 minutes</td><td>0000000FH</td><td></td></tr> </tbody> </table> <ol style="list-style-type: none"> 4) Byte monitor <table border="1"> <thead> <tr> <th>Model</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>All models of ME96</td><td>C50A 0500H</td><td></td></tr> </tbody> </table> <ol style="list-style-type: none"> 5) Attribute monitor <table border="1"> <thead> <tr> <th>Model</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>All models of ME96</td><td>C510 1000H</td><td></td></tr> </tbody> </table> <ol style="list-style-type: none"> 6) Model code <table border="1"> <thead> <tr> <th>Example</th> <th>Data</th> <th>Note.</th> </tr> </thead> <tbody> <tr><td>ME96SSH-MB</td><td>00000014H</td><td></td></tr> <tr><td>ME96SSR-MB</td><td>00000013H</td><td></td></tr> <tr><td>ME96SSHA-MB</td><td>00000017H</td><td></td></tr> <tr><td>ME96SSRA-MB</td><td>00000016H</td><td></td></tr> <tr><td>ME96SSHB-MB</td><td>0000001BH</td><td></td></tr> <tr><td>ME96SSRB-MB</td><td>0000001AH</td><td></td></tr> </tbody> </table>	Setting data	Data	Note.	Single phase 2 wire (1P2W)	00000001H		Single phase 3 wire (1P3W)(1N3 display)	00000002H		Three phase 3 wire (3P3W_2CT)	00000003H		Three phase 4 wire (3P4W)	00000004H		Single phase 3 wire (1P3W)(1N2 display)	00000005H		Three phase 3 wire (3P3W_3CT)	00000006H		Example	Data	Note.	2 minutes = 120 seconds	00000078H		Example	Data	Note.	15 minutes	0000000FH		Model	Data	Note.	All models of ME96	C50A 0500H		Model	Data	Note.	All models of ME96	C510 1000H		Example	Data	Note.	ME96SSH-MB	00000014H		ME96SSR-MB	00000013H		ME96SSHA-MB	00000017H		ME96SSRA-MB	00000016H		ME96SSHB-MB	0000001BH		ME96SSRB-MB	0000001AH		b15 b8 b7 b0	Index number
Setting data	Data	Note.																																																																			
Single phase 2 wire (1P2W)	00000001H																																																																				
Single phase 3 wire (1P3W)(1N3 display)	00000002H																																																																				
Three phase 3 wire (3P3W_2CT)	00000003H																																																																				
Three phase 4 wire (3P4W)	00000004H																																																																				
Single phase 3 wire (1P3W)(1N2 display)	00000005H																																																																				
Three phase 3 wire (3P3W_3CT)	00000006H																																																																				
Example	Data	Note.																																																																			
2 minutes = 120 seconds	00000078H																																																																				
Example	Data	Note.																																																																			
15 minutes	0000000FH																																																																				
Model	Data	Note.																																																																			
All models of ME96	C50A 0500H																																																																				
Model	Data	Note.																																																																			
All models of ME96	C510 1000H																																																																				
Example	Data	Note.																																																																			
ME96SSH-MB	00000014H																																																																				
ME96SSR-MB	00000013H																																																																				
ME96SSHA-MB	00000017H																																																																				
ME96SSRA-MB	00000016H																																																																				
ME96SSHB-MB	0000001BH																																																																				
ME96SSRB-MB	0000001AH																																																																				

Table 7.21 Data Format (7/8)

Data	Data Format ⑦							
Setting Items	<p>The diagram illustrates the structure of Data Format 7. It starts with a header consisting of b15, b8, b7, and b0 bits. Below this is an 'Index number' field. A dashed box encloses four 'Alarm Item' fields, each containing 'High data' and 'Low data' sections. Each alarm item is a b31-bit field, subdivided into b24, b23, b16, b15, b8, b7, and b0 bits.</p> <p>Note: The numbers of alarms which can set are 4 items.</p>							

Alarm Item

<Content of alarm items>

Data		Explanation	ME96 SSHB /SSRB	ME96 SSHA /SSRA	ME96 SSH	ME96 SSR
Dec.	Hex.					
00	00	No alarm	○	○	○	○
01	01	The upper limit alarm of current	○	○	○	○
02	02	The lower limit alarm of current	○	○	○	○
03	03	The upper limit alarm of phase N current	○	○	○	○
09	09	The upper limit alarm of current demand	○	○	○	○
10	0A	The lower limit alarm of current demand	○	○	○	○
11	0B	The upper limit alarm of phase N current demand	○	○	○	○
17	11	The upper limit alarm of L-L voltage	○	○	○	○
18	12	The lower limit alarm of L-L voltage	○	○	○	○
19	13	The upper limit alarm of L-N voltage	○	○	○	○
20	14	The lower limit alarm of L-N voltage	○	○	○	○
21	15	The upper limit alarm of active power	○	○	○	○
22	16	The lower limit alarm of active power	○	○	○	○
23	17	The upper limit alarm of rolling demand (kW) (Last)	○	○	○	-
25	19	The upper limit alarm of reactive power	○	○	○	○
26	1A	The lower limit alarm of reactive power	○	○	○	○
27	1B	The upper limit alarm of power factor	○	○	○	○
28	1C	The lower limit alarm of power factor	○	○	○	○
29	1D	The upper limit alarm of frequency	○	○	○	○
30	1E	The lower limit alarm of frequency	○	○	○	○
31	1F	The upper limit alarm of current harmonic	○	○	○	○
32	20	The upper limit alarm of voltage harmonic	○	○	○	○
33	21	The upper limit alarm of phase N current harmonic	○	○	○	○
35	23	The upper limit alarm of rolling demand (kvar)(Last)	○	○	-	-
36	24	The upper limit alarm of rolling demand (kVA) (Last)	○	○	-	-
37	25	The upper limit alarm of current unbalance	○	-	-	-
38	26	The upper limit alarm of voltage unbalance	○	-	-	-
39	27	The upper limit alarm of rolling demand (kW)(Present)	○	-	-	-
40	28	The upper limit alarm of rolling demand (kvar)(Present)	○	-	-	-
41	29	The upper limit alarm of rolling demand (kVA)(Present)	○	-	-	-
42	2A	The upper limit alarm of rolling demand (kW)(Predict)	○	-	-	-
43	2B	The upper limit alarm of rolling demand (kvar)(Predict)	○	-	-	-
44	2C	The upper limit alarm of rolling demand (kVA)(Predict)	○	-	-	-

Table 7.22 Data Format (8/8)

Data	Data Format ⑧																																																																																									
Setting Items 16bit set register1	<p style="text-align: center;"> </p> <p>Format⑧</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th colspan="4" style="text-align: center;">Data</th> <th rowspan="2" style="text-align: right; vertical-align: middle;">ME96SSH/SSR ME96SSHA/SSRA ME96SSHB/SSRB</th> </tr> <tr> <th style="text-align: center;">Bit</th> <th style="text-align: center;">Content</th> <th style="text-align: center;">ON(1)</th> <th style="text-align: center;">OFF(0)</th> </tr> </thead> <tbody> <tr> <td>b0</td> <td>Reset of all alarm</td> <td>executed</td> <td>—</td> <td>○</td> </tr> <tr> <td>b1</td> <td>Reset of all energy(*1) and all max/min value(*2)</td> <td>executed</td> <td>—</td> <td>○</td> </tr> <tr> <td>b2</td> <td>Reset of all max/min value(*2)</td> <td>executed</td> <td>—</td> <td>○</td> </tr> <tr> <td>b3</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b4</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b5</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b6</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b7</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b8</td> <td>Reset of all digital input (DI) latch</td> <td>executed</td> <td>—</td> <td>○</td> </tr> <tr> <td>b9</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b10</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b11</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b12</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b13</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> <tr> <td>b14</td> <td>Reset of all energy(*1)</td> <td>executed</td> <td>—</td> <td>○</td> </tr> <tr> <td>b15</td> <td>Unusable</td> <td>—</td> <td>—</td> <td>—</td> </tr> </tbody> </table> <p>*1: Periodic active energy and CO2 equivalent are not reset. Active energy (import/export), reactive energy (import(LEAD/LAG) /export(LEAD/LAG)), apparent energy and operating time are reset. *2: Maximum value of rolling demand power is not reset.</p>	Data				ME96SSH/SSR ME96SSHA/SSRA ME96SSHB/SSRB	Bit	Content	ON(1)	OFF(0)	b0	Reset of all alarm	executed	—	○	b1	Reset of all energy(*1) and all max/min value(*2)	executed	—	○	b2	Reset of all max/min value(*2)	executed	—	○	b3	Unusable	—	—	—	b4	Unusable	—	—	—	b5	Unusable	—	—	—	b6	Unusable	—	—	—	b7	Unusable	—	—	—	b8	Reset of all digital input (DI) latch	executed	—	○	b9	Unusable	—	—	—	b10	Unusable	—	—	—	b11	Unusable	—	—	—	b12	Unusable	—	—	—	b13	Unusable	—	—	—	b14	Reset of all energy(*1)	executed	—	○	b15	Unusable	—	—	—
Data				ME96SSH/SSR ME96SSHA/SSRA ME96SSHB/SSRB																																																																																						
Bit	Content	ON(1)	OFF(0)																																																																																							
b0	Reset of all alarm	executed	—	○																																																																																						
b1	Reset of all energy(*1) and all max/min value(*2)	executed	—	○																																																																																						
b2	Reset of all max/min value(*2)	executed	—	○																																																																																						
b3	Unusable	—	—	—																																																																																						
b4	Unusable	—	—	—																																																																																						
b5	Unusable	—	—	—																																																																																						
b6	Unusable	—	—	—																																																																																						
b7	Unusable	—	—	—																																																																																						
b8	Reset of all digital input (DI) latch	executed	—	○																																																																																						
b9	Unusable	—	—	—																																																																																						
b10	Unusable	—	—	—																																																																																						
b11	Unusable	—	—	—																																																																																						
b12	Unusable	—	—	—																																																																																						
b13	Unusable	—	—	—																																																																																						
b14	Reset of all energy(*1)	executed	—	○																																																																																						
b15	Unusable	—	—	—																																																																																						

<Continuation>

Data	Data Format ⑧																																																																																																																														
<p>Setting Items 16bit set register2</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">Format⑧</div>	<p>b15 b8 b7 b0</p> <p>Unused (00H fixed) Index number</p> <p>Unused (0000H fixed) Low data</p> <p>High data</p> <p>High data</p> <p>b15 b8 b7 b0</p> <p>Set register</p>																																																																																																																														
<p><16bit set register 2></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2" style="text-align: center;">Bit</th> <th colspan="3" style="text-align: center;">Data</th> <th rowspan="2" style="text-align: center;">ME96 SSHB /SSRB</th> <th rowspan="2" style="text-align: center;">ME96 SSH /SSHA /SSRA</th> <th rowspan="2" style="text-align: center;">ME96 SSR</th> </tr> <tr> <th style="text-align: center;">Content</th> <th style="text-align: center;">ON(1)</th> <th style="text-align: center;">OFF(0)</th> </tr> </thead> <tbody> <tr> <td>b0</td><td>Select of periodic active energy (period 1) (*1)</td><td>Select</td><td>Cancel</td><td><input type="radio"/></td><td><input type="radio"/></td><td><input type="radio"/></td></tr> <tr> <td>b1</td><td>Select of periodic active energy (period 2) (*1)</td><td>Select</td><td>Cancel</td><td><input type="radio"/></td><td><input type="radio"/></td><td><input type="radio"/></td></tr> <tr> <td>b2</td><td>Select of periodic active energy (period 3) (*1)</td><td>Select</td><td>Cancel</td><td><input type="radio"/></td><td>—</td><td>—</td></tr> <tr> <td>b3</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b4</td><td>Reset of periodic active energy (period 1)</td><td>executed</td><td>—</td><td><input type="radio"/></td><td><input type="radio"/></td><td><input type="radio"/></td></tr> <tr> <td>b5</td><td>Reset of periodic active energy (period 2)</td><td>executed</td><td>—</td><td><input type="radio"/></td><td><input type="radio"/></td><td><input type="radio"/></td></tr> <tr> <td>b6</td><td>Reset of periodic active energy (period 3)</td><td>executed</td><td>—</td><td><input type="radio"/></td><td>—</td><td>—</td></tr> <tr> <td>b7</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b8</td><td>Reset of maximum value of all rolling demand</td><td>executed</td><td>—</td><td><input type="radio"/></td><td><input type="radio"/></td><td>—</td></tr> <tr> <td>b9</td><td>Reset of CO2 equivalent value</td><td>executed</td><td>—</td><td><input type="radio"/></td><td>—</td><td>—</td></tr> <tr> <td>b10</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b11</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b12</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b13</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> <tr> <td>b14</td><td>Restart of rolling demand calculation</td><td>executed</td><td>—</td><td><input type="radio"/></td><td><input type="radio"/></td><td>—</td></tr> <tr> <td>b15</td><td>Unusable</td><td>—</td><td>—</td><td>—</td><td>—</td><td>—</td></tr> </tbody> </table>						Bit	Data			ME96 SSHB /SSRB	ME96 SSH /SSHA /SSRA	ME96 SSR	Content	ON(1)	OFF(0)	b0	Select of periodic active energy (period 1) (*1)	Select	Cancel	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	b1	Select of periodic active energy (period 2) (*1)	Select	Cancel	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	b2	Select of periodic active energy (period 3) (*1)	Select	Cancel	<input type="radio"/>	—	—	b3	Unusable	—	—	—	—	—	b4	Reset of periodic active energy (period 1)	executed	—	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	b5	Reset of periodic active energy (period 2)	executed	—	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	b6	Reset of periodic active energy (period 3)	executed	—	<input type="radio"/>	—	—	b7	Unusable	—	—	—	—	—	b8	Reset of maximum value of all rolling demand	executed	—	<input type="radio"/>	<input type="radio"/>	—	b9	Reset of CO2 equivalent value	executed	—	<input type="radio"/>	—	—	b10	Unusable	—	—	—	—	—	b11	Unusable	—	—	—	—	—	b12	Unusable	—	—	—	—	—	b13	Unusable	—	—	—	—	—	b14	Restart of rolling demand calculation	executed	—	<input type="radio"/>	<input type="radio"/>	—	b15	Unusable	—	—	—	—	—
Bit	Data			ME96 SSHB /SSRB	ME96 SSH /SSHA /SSRA		ME96 SSR																																																																																																																								
	Content	ON(1)	OFF(0)																																																																																																																												
b0	Select of periodic active energy (period 1) (*1)	Select	Cancel	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																																																																																																																									
b1	Select of periodic active energy (period 2) (*1)	Select	Cancel	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																																																																																																																									
b2	Select of periodic active energy (period 3) (*1)	Select	Cancel	<input type="radio"/>	—	—																																																																																																																									
b3	Unusable	—	—	—	—	—																																																																																																																									
b4	Reset of periodic active energy (period 1)	executed	—	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																																																																																																																									
b5	Reset of periodic active energy (period 2)	executed	—	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>																																																																																																																									
b6	Reset of periodic active energy (period 3)	executed	—	<input type="radio"/>	—	—																																																																																																																									
b7	Unusable	—	—	—	—	—																																																																																																																									
b8	Reset of maximum value of all rolling demand	executed	—	<input type="radio"/>	<input type="radio"/>	—																																																																																																																									
b9	Reset of CO2 equivalent value	executed	—	<input type="radio"/>	—	—																																																																																																																									
b10	Unusable	—	—	—	—	—																																																																																																																									
b11	Unusable	—	—	—	—	—																																																																																																																									
b12	Unusable	—	—	—	—	—																																																																																																																									
b13	Unusable	—	—	—	—	—																																																																																																																									
b14	Restart of rolling demand calculation	executed	—	<input type="radio"/>	<input type="radio"/>	—																																																																																																																									
b15	Unusable	—	—	—	—	—																																																																																																																									

*1: When the bit in on(1), the active energy (import) is add to the active energy (period n). (where n=1,2,3)

7.2.5 Multiplying factor

The conditions of multiplying factor by setup of each element are shown below.

Table 7.23 Multiplying factor

Element	Unit	Condition		Multiplying factor
Voltage Harmonics voltage	V	Primary voltage	less than 440V	x10 ⁻¹
			440V or more	x1
Current Current demand Harmonics current	A	Primary current	less than 4A	x10 ⁻³
			4A or more and less than 40A	x10 ⁻²
			40A or more and less than 400A	x10 ⁻¹
			400A or more and less than 4000A	x1
Active power Rolling demand power Reactive power Apparent power	kW kvar kVA	Total load power *1	0kW or more and less than 1.2kW	x10 ⁻⁴
			1.2kW or more and less than 12kW	x10 ⁻³
			12kW or more and less than 120kW	x10 ⁻²
			120kW or more and less than 1200kW	x10 ⁻¹
			1200kW or more and less than 12000kW	x1
			12000kW or more and less than 120000kW	x10
			120000kW or more	x10 ²
Active energy Reactive energy Apparent energy CO2 equivalent	kWh kvarh kVAh	Total load power *1	0kW or more and less than 10kW	x10 ⁻²
			10kW or more and less than 100kW	x10 ⁻¹
			100kW or more and less than 1000kW	x1
			1000kW or more and less than 10000kW	x10
			10000kW or more and less than 100000kW	x10 ²
			100000kW or more	x10 ³
Active energy (extended) Reactive energy (extended)	kWh kvarh	Total load power *1	0kW or more and less than 10kW	x10 ⁻⁵
			10kW or more and less than 100kW	x10 ⁻⁴
			100kW or more and less than 1000kW	x10 ⁻³
			1000kW or more and less than 10000kW	x10 ⁻²
			10000kW or more and less than 100000kW	x10 ⁻¹
			100000kW or more	x1
Power factor	%	-	-	x10 ⁻¹
Frequency	Hz	-	-	x10 ⁻¹
Harmonics distortion (Current)	%	-	-	x10 ⁻¹
Harmonics distortion (Voltage)	%	-	-	x10 ⁻¹
Active energy (unit: Wh fixed) Reactive energy (unit: varh fixed) Apparent energy (unit: VA fixed)	Wh varh VAh	-	-	x10 ⁻³
Active energy (unit: kWh fixed) Reactive energy (unit: kvarh fixed) Apparent energy (unit: kVA fixed)	kWh kvarh kVAh	-	-	x1
Active energy (unit: MWh fixed) Reactive energy (unit: Mvarh fixed) Apparent energy (unit: MVA fixed)	MWh Mvarh MVAh	-	-	x10 ³
Operating time	h	-	-	x1
Current/Voltage unbalance	%	-	-	x10 ⁻²

*1: How to calculate primary rated power is as follows.

$$\text{Total rated power [kW]} = \frac{\alpha \times (\text{Primary voltage}) \times (\text{Primary current})}{1000}$$

Phase wiring	α	Note
1P2W	$\alpha=1$	
1P3W	$\alpha=2$	Primary voltage is L-N voltage.
3P3W	$\alpha=1.732$	
3P4W	$\alpha=3$	Primary voltage is L-N voltage.

7.2.6 About Error Occurrence

When the command and related data transmitted to ME96 is improper or ME96 is in H/W error, RX(n+7)A (Error status flag) becomes 1(ON), the error code shown in Table 7.24 is returned as reply data.

Table 7.24 Error Code

Error Description	Error Code (Hex.)
Illegal command or packet length	40h
Invalid group number	41h
Invalid channel number	42h
ME96 is in set-up mode or test mode	43h, 44h
Invalid data for set-up	51h
It is not set the item of alarm	55h

If an error occurs, the error code is written into the RWn as shown in the figure below, and RX(n+7)A (error status flag) is turned on (error occurrence) and RX(n+7)B (remote READY) is turned off (normal communication stop). For the error resetting method, refer to "6.3 Error Communication".

8. Abbreviations and Special Terms

Abbreviations and special terms used in this manual are shown below:

Abbreviation and Special Terms	Description
Master station	Station which controls remote stations and local stations. One station is required for one system.
Local station	Station with the CPU which can communicate with master station and other local stations.
Remote I/O station	Remote station which deals with bit information only.
Remote device station	Remote station which deals with bit information and word information.
Remote station	General name for remote I/O station and remote device station. Controlled by a master station.
Intelligent device station	Station that can perform transient transmission.
RX	Remote input
RY	Remote output
RWw	Remote register (write area)
RWr	Remote register (read area)
Command	Identification code allocated to items to be monitored or set. ME96 uses a special-purpose command that is transmitted to monitor each measurement value or set each parameter.
Demand value	The demand value is an approximate average value during the demand time period. When it is set to 0, each demand present value becomes equivalent to the present value.

9. Program Example

9.1 Program Content

This program example is assumed the system configuration in below.


In the program, at first, the parameters of the linked number and station information are set, and the data link with the parameter of buffer memory starts up.

Next, the reading data shown in below is monitored continuously.

Also, this program is made by using "SW8D5C-GPPW GX Developer".

Note: The refresh set with the automatic refresh parameters and the refresh executed with the FROM/TO instructions cannot be performed simultaneously.

9.2 System Configuration



※Reading data


Station number 1: ME96	Moniter using monitoring by pattern (P08). Phase 1 current, Phase 2 current, Phase 3 current, 1-2 voltage, 2-3 voltage, 3-1 voltage, Total active power, Active energy (import).
	Moniter using monitoring by command(1H). Total reactive power, Total power factor, Rective energy (import lag).
Station number 2: ME96	Same as above.

9.3 Parameter Settings

Parameter settings are set as following with GX Developer.


9.3.1 Network Parameter Settings and Auto Refresh Parameter Settings

The following is shown CC-Link network parameter settings and auto refresh parameter settings.



9.3.2 Operational Settings

Operational settings are as follows.



9.3.3 Station Information Settings

Station information settings are as follows.

Station No.	Station type	Expanded cyclic setting	Exclusive station count	Remote station points	Reserve/invalid station select	Intelligent buffer select(word)		
						Send	Receive	Automatic
1/1	Ver.2 Remote device station	octuple	Exclusive station 1	128 points	No setting			
2/2	Ver.2 Remote device station	octuple	Exclusive station 1	128 points	No setting			

At the bottom are buttons: Default, Check, End, and Cancel.


9.4 Device Allocation


Allocation of transmitted device


Items	Contents	Device No.	Note
Remote input (RX)	Station number 1: Remote input (RX00 to RX7F)	X1000 to X107F	Set X1000 to remote input(RX) refresh device.
	Station number 2: Remote input (RX00 to RX7F)	X1080 to X10FF	
Remote output (RY)	Station number 1: Remote output (RY00 to RY7F)	Y1000 to Y107F	Set Y1000 to remote output(RY) refresh device.
	Station number 2: Remote output (RY00 to RY7F)	Y1080 to Y10FF	
Remote register (RWr)	Station number 1: Remote register(RWr0 to RWr3)	W0000 to W001F	Set W0000 to remote register(RWr) refresh device.
	Station number 2: Remote register (RWr0 to RWr3)	W0020 to W003F	
Remote register (RWw)	Station number 1: Remote register (RWw0 to RWw3)	W1000 to W101F	Set W1000 to remote register(RWw) refresh device.
	Station number 2: Remote register (RWw0 to RWw3)	W1020 to W103F	
Link special relay (SB)	Link special relay of master station (SB0 to SB01FF)	SB0 to SB01FF	Set SB0 to link special relay(SB) refresh device.
Link special register (SW)	Link special register of master station (SW0 to SW01FF)	SW0 to SW01FF	Set SW0 to link special register(SW) refresh device.
Items of sending data	Sending data for monitoring by command(1H).	D0 to D31	Number of items are mentioned in section 9.2.
Error code	For station number 1:	D1000 to D1031	
	For station number 2:	D1050 to D1081	
Station error	For station number 1:	M0	0: Normal 1: Data link error occurred
	For station number 2:	M1	
Check of setting completion flag	For station number 1:	M100	To check the OFF.
	For station number 2:	M101	
Check of monitor pattern setting flag	For station number 1:	M150	To check the OFF.
	For station number 2:	M151	
Start of monitoring	For station number 1:	M200	
	For station number 2:	M201	
Start of received data	For station number 1:	M250	
	For station number 2:	M251	
Reception of error for monitoring by pattern	For station number 1:	M300	
	For station number 2:	M301	
Wait time for clear error	For station number 1:	T0	
	For station number 2:	T1	
Start time for monitor communication	For station number 1:	T50	
	For station number 2:	T51	
Reception time for monitoring by pattern	For station number 1:	T100	
	For station number 2:	T101	
Time out	For station number 1:	T150	
	For station number 2:	T151	
Index modification	For the select of station number	Z0	Uses Z0 or Z1. (To be indexed the timer)
	For the flag of remote I/O	Z2	
	For the remote register	Z3	
	For the write device of received data	Z4	
	For the flag of monitoring by pattern	Z5	


Items	Contents		Device No.	Note	
Received data	Station number 1	Total reactive power	Multiplying factor, 00h Numerical value	R1 R2, R3	
		Total power factor	Multiplying factor, 00h Numerical value	R5 R6, R7	
		Reactive energy (import lag)	Multiplying factor, 00h Numerical value	R9 R10, R11	
		Phase 1 current	Multiplying factor, 00h Numerical value	R33 R34, R35	
		Phase 2 current	Multiplying factor, 00h Numerical value	R37 R38, R39	
		Phase 3 current	Multiplying factor, 00h Numerical value	R41 R42, R43	
		1-2 voltage	Multiplying factor, 00h Numerical value	R45 R46, R47	
		2-3 voltage	Multiplying factor, 00h Numerical value	R49 R50, R51	
		3-1 voltage	Multiplying factor, 00h Numerical value	R53 R54, R55	
		Total active power	Multiplying factor, 00h Numerical value	R57 R58, R59	
		Active energy (import)	Multiplying factor, 00h Numerical value	R61 R62, R63	
		Total reactive power	Multiplying factor, 00h Numerical value	R101 R102, R103	
		Total power factor	Multiplying factor, 00h Numerical value	R105 R106, R107	
		Reactive energy (import lag)	Multiplying factor, 00h Numerical value	R109 R110, R111	
Received data	Station number 2	Phase 1 current	Multiplying factor, 00h Numerical value	R133 R134, R135	
		Phase 2 current	Multiplying factor, 00h Numerical value	R137 R138, R139	
		Phase 3 current	Multiplying factor, 00h Numerical value	R141 R142, R143	
		1-2 voltage	Multiplying factor, 00h Numerical value	R145 R146, R147	
		2-3 voltage	Multiplying factor, 00h Numerical value	R149 R150, R151	
		3-1 voltage	Multiplying factor, 00h Numerical value	R153 R154, R155	
		Total active power	Multiplying factor, 00h Numerical value	R157 R158, R159	
		Active energy (import)	Multiplying factor, 00h Numerical value	R161 R162, R163	
Active value = Numerical value × Multiplying factor					
Active value = Numerical value × Multiplying factor					


9.5 Program Example











10. Test Mode

ME96 has the test mode which the fixed values are replied even if the voltage and current are not input. It can be used to check the communication to programmable controller.

10.1 ME96SSH/SSR/SSHA/SSRA/SSHB/SSRB-MB

(1) Shift to Test Mode

Operation of ME96 is necessary. At first, shifts to the setting value confirmation mode from the operation mode. And then, select "9" of menu number, and shifts to the test menu screen. And then, select "1" of menu number, and shifts to the test mode. (For details, refer to each user's manual)

(2) How to Test

In the test mode, you need to appear values which wanted to monitor on the screen of ME96. For example, if you want to monitor the active power, you need to appear the active power on the screen of ME96.

① Replied Data

Values displayed on the screen of ME96 can be monitored by CC-Link communication. Measurement elements not displayed on the screen are zero (only power factor is 1.000). When DI1 to DI4 are used, it is also possible to monitor the digital input status.

② Display screen

In the same as the operating mode, items are displayed when making settings such as those for the display pattern. Maximum and minimum values can be displayed. (Cyclic function is invalid.)

③ Button Operations

Button	Operation
[DISPLAY]	Switch the measurement screen.
[PHASE]	Switch phase display. Switch between the harmonic RMS value and distortion ratio. (Available on the harmonics display screen)
[MAXMIN]	Enter/Exit the Max/Min value screen.
[+], [-]	Switch the item expressed with the bar graph. Switch the harmonic degree. (Available on the harmonics display screen)
[+]+[-] for 2 seconds	Change the units such as Wh, varh, and VAh.
[SET]	Test mode is finished and back to test menu screen.

* In details of valid operation, please refer each user's manuals.