



Energy Measuring Unit Programming Manual (CC-Link) For ver.1 remote device station

MODEL

EMU4-FD1-MB

- Before operating the instrument, you should first read thoroughly this operation manual for safe operation and optimized performance of the product.
Deliver this user's manual to the end user.

CONTENTS

1.	General Description	2
2.	Specification.....	3
3.	Configuration Conditions of CC-Link System.....	4
3.1	Remote net ver.1 mode	4
3.2	Remote net ver.2 mode	5
4.	Programming	7
4.1	Programming Procedure	7
5.	Parameter Settings	8
5.1	Procedure from Parameter Settings to Data Link Startup	8
5.1.1	CPU Parameter Area and Master Module Parameter Memory	8
5.1.2	Procedure for Parameter Settings to Data Link Startup with GX Developer.....	8
5.2	Example of Parameter Settings with GX Developer	9
5.2.1	Master Station Network Parameter Settings.....	9
6.	Communication Between the Master Station and Measuring Unit	13
6.1	Communication Guideline	13
6.2	Initial Communication	14
6.3	Error Communication.....	14
6.4	Normal Communication	15
7.	Remote I/O and Remote Register.....	16
7.1	Remote Input RX, Remote Output RY	16
7.1.1	Remote input RX.....	16
7.1.2	Remote Output RY	19
7.2	Remote Register (RW _r , RW _w)	21
7.2.1	Supported Command	24
7.2.2	Details of Commands.....	25
7.2.3	Data Composition.....	35
7.2.4	Significant digits and Multiplying factor.....	43
7.2.5	About Error Occurrence	48
8.	Abbreviations and Special Terms.....	50
9.	Program Example	51
9.1	Program Example 1	51
9.2	Program Example 2	64
10.	Test Mode	80
10.1	How to Test.....	80

1. General Description

This manual describes the programming methods that should be created by the user for monitoring measurement value of Energy Measuring Unit (called Measuring Unit from here on) with the Control & Communication Link (abbreviated as CC-Link from here on).

In programming, read the following related manuals in addition to this manual.

Table 1.1 Related Manuals

Manual Name	Manual No.
CC-Link System Master/Local Module User's Manual type QJ61BT11	SH-080016 (13JL91)
CC-Link System Master/Local Module User's Manual type QJ61BT11N	SH-080394E (13JR64)
CC-Link System Master/Local Module User's Manual type AJ61BT11/A1SJ61BT11	IB-66721 (13J872)
CC-Link System Master/Local Module User's Manual type AJ61QBT11/A1SJ61QBT11	IB-66722 (13J873)
MELSEC-L CC-Link System Master/Local Module User's Manual	SH-080895ENG (13JZ41)
FX2N-16CCL-M USER'S MANUAL	JY992D93101 (09R710)
FX3U-16CCL-M USER'S MANUAL	JY997D43601 (09R724)
User's Manual for Measuring Unit	Supplied with product or download.

NOTICE

When using Energy Measuring Unit EcoMonitorLight (EMU4-FD1-MB), is necessary CC-Link communication is not available without optional plug-in module.

In this manual, "EMU4-FD1-MB" means the main device of EcoMonitorLight with the optional plug-in module (model: EMU4-CM-C)


Point							
EMU4-FD1-MB, can be setup the version of remote device station by the dip switch of the CC-Link Communication Unit (model: EMU4-CM-C).							
Use the following as a guideline in setting the remote device station version and set the version.							
<table border="1"><thead><tr><th>Setup</th><th>Guideline for selection</th></tr></thead><tbody><tr><td>Ver.1remote device station (Ver.1 compatible slave station)</td><td>Select this when utilizing the conventional program, because of compatibility with Measuring unit previous EMU4.</td></tr><tr><td>Ver.2remote device station (Ver.2 compatible slave station)</td><td>Select this when configuring a new system or the being newly added to the existing system in combination with the applicable master module.</td></tr></tbody></table>		Setup	Guideline for selection	Ver.1remote device station (Ver.1 compatible slave station)	Select this when utilizing the conventional program, because of compatibility with Measuring unit previous EMU4.	Ver.2remote device station (Ver.2 compatible slave station)	Select this when configuring a new system or the being newly added to the existing system in combination with the applicable master module.
Setup	Guideline for selection						
Ver.1remote device station (Ver.1 compatible slave station)	Select this when utilizing the conventional program, because of compatibility with Measuring unit previous EMU4.						
Ver.2remote device station (Ver.2 compatible slave station)	Select this when configuring a new system or the being newly added to the existing system in combination with the applicable master module.						
This programming manual is for ver.1 remote device station. For use in the ver.2 remote device station (Ver.2 compatible slave station), refer to the following manual. EMU4 Programming Manual (CC-Link)(For ver.2 remote device station)							

2. Specification

Measuring Unit specification is shown in Table 2.1.

Table 2.1 CC-Link Specification

Item	Specification
CC-Link station type	Remote device station (ver.1 remote device station)
Number of occupied stations	1 station
Maximum number of stations per master station	42 stations (In case of connecting only remote device station occupied by 1 station.)
Transmission speed	156kbps/625kbps/2.5Mbps/5Mbps/10Mbps
Remote I/O (RX, RY)	32 points each
Remote register (RWw, RWr)	4 points each




3. Configuration Conditions of CC-Link System

3.1 Remote net ver.1 mode

A total of 64 remote I/O stations, remote device stations, local stations, standby master stations, or intelligent device stations can be connected to a single master station.

However, the following conditions must all be satisfied.

Condition 1	$\{(1 \times a) + (2 \times b) + (3 \times c) + (4 \times d)\} \leq 64$	a: Number of modules occupying 1 station (Measuring Unit is applied) b: Number of modules occupying 2 stations c: Number of modules occupying 3 stations d: Number of modules occupying 4 stations
Condition 2	$\{(16 \times A) + (54 \times B) + (88 \times C)\} \leq 2304$	A: Number of remote I/O stations ≤ 64 B: Number of remote device stations (Measuring Unit is applied) ≤ 42 C: Number of local stations, standby master stations and intelligent device stations ≤ 26




3.2 Remote net ver.2 mode

A total of 64 remote I/O stations, remote device stations, local stations, standby master stations, or intelligent device stations can be connected to a single master station.

However, the following conditions must all be satisfied.


Condition 1	$\{(a+a2+a4+a8) + (b+b2+b4+b8) \times 2 + (c+c2+c4+c8) \times 3 + (d+d2+d4+d8) \times 4\} \leq 64$	a: The total number of ver.1 compatible slave stations that occupy 1 station, and ver.2 compatible slave stations that occupy 1 station which are set to "Single". (Measuring Unit is applied)
Condition 2	$[(a \times 32) + (a2 \times 32) + (a4 \times 64) + (a8 \times 128)] + [(b \times 64) + (b2 \times 96) + (b4 \times 192) + (b8 \times 384)] + [(c \times 96) + (c2 \times 160) + (c4 \times 320) + (c8 \times 640)] + [(d \times 128) + (d2 \times 224) + (d4 \times 448) + (d8 \times 896)] \leq 8192$	b: The total number of ver.1 compatible slave stations that occupy 2 stations, and ver.2 compatible slave stations that occupy 2 stations which are set to "Single". c: The total number of ver.1 compatible slave stations that occupy 3 stations, and ver.2 compatible slave stations that occupy 3 stations which are set to "Single". d: The total number of ver.1 compatible slave stations that occupy 4 stations, and ver.2 compatible slave stations that occupy 4 stations which are set to "Single".
Condition 3	$[(a \times 4) + (a2 \times 8) + (a4 \times 16) + (a8 \times 32)] + [(b \times 8) + (b2 \times 16) + (b4 \times 32) + (b8 \times 64)] + [(c \times 12) + (c2 \times 24) + (c4 \times 48) + (c8 \times 96)] + [(d \times 16) + (d2 \times 32) + (d4 \times 64) + (d8 \times 128)] \leq 2048$	a2: The number of ver.2 compatible stations that occupy 1 station which are set to "Double". b2: The number of ver.2 compatible stations that occupy 2 stations which are set to "Double". c2: The number of ver.2 compatible stations that occupy 3 stations which are set to "Double". d2: The number of ver.2 compatible stations that occupy 4 stations which are set to "Double". a4: The number of ver.2 compatible stations that occupy 1 station which are set to "Quadruple". b4: The number of ver.2 compatible stations that occupy 2 stations which are set to "Quadruple". c4: The number of ver.2 compatible stations that occupy 3 stations which are set to "Quadruple". d4: The number of ver.2 compatible stations that occupy 4 stations which are set to "Quadruple". a8: The number of ver.2 compatible stations that occupy 1 station which are set to "Octuple". b8: The number of ver.2 compatible stations that occupy 2 stations which are set to "Octuple". c8: The number of ver.2 compatible stations that occupy 3 stations which are set to "Octuple". d8: The number of ver.2 compatible stations that occupy 4 stations which are set to "Octuple".
Condition 4	$\{(16 \times A) + (54 \times B) + (88 \times C)\} \leq 2304$	A: Number of remote I/O stations ≤ 64 B: Number of remote device stations (Measuring Unit is applied) ≤ 42 C: Number of local stations, standby master stations and intelligent device stations ≤ 26



4. Programming

4.1 Programming Procedure

Create a program which executes the “Monitoring of the measurement values” by following the procedure below:



5. Parameter Settings

5.1 Procedure from Parameter Settings to Data Link Startup

The following explains the procedure from setting the parameters to stating the data link.

5.1.1 CPU Parameter Area and Master Module Parameter Memory


(1) CPU Parameter Area

This area is used to set the basic values for controlling the programmable controller system and the network parameters that control the CC-Link system.

(2) Master Station Parameter Memory


This area stores the network parameters for the CC-Link system.

When the module is powered OFF or the programmable controller CPU is reset, the network parameters are erased.




5.1.2 Procedure for Parameter Settings to Data Link Startup with GX Developer

Follow the procedure below for parameter settings to data link startup:



5.2 Example of Parameter Settings with GX Developer


This section explains the parameter settings using the GX Developer. For more details on the GX Developer operation, refer to the GX Developer Operating Manual. The explanations in this section are based on the following example of the system configuration.



5.2.1 Master Station Network Parameter Settings

- 1) Double-click on the “Network param”.
- 2) Double-click on the “CC-Link” on the “Network parameter” screen.
- 3) Set the parameters as required.

The following describes an example of the parameter settings.




Setting Item	Description	Example for settings	Remarks
No.of boards in module	Set the "No. of boards in module" for which the network parameters are to be set.	1	
Start I/O No	Set the "Start I/O No." for the master station.	0000	Please setup same value of start XY of CC-Link Unit in PC parameter setup
Operational settings	Set the following: ·Parameter name ·Data link err station setting ·Case of CPU Stop setting ·Block data assurance per station	Refer to next page.	Even if the Parameter name is not set, this will not affect the operation of the CC-Link system
Type	Set the station type.	Master station	
Mode	Set the CC-Link mode.	Remote net (Ver.1 mode)	"Remote net ver.2 mode" and "Remote net additional mode" can be also used in case of the QJ61BT11N.
All connect count	Set the total number of connected stations in the CC-Link system including reserved stations.	2 (modules)	
Remote input (RX)	Set the remote input (RX) refresh device.	X100	Device name - Select from X, M, L, B, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote output (RY)	Set the remote output (RY) refresh device.	Y100	Device name - Select from Y, M, L, B, T, C, ST, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RWr)	Set the remote register (RWr) refresh device.	W300	Device name - Select from M, L, B, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RWw)	Set the remote register (RWw) refresh device.	W400	Device name - Select from M, L, B, T, C, ST, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Special relay (SB)	Set the link special relay (SB) refresh device.	SB0	Device name - Select from M, L, B, D, W, R, SB or ZR. Device number - Within the range of the device points that the CPU has.
Special register (SW)	Set the link special register (SW) refresh device.	SW0	Device name - Select from M, L, B, D, W, R, SW or ZR. Device number - Within the range of the device points that the CPU has.
Retry count	Set the number of retries for "Retry count", when a communication error occurs.	3	
Automatic reconnection station count	Set the number of modules that can return to system operation by a single link scan.	1	
Standby master station No.	Set the station number for the standby master station	Blank	Blank: No standby master station specified.
PLC down select	Set the data link status for "PLC down select", when a master station programmable controller CPU error occurs.	Stop	
Scan mode setting	Set whether the link scan for the sequence scan is synchronous or asynchronous.	Asynchronous	
Delay information setting	Set for the link scan delay time.	0	
Station information settings	Set the station data.	Refer to page12	

POINT


- (1) For the automatic refresh parameter setting, set the start device only. Devices are automatically assigned until the last station number including reserved stations and occupied stations.
 In the example of the system configuration in this section, the last station number is "2". Therefore, total of remote I/O points is 64 points ($32 \times 2 = 64$) and total of remote register points is 8 points ($4 \times 2 = 8$). If refresh device of remote input (RX) is set to "X100" and that of remote register (RWr) is set to "W300", the end devices will be "X13F" and "W307" respectively.
- (2) When setting X, Y, B, W, SB and SW as refresh devices, make setting so that they do not overlap with the device numbers used on the other networks, etc.

『Example for Operational settings』



Setting Item	Example for settings	Description	Remarks
Parameter name	"SAMPLE"	Set the Parameter name.	Even if the Parameter name is not set, this will not affect the operation of the CC-Link system
Data link disorder station setting	Clear ("Hold input data" not checked)	Set the input status for the data link error station.	
Case of CPU STOP setting	Refresh ("Clears compulsorily" not checked)	Set the slave station refresh/compulsory clear setting at programmable controller CPU STOP.	
Block data assurance per station	Disable ("Enable setting" not checked)	Set the block guarantee of cyclic data per station.	

《Example for Station information settings》



Setting Item	Description	Example for settings	Remarks
Station type	Set the station data.	Remote device station	Set the "remote device station" in case of the Measuring Unit. (If setting of "Mode" is remote net(Ver.2 mode, Set the "Ver.1 Remote device station".)
Number of occupied stations *		Occupies 1 station	Set the "Occupies 1 station" in case of the Measuring Unit.
Remote station points		32 points [when occupies 1 station]	Cannot be changed.
Reserved/invalid station select		No setting	

* "Number of exclusive stations" on the screen is described as "Number of occupied stations" in this manual.

"Exclusive station 1" on the screen is described as "Occupies 1 station" in this manual

6. Communication Between the Master Station and Measuring Unit


6.1 Communication Guideline

There are three communication statuses (Initial Communication, Normal Communication, Error Communication) between the Master station and Measuring Unit.

The following can be performed at normal communication.

- Monitoring of the measurement values such as the current, voltage and energy, etc.
- Setting the set data of the time constant for current demand.


Measuring Unit has a special-purpose command for each measurement items and each setting items. It becomes possible to monitor measurement value or to set the setting value by writing the command into the remote register RWw of the master station.



6.2 Initial Communication


Initial communication is performed at the beginning after the power supply is turned on or hardware is reset.

Refer to section 7.1 about the remote input RX and the remote output RY.



- ① After the power supply is turned on, or hardware is reset, the initial data processing request flag is turned on by Measuring Unit.
- ② After the initial data processing request flag is turned on, turn on the initial data setting completion flag.
- ③ After the initial data setting completion flag is turned on, the initial data processing request flag is turned off and the remote READY is turned on.
- ④ After the initial data processing request flag is turned off, turned off the initial data setting completion flag.

6.3 Error Communication




- ① When an error occurs in Measuring Unit, error status flag is turned on and the remote READY is turned off.
- ② When the error status flag is turned on, read the error code from the remote register RWr. Eliminate the cause of the error while referring to the red error code. When resuming communication with Measuring Unit, turn on the error reset request flag.
- ③ After the error reset request flag is turned on, the error status flag is turned off.
- ④ After the error status flag is turned off, turn off the error reset request flag.
- ⑤ After the error reset request flag is turned off, the remote READY is turned on and normal communication is resumed.

Note: Refer to “**7.2.5 Error Occurrence**” for error code.

6.4 Normal Communication

After initial data processing is complete, the normally communication is performed to monitor the measurement values and to set the parameters.



① After writing the command and related data into the remote register RWw, turn on the command execution request flag.

② After receiving the reply data corresponding to the command, the command completion reply flag turned on.

③ After the command completion reply flag is turned on, read the reply data from the remote register RWw.

④ After reading the reply data, cancel the command execution request by turning off the command execution request flag.

⑤ After the command execution request flag is turned off, the command completion reply flag is turned off.

Note1: When sending commands successively, repeat ① to ⑤ above.

Note2: The command can be sent only when the remote READY is ON.

7. Remote I/O and Remote Register

7.1 Remote Input RX, Remote Output RY

The remote input RX and remote output RY are used to communicate for bit data between the master station and Measuring Unit.

7.1.1 Remote input RX

The allocation of the remote input RX of Measuring Unit is shown in the table below.

Device No.	Signal name	Description		EMU4-FD1 -MB	Note
		OFF(0)	ON(1)		
RXn0	Alarm of Pulse	Non-Alarm state	Alarm state	○	Note 2 Note 3
RXn1	Reserved	—	—	—	
RXn2	Alarm of Demand current	Non-Alarm state	Alarm state	○	Note 2
RXn3	Alarm of Demand Active power	Non-Alarm state	Alarm state	○	Note 2
RXn4	Contact Input	OFF(open)	ON(close)	○	Note 4
RXn5	Alarm (total)	Non-Alarm state	Alarm state	○	Note 2
RXn6	Reserved	—	—	—	
RXn7	Reserved	—	—	—	
RXn8	Alarm of Voltage	Non-Alarm state	Alarm state	○	Note 2
RXn9	Reserved	—	—	—	
RXnA	Reserved	—	—	—	
RXnB	Reserved	—	—	—	
RXnC	Reserved	—	—	—	
RXnD	Alarm of Power factor	Non-Alarm state	Alarm state	○	Note 2
RXnE	Reserved	—	—	—	
RXnF	Command completion reply flag	No receiving of reply date	Receiving of reply data	○	Note 1
RX(n+1)0	Reserved	—	—	—	
RX(n+1)1	Reserved	—	—	—	
RX(n+1)2	Reserved	—	—	—	
RX(n+1)3	Reserved	—	—	—	
RX(n+1)4	Reserved	—	—	—	
RX(n+1)5	Reserved	—	—	—	
RX(n+1)6	Reserved	—	—	—	
RX(n+1)7	Reserved	—	—	—	
RX(n+1)8	Initial data processing request flag	Power OFF, remote READY ON, or error status flag ON	Power supply is turned ON or hardware reset	○	Note 1
RX(n+1)9	Reserved	—	—	—	
RX(n+1)A	Error status flag	No error occurrence	Error occurrence	○	Note 1
RX(n+1)B	Remote READY	Command sending not possible	Normally communication status (Command sending possible)	○	Note 1
RX(n+1)C	Reserved	—	—	—	
RX(n+1)D	Reserved	—	—	—	
RX(n+1)E	Reserved	—	—	—	
RX(n+1)F	Reserved	—	—	—	

Note1: For the details, refer to "Communication Between the Master Station and Measuring Unit".

Note2: The Alarm is output only when it is set in the Measuring Unit.


Note3: Alarm of Pulse count is available only when Setting of external input signal of EMU4-FD1-MB is setup Pulse input.

Note4: Contact Input is available only when Setting of external input signal of EMU4-FD1-MB is setup Contact input.

Note5: RX is bit data which is stored the input status of Measuring Unit.

Note6: The "n" in the table is determined by the station number of Measuring Unit.

- (1) Relationships between programmable controller CPU, master module and Measuring Unit(RX)
- 1) The input status of Measuring Unit is stored automatically (for each link scan) in the master station's "remote input RX" buffer memory.
 - 2) The input status stored in the "remote input RX" buffer memory is stored in the CPU device set with the automatic refresh parameters.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	X100 ~ X11F	15	X2C0 ~ X2D9	29	X480 ~ X49F
2	X120 ~ X13F	16	X2E0 ~ X2F9	30	X4A0 ~ X4B9
3	X140 ~ X15F	17	X300 ~ X31F	31	X4C0 ~ X4D9
4	X160 ~ X17F	18	X320 ~ X33F	32	X4E0 ~ X4F9
5	X180 ~ X19F	19	X340 ~ X35F	33	X500 ~ X51F
6	X1A0 ~ X1B9	20	X360 ~ X37F	34	X520 ~ X53F
7	X1C0 ~ X1D9	21	X380 ~ X39F	35	X540 ~ X55F
8	X1E0 ~ X1F9	22	X3A0 ~ X3B9	36	X560 ~ X57F
9	X200 ~ X21F	23	X3C0 ~ X3D9	37	X580 ~ X59F
10	X220 ~ X23F	24	X3E0 ~ X3F9	38	X5A0 ~ X5B9
11	X240 ~ X25F	25	X400 ~ X41F	39	X5C0 ~ X5D9
12	X260 ~ X27F	26	X420 ~ X43F	40	X5E0 ~ X5F9
13	X280 ~ X29F	27	X440 ~ X45F	41	X600 ~ X61F
14	X2A0 ~ X2B9	28	X460 ~ X47F	42	X620 ~ X63F

Device No. is determined to "X100~X63F" if refresh device of remote input (RX) is set to "X100".

7.1.2 Remote Output RY

The allocation of the remote output RY of Measuring Unit is shown in the table below.

Device No.	Signal name	Description		Note
		ON(1)→OFF(0)	OFF(0)→ON(1)	
RYn0	Reserved	—	—	
RYn1	Reserved	—	—	
RYn2	Reserved	—	—	
RYn3	Reserved	—	—	
RYn4	Reserved	—	—	
RYn5	Reserved	—	—	
RYn6	Reserved	—	—	
RYn7	Reserved	—	—	
RYn8	Reserved	—	—	
RYn9	Reserved	—	—	
RYnA	Reserved	—	—	
RYnB	Reserved	—	—	
RYnC	Reserved	—	—	
RYnD	Reserved	—	—	
RYnE	Reserved	—	—	
RYnF	Command execution request flag	Cancel command request	Command request	Note 1
RY(n+1)0	Reserved	—	—	
RY(n+1)1	Reserved	—	—	
RY(n+1)2	Reserved	—	—	
RY(n+1)3	Reserved	—	—	
RY(n+1)4	Reserved	—	—	
RY(n+1)5	Reserved	—	—	
RY(n+1)6	Reserved	—	—	
RY(n+1)7	Reserved	—	—	
RY(n+1)8	Initial data setting completion flag	Cancel normal communication request	Normal communication request	Note 1
RY(n+1)9	Reserved	—	—	
RY(n+1)A	Error reset request flag	Cancel error reset request	Error reset request	Note 1
RY(n+1)B	Reserved	—	—	
RY(n+1)C	Reserved	—	—	
RY(n+1)D	Reserved	—	—	
RY(n+1)E	Reserved	—	—	
RY(n+1)F	Reserved	—	—	


Note 1: For the details, refer to "6.Communication Between the Master Station and Measuring Unit"

Note 2: RY is bit device which is sent by the program.

Note 3: The "n" in the table is determined by the station number of Measuring Unit.

Point	
Do not read or write to reserved remote registers. If reading or writing is performed, the functions of Measuring Unit is not guaranteed.	

- (1) Relationships between programmable controller CPU, master module and Measuring Unit(RY)
- 1) The on/off data of the CPU device set with the automatic refresh parameters is stored in the "remote output RY" buffer memory.
 - 2) Remote output RY is automatically set to on/off (for each link scan) according to the output status stored in the "remote output RY" buffer memory.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	Y100 ~ Y11F	15	Y2C0 ~ Y2D9	29	Y480 ~ Y49F
2	Y120 ~ Y13F	16	Y2E0 ~ Y2F9	30	Y4A0 ~ Y4B9
3	Y140 ~ Y15F	17	Y300 ~ Y31F	31	Y4C0 ~ Y4D9
4	Y160 ~ Y17F	18	Y320 ~ Y33F	32	Y4E0 ~ Y4F9
5	Y180 ~ Y19F	19	Y340 ~ Y35F	33	Y500 ~ Y51F
6	Y1A0 ~ Y1B9	20	Y360 ~ Y37F	34	Y520 ~ Y53F
7	Y1C0 ~ Y1D9	21	Y380 ~ Y39F	35	Y540 ~ Y55F
8	Y1E0 ~ Y1F9	22	Y3A0 ~ Y3B9	36	Y560 ~ Y57F
9	Y200 ~ Y21F	23	Y3C0 ~ Y3D9	37	Y580 ~ Y59F
10	Y220 ~ Y23F	24	Y3E0 ~ Y3F9	38	Y5A0 ~ Y5B9
11	Y240 ~ Y25F	25	Y400 ~ Y41F	39	Y5C0 ~ Y5D9
12	Y260 ~ Y27F	26	Y420 ~ Y43F	40	Y5E0 ~ Y5F9
13	Y280 ~ Y29F	27	Y440 ~ Y45F	41	Y600 ~ Y61F
14	Y2A0 ~ Y2B9	28	Y460 ~ Y47F	42	Y620 ~ Y63F


Device No. is determined to "Y100~Y63F" if refresh device of remote output (RY) is set to "Y100".

7.2 Remote Register (RWr, RWw)

The remote register RWr and RWw are used to communicate word data between the master station and Measuring Unit. Because it occupies 1 station, the remote registers RWr and RWw each have 4 words in length.

Measuring Unit has the special-purpose commands for each measurement items and setting items. It becomes possible to monitor each measurement values or set each parameters by writing into the remote register RWw of the master station command and the related data allocated to the item you want to monitor or set.


- (1) Relationships between programmable controller CPU, master module and Measuring Unit(RWr)
 - 1) The remote register RWr data of a remote device station is automatically stored in the "remote register RWr" buffer memory of the master station.
 - 2) The remote register RWr data of Measuring Unit stored in the "remote register RWr" buffer memory is stored in the CPU device set with the automatic refresh parameters.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	W300 ~ W303	15	W338 ~ W33B	29	W370 ~ W373
2	W304 ~ W307	16	W33C ~ W33F	30	W374 ~ W377
3	W308 ~ W30B	17	W340 ~ W343	31	W378 ~ W37B
4	W30C ~ W30F	18	W344 ~ W347	32	W37C ~ W37F
5	W310 ~ W313	19	W348 ~ W34B	33	W380 ~ W383
6	W314 ~ W317	20	W34C ~ W34F	34	W384 ~ W387
7	W318 ~ W31B	21	W350 ~ W353	35	W388 ~ W38B
8	W31C ~ W31F	22	W354 ~ W357	36	W38C ~ W38F
9	W320 ~ W323	23	W358 ~ W35B	37	W390 ~ W393
10	W324 ~ W327	24	W35C ~ W35F	38	W394 ~ W397
11	W328 ~ W32B	25	W360 ~ W363	39	W398 ~ W39B
12	W32C ~ W32F	26	W364 ~ W367	40	W39C ~ W39F
13	W330 ~ W333	27	W368 ~ W36B	41	W3A0 ~ W3A3
14	W334 ~ W337	28	W36C ~ W36F	42	W3A4 ~ W3A7

Device No. is determined to "W300~W3A7" if refresh device of remote register (RWr) is set to "W300".

- (2) Relationships between programmable controller CPU, master module and Measuring Unit(RWw)
- 1) The transmission data of the CPU device set with the automatic refresh parameters is stored in the "remote register RWw" buffer memory.
 - 2) The data stored in the "remote register RWw" buffer memory is automatically sent to the remote register RWw of each remote device station.



Station number	Device No.	Station number	Device No.	Station number	Device No.
1	W400 ~ W403	15	W438 ~ W43B	29	W470 ~ W473
2	W404 ~ W407	16	W43C ~ W43F	30	W474 ~ W477
3	W408 ~ W40B	17	W440 ~ W443	31	W478 ~ W47B
4	W40C ~ W40F	18	W444 ~ W447	32	W47C ~ W47F
5	W410 ~ W413	19	W448 ~ W44B	33	W480 ~ W483
6	W414 ~ W417	20	W44C ~ W44F	34	W484 ~ W487
7	W418 ~ W41B	21	W450 ~ W453	35	W488 ~ W48B
8	W41C ~ W41F	22	W454 ~ W457	36	W48C ~ W48F
9	W420 ~ W423	23	W458 ~ W45B	37	W490 ~ W493
10	W424 ~ W427	24	W45C ~ W45F	38	W494 ~ W497
11	W428 ~ W42B	25	W460 ~ W463	39	W498 ~ W49B
12	W42C ~ W42F	26	W464 ~ W467	40	W49C ~ W49F
13	W430 ~ W433	27	W468 ~ W46B	41	W4A0 ~ W4A3
14	W434 ~ W437	28	W46C ~ W46F	42	W4A4 ~ W4A7

Device No. is determined to "W400~W4A7" if refresh device of remote register (RWw) is set to "W400".

7.2.1 Supported Command

The commands supported by Measuring Unit are listed in the table below. For the details of each commands, refer to “7.2.2 Details of Commands”.

(1) Command

Table 7.1 Suppoted Commands

Command	Name	Description	Note	page
1H	Data Monitor	For monitoring measurement		25
2H	Data Set	For setting measurement		32

Note) 1: The command can be sent only when the remote READY is ON.

2: The command execution request flag and command completion reply flag are used to send the command and receive replay data. For details of each flag, refer to “6.4 Normal Communication”.

3: In case of monitoring the present value and its maximum continuously according to the renewal data timing of Measuring Unit, the maximum may be smaller than the present value.

7.2.2 Details of Commands

The details of the command and reply data supported by Measuring Unit are described here.


(1) Data Monitor Command (1H)

1H	Data Monitor																																																												
<ul style="list-style-type: none"> The measurement items are assigned "Unit No.", "Group No." and "Channel No.". (Refer to Table 7.2.) After writing the command as shown below into the remote register RWw, set the command execution request flag to ON(1). When the command completion reply flag is turned on, the item specified is reset. The details of the data format are shown in the Data Composition Table 7.4 to Table 7.10. The monitoring item is changed with the setting of phase wire system. (Refer to Table 7.3.) 																																																													
Remote register RWw (PLC→Measuring Unit)		Remote register RWr (Measuring Unit→PLC)																																																											
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>b15</th> <th>b8</th> <th>b7</th> <th>b4</th> <th>b3</th> <th>b0</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">m</td> <td>Group No.</td> <td></td> <td>Unit No. *1</td> <td></td> <td></td> <td>1H</td> </tr> <tr> <td style="text-align: center;">m+1</td> <td>00H</td> <td></td> <td>Channel No.</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">m+2</td> <td>00H</td> <td></td> <td>00H</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align: center;">m+3</td> <td>00H</td> <td></td> <td>00H</td> <td></td> <td></td> <td></td> </tr> </tbody> </table> <p>(*1) 1H is used in the unit No. of Measuring Unit</p>		b15	b8	b7	b4	b3	b0	m	Group No.		Unit No. *1			1H	m+1	00H		Channel No.				m+2	00H		00H				m+3	00H		00H				<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>b15</th> <th>b8</th> <th>b7</th> <th>b0</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">n</td> <td>Channel No.</td> <td></td> <td>Group No.</td> <td></td> </tr> <tr> <td style="text-align: center;">n+1</td> <td>Index number</td> <td></td> <td>00H</td> <td></td> </tr> <tr> <td style="text-align: center;">n+2</td> <td></td> <td></td> <td>Low data</td> <td></td> </tr> <tr> <td style="text-align: center;">n+3</td> <td></td> <td></td> <td>High data</td> <td></td> </tr> </tbody> </table>		b15	b8	b7	b0	n	Channel No.		Group No.		n+1	Index number		00H		n+2			Low data		n+3			High data	
	b15	b8	b7	b4	b3	b0																																																							
m	Group No.		Unit No. *1			1H																																																							
m+1	00H		Channel No.																																																										
m+2	00H		00H																																																										
m+3	00H		00H																																																										
	b15	b8	b7	b0																																																									
n	Channel No.		Group No.																																																										
n+1	Index number		00H																																																										
n+2			Low data																																																										
n+3			High data																																																										

m, n : Address is allocated to the master module by the station number setting.

Note: Measuring Unit can monitor the value of the measurement items which are not displayed.

*1: It is described as 8 bits data by combining the unit No. (high 4 bits) and the command (low 4 bits).



For example, When the unit No. is 1H and the command is 1H, it becomes "11H".

Table 7.2 Group Channel List for Data Monitor Command (1H) (1/5)

Group (H)	Channel (H)	Note	Data type	Content name				EMU4-FD1-MB	Data format
F0	02		Set-up	Model code				O	(5)
E0	11			Primary current	A			O	(4)
E0	12			Primary voltage (L-L)	V			O	
E0	1B	*2		Primary voltage (L-N)	V			O	
E0	1C			Secondary voltage (L-L/L-N)	V			O	
E0	13			Phase & Wiring				O	(5)
02	E0			Time constant for DA	sec			O	
08	E0			Time constant for DW	sec			O	
E0	1E			Secondary current				O	
01	01		Measurement	Average current	A	Inst.		O	(1)
01	21			Phase 1 current	A	Inst.		O	
01	41	*1		Phase 2 current	A	Inst.		O	
01	61	*1		Phase 3 current	A	Inst.		O	
01	81	*2		Phase N current	A	Inst.		O	
02	21			Phase 1 current demand	A	Inst.		O	
02	41	*1		Phase 2 current demand	A	Inst.		O	
02	61	*1		Phase 3 current demand	A	Inst.		O	
02	81	*2		Phase N current demand	A	Inst.		O	
03	21	*2	Measurement	1-N voltage	V	Inst.		O	(1)
03	41	*2		2-N voltage	V	Inst.		O	
03	61	*2		3-N voltage	V	Inst.		O	
05	01			Average L-L voltage	V	Inst.		O	
05	21			1-2 voltage	V	Inst.		O	
05	41	*1		2-3 voltage	V	Inst.		O	
05	61	*1		3-1 voltage	V	Inst.		O	
07	01			Active power	kW	Inst.	Total	O	
08	01			Active power demand	kW	Inst.	Total	O	
09	01			Reactive power	kvar	Inst.	Total	O	
0B	01	*2		Apparent power	kVA	Inst.	Total	O	
0D	01			Power factor	%	Inst.	Total	O	
0F	01			Frequency	Hz	Inst.		O	

Inst.: Instantaneous value. Max.: Maximum value. Min.: Minimum value. RMS.: Root-Mean-Square value.

Note: Measurement data correspond as follows according to setting of phase wiring. (Maximum / Minimum data and harmonic data are same.)

Name of channel	Phase wiring			
	3P3W	1P3W(1N3)	1P3W(1N2)	1P2W
1-2 voltage	1-2 voltage	1-N voltage	1-N voltage	Voltage
2-3 voltage	2-3 voltage	2-N voltage	2-N voltage	-
3-1 voltage	3-1 voltage	1-3 voltage	1-3 voltage	-
Phase 1 current	Phase 1 current	Phase 1 current	Phase 1 current	Current
Phase 2 current	Phase 2 current	Phase N current	Phase N current	-
Phase 3 current	Phase 3 current	Phase 3 current	Phase 2 current	-

Table 7.2 Group Channel List for Data Monitor Command (1H) (2/5)

Group (H)	Channel (H)	Note	Data type	Content name				EMU4-FD1-MB	Data format
63	21	*3	Measurement	1-2 harmonic voltage	V	RMS.	Total	O	①
4D	21	*3		1-2 harmonic voltage	V	RMS.	1st	O	
4F	21	*3		1-2 harmonic voltage	V	RMS.	3rd	O	
51	21	*3		1-2 harmonic voltage	V	RMS.	5th	O	
53	21	*3		1-2 harmonic voltage	V	RMS.	7th	O	
55	21	*3		1-2 harmonic voltage	V	RMS.	9th	O	
57	21	*3		1-2 harmonic voltage	V	RMS.	11th	O	
59	21	*3		1-2 harmonic voltage	V	RMS.	13th	O	
5B	21	*3		1-2 harmonic voltage	V	RMS.	15th	O	
76	86	*3	Measurement	1-2 voltage THD	%	Inst.	Total	O	①
76	73	*3		1-2 voltage harmonic distortion	%	Inst.	3rd	O	
76	75	*3		1-2 voltage harmonic distortion	%	Inst.	5th	O	
76	77	*3		1-2 voltage harmonic distortion	%	Inst.	7th	O	
76	79	*3		1-2 voltage harmonic distortion	%	Inst.	9th	O	
76	7B	*3		1-2 voltage harmonic distortion	%	Inst.	11th	O	
76	7D	*3		1-2 voltage harmonic distortion	%	Inst.	13th	O	
76	7F	*3		1-2 voltage harmonic distortion	%	Inst.	15th	O	
63	41	*1 *3	Measurement	2-3 harmonic voltage	V	RMS.	Total	O	①
4D	41	*1 *3		2-3 harmonic voltage	V	RMS.	1st	O	
4F	41	*1 *3		2-3 harmonic voltage	V	RMS.	3rd	O	
51	41	*1 *3		2-3 harmonic voltage	V	RMS.	5th	O	
53	41	*1 *3		2-3 harmonic voltage	V	RMS.	7th	O	
55	41	*1 *3		2-3 harmonic voltage	V	RMS.	9th	O	
57	41	*1 *3		2-3 harmonic voltage	V	RMS.	11th	O	
59	41	*1 *3		2-3 harmonic voltage	V	RMS.	13th	O	
5B	41	*1 *3		2-3 harmonic voltage	V	RMS.	15th	O	
76	9C	*1 *3	Measurement	2-3 voltage THD	%	Inst.	Total	O	①
76	89	*1 *3		2-3 voltage harmonic distortion	%	Inst.	3rd	O	
76	8B	*1 *3		2-3 voltage harmonic distortion	%	Inst.	5th	O	
76	8D	*1 *3		2-3 voltage harmonic distortion	%	Inst.	7th	O	
76	8F	*1 *3		2-3 voltage harmonic distortion	%	Inst.	9th	O	
76	91	*1 *3		2-3 voltage harmonic distortion	%	Inst.	11th	O	
76	93	*1 *3		2-3 voltage harmonic distortion	%	Inst.	13th	O	
76	95	*1 *3		2-3 voltage harmonic distortion	%	Inst.	15th	O	

Inst.: Instantaneous value. Max.: Maximum value. Min.: Minimum value. RMS.: Root-Mean-Square value.

Table 7.2 Group Channel List for Data Monitor Command (1H) (3/5)

Group (H)	Channel (H)	Note	Data type	Content name				EMU4-FD1-MB	Data format
4B	21	*2	Measurement	1-N harmonic voltage	V	RMS.	Total	O	①
35	21	*2		1-N harmonic voltage	V	RMS.	1st	O	
37	21	*2		1-N harmonic voltage	V	RMS.	3rd	O	
39	21	*2		1-N harmonic voltage	V	RMS.	5th	O	
3B	21	*2		1-N harmonic voltage	V	RMS.	7th	O	
3D	21	*2		1-N harmonic voltage	V	RMS.	9th	O	
3F	21	*2		1-N harmonic voltage	V	RMS.	11th	O	
41	21	*2		1-N harmonic voltage	V	RMS.	13th	O	
43	21	*2		1-N harmonic voltage	V	RMS.	15th	O	
77	86	*2		1-N voltage THD	%	Inst.	Total	O	
77	73	*2	Measurement	1-N voltage harmonic distortion	%	Inst.	3rd	O	①
77	75	*2		1-N voltage harmonic distortion	%	Inst.	5th	O	
77	77	*2		1-N voltage harmonic distortion	%	Inst.	7th	O	
77	79	*2		1-N voltage harmonic distortion	%	Inst.	9th	O	
77	7B	*2		1-N voltage harmonic distortion	%	Inst.	11th	O	
77	7D	*2		1-N voltage harmonic distortion	%	Inst.	13th	O	
77	7F	*2		1-N voltage harmonic distortion	%	Inst.	15th	O	
4B	41	*2		2-N harmonic voltage	V	RMS.	Total	O	①
35	41	*2		2-N harmonic voltage	V	RMS.	1st	O	
37	41	*2		2-N harmonic voltage	V	RMS.	3rd	O	
39	41	*2		2-N harmonic voltage	V	RMS.	5th	O	
3B	41	*2		2-N harmonic voltage	V	RMS.	7th	O	
3D	41	*2		2-N harmonic voltage	V	RMS.	9th	O	
3F	41	*2		2-N harmonic voltage	V	RMS.	11th	O	
41	41	*2		2-N harmonic voltage	V	RMS.	13th	O	
43	41	*2		2-N harmonic voltage	V	RMS.	15th	O	
77	9C	*2	Measurement	2-N voltage THD	%	Inst.	Total	O	①
77	89	*2		2-N voltage harmonic distortion	%	Inst.	3rd	O	
77	8B	*2		2-N voltage harmonic distortion	%	Inst.	5th	O	
77	8D	*2		2-N voltage harmonic distortion	%	Inst.	7th	O	
77	8F	*2		2-N voltage harmonic distortion	%	Inst.	9th	O	
77	91	*2		2-N voltage harmonic distortion	%	Inst.	11th	O	
77	93	*2		2-N voltage harmonic distortion	%	Inst.	13th	O	
77	95	*2		2-N voltage harmonic distortion	%	Inst.	15th	O	
4B	61	*2	Measurement	3-N harmonic voltage	V	RMS.	Total	O	①
35	61	*2		3-N harmonic voltage	V	RMS.	1st	O	
37	61	*2		3-N harmonic voltage	V	RMS.	3rd	O	
39	61	*2		3-N harmonic voltage	V	RMS.	5th	O	
3B	61	*2		3-N harmonic voltage	V	RMS.	7th	O	
3D	61	*2		3-N harmonic voltage	V	RMS.	9th	O	
3F	61	*2		3-N harmonic voltage	V	RMS.	11th	O	
41	61	*2		3-N harmonic voltage	V	RMS.	13th	O	
43	61	*2		3-N harmonic voltage	V	RMS.	15th	O	

Inst.: Instantaneous value. Max.: Maximum value. Min.: Minimum value. RMS.: Root-Mean-Square value.

Table 7.2 Group Channel List for Data Monitor Command (1H) (4/5)

Group (H)	Channel (H)	Note	Data type	Content name				EMU4-FD1-MB	Data format
77	B2	*2	Measurement	3-N voltage THD	%	Inst.	Total	○	①
77	9F	*2		3-N voltage harmonic distortion	%	Inst.	3rd	○	
77	A1	*2		3-N voltage harmonic distortion	%	Inst.	5th	○	
77	A3	*2		3-N voltage harmonic distortion	%	Inst.	7th	○	
77	A5	*2		3-N voltage harmonic distortion	%	Inst.	9th	○	
77	A7	*2		3-N voltage harmonic distortion	%	Inst.	11th	○	
77	A9	*2		3-N voltage harmonic distortion	%	Inst.	13th	○	
77	AB	*2		3-N voltage harmonic distortion	%	Inst.	15th	○	
33	21		Measurement	Phase 1 harmonic current	A	RMS.	Total	○	①
1D	21			Phase 1 harmonic current	A	RMS.	1st	○	
1F	21			Phase 1 harmonic current	A	RMS.	3rd	○	
21	21			Phase 1 harmonic current	A	RMS.	5th	○	
23	21			Phase 1 harmonic current	A	RMS.	7th	○	
25	21			Phase 1 harmonic current	A	RMS.	9th	○	
27	21			Phase 1 harmonic current	A	RMS.	11th	○	
29	21			Phase 1 harmonic current	A	RMS.	13th	○	
2B	21			Phase 1 harmonic current	A	RMS.	15th	○	
75	86		Measurement	Phase 1 current THD	%	Inst.	Total	○	①
75	73			Phase 1 current harmonic distortion	%	Inst.	3rd	○	
75	75			Phase 1 current harmonic distortion	%	Inst.	5th	○	
75	77			Phase 1 current harmonic distortion	%	Inst.	7th	○	
75	79			Phase 1 current harmonic distortion	%	Inst.	9th	○	
75	7B			Phase 1 current harmonic distortion	%	Inst.	11th	○	
75	7D			Phase 1 current harmonic distortion	%	Inst.	13th	○	
75	7F			Phase 1 current harmonic distortion	%	Inst.	15th	○	
33	41	*2	Measurement	Phase 2 harmonic current	A	RMS.	Total	○	①
1D	41	*2		Phase 2 harmonic current	A	RMS.	1st	○	
1F	41	*2		Phase 2 harmonic current	A	RMS.	3rd	○	
21	41	*2		Phase 2 harmonic current	A	RMS.	5th	○	
23	41	*2		Phase 2 harmonic current	A	RMS.	7th	○	
25	41	*2		Phase 2 harmonic current	A	RMS.	9th	○	
27	41	*2		Phase 2 harmonic current	A	RMS.	11th	○	
29	41	*2		Phase 2 harmonic current	A	RMS.	13th	○	
2B	41	*2		Phase 2 harmonic current	A	RMS.	15th	○	
75	9C	*2	Measurement	Phase 2 current THD	%	Inst.	Total	○	①
75	89	*2		Phase 2 current harmonic distortion	%	Inst.	3rd	○	
75	8B	*2		Phase 2 current harmonic distortion	%	Inst.	5th	○	
75	8D	*2		Phase 2 current harmonic distortion	%	Inst.	7th	○	
75	8F	*2		Phase 2 current harmonic distortion	%	Inst.	9th	○	
75	91	*2		Phase 2 current harmonic distortion	%	Inst.	11th	○	
75	93	*2		Phase 2 current harmonic distortion	%	Inst.	13th	○	
75	95	*2		Phase 2 current harmonic distortion	%	Inst.	15th	○	
33	61	*1	Measurement	Phase 3 harmonic current	A	RMS.	Total	○	①
1D	61	*1		Phase 3 harmonic current	A	RMS.	1st	○	
1F	61	*1		Phase 3 harmonic current	A	RMS.	3rd	○	
21	61	*1		Phase 3 harmonic current	A	RMS.	5th	○	
23	61	*1		Phase 3 harmonic current	A	RMS.	7th	○	
25	61	*1		Phase 3 harmonic current	A	RMS.	9th	○	
27	61	*1		Phase 3 harmonic current	A	RMS.	11th	○	
29	61	*1		Phase 3 harmonic current	A	RMS.	13th	○	
2B	61	*1		Phase 3 harmonic current	A	RMS.	15th	○	

Inst.: Instantaneous value. Max.: Maximum value. Min.: Minimum value. RMS.: Root-Mean-Square value.

Table 7.2 Group Channel List for Data Monitor Command (1H) (5/5)

Group (H)	Channel (H)	Note	Data type	Content name				EMU4-FD1-MB	Data format
75	B2	*1	Measurement	Phase 3 current THD	%	Inst.	Total	○	①
75	9F	*1		Phase 3 current harmonic distortion	%	Inst.	3rd	○	
75	A1	*1		Phase 3 current harmonic distortion	%	Inst.	5th	○	
75	A3	*1		Phase 3 current harmonic distortion	%	Inst.	7th	○	
75	A5	*1		Phase 3 current harmonic distortion	%	Inst.	9th	○	
75	A7	*1		Phase 3 current harmonic distortion	%	Inst.	11th	○	
75	A9	*1		Phase 3 current harmonic distortion	%	Inst.	13th	○	
75	AB	*1		Phase 3 current harmonic distortion	%	Inst.	15th	○	
33	81	*2		Phase N harmonic current	A	RMS.	Total	○	
1D	81	*2	Measurement	Phase N harmonic current	A	RMS.	1st	○	①
1F	81	*2		Phase N harmonic current	A	RMS.	3rd	○	
21	81	*2		Phase N harmonic current	A	RMS.	5th	○	
23	81	*2		Phase N harmonic current	A	RMS.	7th	○	
25	81	*2		Phase N harmonic current	A	RMS.	9th	○	
27	81	*2		Phase N harmonic current	A	RMS.	11th	○	
29	81	*2		Phase N harmonic current	A	RMS.	13th	○	
2B	81	*2		Phase N harmonic current	A	RMS.	15th	○	
75	C8	*2	Measurement	Phase N current THD	%	Inst.	Total	○	①
75	B5	*2		Phase N current harmonic distortion	%	Inst.	3rd	○	
75	B7	*2		Phase N current harmonic distortion	%	Inst.	5th	○	
75	B9	*2		Phase N current harmonic distortion	%	Inst.	7th	○	
75	BB	*2		Phase N current harmonic distortion	%	Inst.	9th	○	
75	BD	*2		Phase N current harmonic distortion	%	Inst.	11th	○	
75	BF	*2		Phase N current harmonic distortion	%	Inst.	13th	○	
75	C1	*2		Phase N current harmonic distortion	%	Inst.	15th	○	
80	01		Measurement	Active energy (import)	kWh	count		○	②
80	63			Active energy (export)	kWh	count		○	
81	01			Reactive energy (import lag)	kvar	count		○	
80	64			Active energy (import)	kWh	count	expand	○	
80	65			Active energy (export)	kWh	count	expand	○	
81	66			Reactive energy (import lag)	kvar	count	expand	○	
83	01			Pulse count 1	pulse	count		○	
87	01			Operating time 1	min	count		○	
8B	01			Active energy during operation 1	kWh	count		○	
A0	31		Alarm state	Alarm state		Alarm		○	③

Inst.: Instantaneous value. Max.: Maximum value. Min.: Minimum value. RMS.: Root-Mean-Square value.

Note

*1: If phase wire system is set to single-phase 2-wire, Out-of-range error occurs.

*2: If phase wire system is set to except three-phase 4-wire, Out-of-range error occurs.

*3: If phase wire system is set to three-phase 4-wire, Out-of-range error occurs.

(2) Data Monitor Command (2H)

2H	Data Set																																																													
<ul style="list-style-type: none"> • You can change setting value of measuring unit by PLC. • Writing the number of Group number and Channel number of data to the memory. • Please refer to Table 7.3 for data group number and data channel number. 																																																														
<p>*After writing the set-up value, about 5 seconds is needed to restart the measurement based on new set-up value.</p>																																																														
Remote register RWw (PLC→Measuring Unit)		Remote register RWr (Measuring Unit→PLC)																																																												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>b15</th> <th>b8</th> <th>b7</th> <th>b4</th> <th>b3</th> <th>b0</th> </tr> </thead> <tbody> <tr> <td>m</td> <td>Group No.</td> <td>(Unit.No. *1)</td> <td></td> <td></td> <td></td> <td>2H</td> </tr> <tr> <td>m+1</td> <td>Index number</td> <td colspan="2">Channel No.</td> <td></td> <td></td> <td></td> </tr> <tr> <td>m+2</td> <td colspan="2">Low data</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>m+3</td> <td colspan="2">High data</td> <td></td> <td></td> <td></td> <td></td> </tr> </tbody> </table>			b15	b8	b7	b4	b3	b0	m	Group No.	(Unit.No. *1)				2H	m+1	Index number	Channel No.					m+2	Low data						m+3	High data						<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>b15</th> <th>b8</th> <th>b7</th> <th>b0</th> </tr> </thead> <tbody> <tr> <td>n</td> <td>Channel No.</td> <td colspan="2">Group No.</td> <td></td> </tr> <tr> <td>n+1</td> <td>00H</td> <td colspan="2">00H</td> <td></td> </tr> <tr> <td>n+2</td> <td>00H</td> <td colspan="2">00H</td> <td></td> </tr> <tr> <td>n+3</td> <td>00H</td> <td colspan="2">00H</td> <td></td> </tr> </tbody> </table>		b15	b8	b7	b0	n	Channel No.	Group No.			n+1	00H	00H			n+2	00H	00H			n+3	00H	00H		
	b15	b8	b7	b4	b3	b0																																																								
m	Group No.	(Unit.No. *1)				2H																																																								
m+1	Index number	Channel No.																																																												
m+2	Low data																																																													
m+3	High data																																																													
	b15	b8	b7	b0																																																										
n	Channel No.	Group No.																																																												
n+1	00H	00H																																																												
n+2	00H	00H																																																												
n+3	00H	00H																																																												
<p>(*1) 1H is used in the unit No. of Measuring Unit</p>																																																														

m, n : Address is allocated to the master module by the station number setting.

Table 7.3 Group Channel List for Data Set Command (2H)

Hex		Content name	EMU4-FD1-MB		Data format
Group	Channel		Range	Setting unit	
E0	11	Primary current	1.0A to 6000.0A	(Note1)	(4)
E0	12	Primary voltage (L-L)	1V to 6600V	(Note2)	(4)
E0	1B	Primary voltage (L-N)	1V to 6600V (EMU4-FD1-MB 3P4W only)	(Note3)	(4)
E0	1C	Secondary voltage (L-L/L-N)	1V to 220V	Step 1V	(4)
E0	13	Phase Wire system	01H: 1P2W 02H: 1P3W 03H: 3P3W 04H: 3P4W (EMU4-FD1-MB only)	—	(5)
02	E0	Time constant for DA	0 to 1800s	(Note4)	(5)
08	E0	Time constant for DW	0 to 1800s	(Note4)	(5)
80	01	Active energy (import)	0 to 999999xMultiplicand (Note5)	Step 1xMultiplicand	(2)
80	63	Active energy (export)	0 to 999999xMultiplicand (Note5)	Step 1xMultiplicand	(2)
81	01	Reactive energy (import lag)	0 to 999999xMultiplicand (Note5)	Step 1xMultiplicand	(2)
A1	3A	16bit set register	Refer to Table 7.8 Data Format (5/6)	—	(5)

Note 1: From the most significant digit to 3 digits can be freely setting in the range from 100.0A to 6000.0A.

Note 2: Effective value of primary voltage(L-L) is follows.

3P3W or 1P2W :

From the most significant digit to 3 digits can be freely setting in the range from 1000V to 6600V.

When setup 110V, 220V or 440V, Setup is Direct setup(Not use VT) in EMU4-FD1-MB.

1P3W :

110V is valid only.

3P4W :

From the most significant digit to 3 digits can be freely setting in the range from 1000V to 6600V.

Set value	Direct voltage	Set value	Direct voltage
110V	63.5/110V	380V	220/380V
173V	100/173V	400V	230/400V
182V	105/182V	415V	240/415V
190V	110/190V	420V	242/420V
199V	115/199V	430V	250/430V
208V	120/208V	440V	254/440V
220V	127/220V	460V	265/460V
346V	200/346V	480V	277/480V

*From the most significant digit to 3 figures can be freely set up in the range.

Note 3 : Setup of phase voltage is only available in 3P4W.

From the most significant digit to 3 digits can be freely setting in the range from 1000V to 6600V..

Setup is Direct setup(Not use VT) when setup in below value.

Set value	Direct voltage
63.5V	63.5/110V
100V	100/173V
105V	105/182V
110V	110/190V
115V	115/199V
120V	120/208V
127V	127/220V
200V	200/346V
220V	220V/380V
230V	230/400V
240V	240/415V
242V	242/420V
250V	250/430V
254V	254/440V
265V	265/460V
277V	277/480V

Note 4 : The set value is the second unit value. (For example of 2 minutes, set as 120 seconds.) About setting range, please refer to each user's manuals.

Note 5 : Multiplicand fixed for each items according to phase wire system, primary voltage and primary current.(For details, refer to 7.2.4 Significant digits and Multiplying factor)

7.2.3 Data Composition

Table 7.4 Data Format (1/6)

Data	Data Format ①																										
Measurement																											
Current, Voltage, Active power, Reactive power, Power factor, Frequency, etc.																											
Format①																											
<p>Multiplicand</p> <p>Numerical value</p> <p>b15 b8 b7 b0</p> <p>Index number</p> <p>Low data</p> <p>High data</p> <p>b31 b24 b23 b16 b15 b8 b7 b0</p> <p>Numerical value: 32-bit integer with a sign $-2147483648 \sim 2147483647$ $(80000000H \sim 7FFFFFFFH)$</p>																											
<p><Multiplicand></p> <p>Multiplicand is fixed for every item according to settings of primary current, primary voltage, and phase wiring. (Refer to P44.)</p> <table border="1"> <thead> <tr> <th>Index number</th> <th>Multiplicand</th> <th>Remarks</th> </tr> </thead> <tbody> <tr> <td>03H</td> <td>$\times 10^3$</td> <td rowspan="8">Actual value = Numerical value \times Multiplicand</td> </tr> <tr> <td>02H</td> <td>$\times 10^2$</td> </tr> <tr> <td>01H</td> <td>$\times 10$</td> </tr> <tr> <td>00H</td> <td>$\times 1$</td> </tr> <tr> <td>FFH</td> <td>$\times 10^{-1}$</td> </tr> <tr> <td>FEH</td> <td>$\times 10^{-2}$</td> </tr> <tr> <td>FDH</td> <td>$\times 10^{-3}$</td> </tr> </tbody> </table>								Index number	Multiplicand	Remarks	03H	$\times 10^3$	Actual value = Numerical value \times Multiplicand	02H	$\times 10^2$	01H	$\times 10$	00H	$\times 1$	FFH	$\times 10^{-1}$	FEH	$\times 10^{-2}$	FDH	$\times 10^{-3}$		
Index number	Multiplicand	Remarks																									
03H	$\times 10^3$	Actual value = Numerical value \times Multiplicand																									
02H	$\times 10^2$																										
01H	$\times 10$																										
00H	$\times 1$																										
FFH	$\times 10^{-1}$																										
FEH	$\times 10^{-2}$																										
FDH	$\times 10^{-3}$																										
<p><Example: Active power></p> <table border="1"> <thead> <tr> <th>Data</th> <th>Multiplicand</th> <th>Numerical value</th> <th>Actual value</th> </tr> </thead> <tbody> <tr> <td>FF000000FFH</td> <td>FFH $\Rightarrow 10^{-1}$</td> <td>000000FFH $\Rightarrow 255$</td> <td>$255 \times 10^{-1} = 25.5[\text{kW}]$</td> </tr> <tr> <td>00000000FFH</td> <td>00H $\Rightarrow 1$</td> <td>000000FFH $\Rightarrow 255$</td> <td>$255 \times 1 = 255[\text{kW}]$</td> </tr> <tr> <td>FFFFFFFF01H</td> <td>FFH $\Rightarrow 10^{-1}$</td> <td>FFFFFFFFFF01H $\Rightarrow -255$</td> <td>$-255 \times 10^{-1} = -25.5[\text{kW}]$</td> </tr> <tr> <td>00FFFFFF01H</td> <td>00H $\Rightarrow 1$</td> <td>FFFFFF01H $\Rightarrow -255$</td> <td>$-255 \times 1 = -255[\text{kW}]$</td> </tr> </tbody> </table>								Data	Multiplicand	Numerical value	Actual value	FF000000FFH	FFH $\Rightarrow 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kW}]$	00000000FFH	00H $\Rightarrow 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kW}]$	FFFFFFFF01H	FFH $\Rightarrow 10^{-1}$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 10^{-1} = -25.5[\text{kW}]$	00FFFFFF01H	00H $\Rightarrow 1$	FFFFFF01H $\Rightarrow -255$	$-255 \times 1 = -255[\text{kW}]$
Data	Multiplicand	Numerical value	Actual value																								
FF000000FFH	FFH $\Rightarrow 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kW}]$																								
00000000FFH	00H $\Rightarrow 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kW}]$																								
FFFFFFFF01H	FFH $\Rightarrow 10^{-1}$	FFFFFFFFFF01H $\Rightarrow -255$	$-255 \times 10^{-1} = -25.5[\text{kW}]$																								
00FFFFFF01H	00H $\Rightarrow 1$	FFFFFF01H $\Rightarrow -255$	$-255 \times 1 = -255[\text{kW}]$																								

Table 7.5 Data Format (2/6)

Data	Data Format ②																																					
Measurement Active energy Reactive energy Operating time Active energy during operation 1 Format②	<p style="text-align: center;">Numerical value: 32-bit integer with a sign However, the effective numerical value is 0~999999 (0H~F423FH)</p> <p><Multiplicand></p> <p>Multiplicand is fixed for every item according to settings of primary current, primary voltage, and phase wiring. (Refer to 7.2.4 Significant digits and Multiplying factor)</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Index number</th> <th style="text-align: center;">Multiplicand</th> <th style="text-align: center;">Remarks</th> </tr> </thead> <tbody> <tr><td style="text-align: center;">04H</td><td style="text-align: center;">$\times 10^4$</td><td rowspan="10" style="vertical-align: middle; padding-left: 10px;">Actual value = Numerical value \times Multiplicand</td></tr> <tr><td style="text-align: center;">03H</td><td style="text-align: center;">$\times 10^3$</td></tr> <tr><td style="text-align: center;">02H</td><td style="text-align: center;">$\times 10^2$</td></tr> <tr><td style="text-align: center;">01H</td><td style="text-align: center;">$\times 10$</td></tr> <tr><td style="text-align: center;">00H</td><td style="text-align: center;">$\times 1$</td></tr> <tr><td style="text-align: center;">FFH</td><td style="text-align: center;">$\times 10^{-1}$</td></tr> <tr><td style="text-align: center;">FEH</td><td style="text-align: center;">$\times 10^{-2}$</td></tr> <tr><td style="text-align: center;">FDH</td><td style="text-align: center;">$\times 10^{-3}$</td></tr> <tr><td style="text-align: center;">FCH</td><td style="text-align: center;">$\times 10^{-4}$</td></tr> <tr><td style="text-align: center;">FBH</td><td style="text-align: center;">$\times 10^{-5}$</td></tr> </tbody> </table> <p><Example: Active Energy></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Data</th> <th style="text-align: center;">Multiplicand</th> <th style="text-align: center;">Numeric value</th> <th style="text-align: center;">Actual value</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">FF000000FFH</td> <td style="text-align: center;">FFH $\Rightarrow 10^{-1}$</td> <td style="text-align: center;">000000FFH $\Rightarrow 255$</td> <td style="text-align: center;">$255 \times 10^{-1} = 25.5[\text{kWh}]$</td> </tr> <tr> <td style="text-align: center;">00000000FFH</td> <td style="text-align: center;">00H $\Rightarrow 1$</td> <td style="text-align: center;">000000FFH $\Rightarrow 255$</td> <td style="text-align: center;">$255 \times 1 = 255[\text{kWh}]$</td> </tr> </tbody> </table>		Index number	Multiplicand	Remarks	04H	$\times 10^4$	Actual value = Numerical value \times Multiplicand	03H	$\times 10^3$	02H	$\times 10^2$	01H	$\times 10$	00H	$\times 1$	FFH	$\times 10^{-1}$	FEH	$\times 10^{-2}$	FDH	$\times 10^{-3}$	FCH	$\times 10^{-4}$	FBH	$\times 10^{-5}$	Data	Multiplicand	Numeric value	Actual value	FF000000FFH	FFH $\Rightarrow 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kWh}]$	00000000FFH	00H $\Rightarrow 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kWh}]$
Index number	Multiplicand	Remarks																																				
04H	$\times 10^4$	Actual value = Numerical value \times Multiplicand																																				
03H	$\times 10^3$																																					
02H	$\times 10^2$																																					
01H	$\times 10$																																					
00H	$\times 1$																																					
FFH	$\times 10^{-1}$																																					
FEH	$\times 10^{-2}$																																					
FDH	$\times 10^{-3}$																																					
FCH	$\times 10^{-4}$																																					
FBH	$\times 10^{-5}$																																					
Data	Multiplicand	Numeric value	Actual value																																			
FF000000FFH	FFH $\Rightarrow 10^{-1}$	000000FFH $\Rightarrow 255$	$255 \times 10^{-1} = 25.5[\text{kWh}]$																																			
00000000FFH	00H $\Rightarrow 1$	000000FFH $\Rightarrow 255$	$255 \times 1 = 255[\text{kWh}]$																																			

Table 7.6 Data Format (3/6)

Data	Data Format ③
Alarm state	<p>Format③</p> <pre> graph TD subgraph DF3 [Data Format ③] direction TB A[00H(fixed)] --> B[Index number] B --> C[Low data] C --> D[High data] D --> E[High data] E --> F[Low data] end subgraph AS [Alarm state] direction LR G[High data] --- H[b15 b8] I[Low data] --- J[b7 b0] H --- I end </pre> <p>00H(fixed)</p> <p>b15 b8 b7 b0</p> <p>Index number</p> <p>Low data</p> <p>High data</p> <p>High data</p> <p>Low data</p> <p>b15 b8 b7 b0</p> <p>High data</p> <p>Alarm state</p>

Alarm: Refer to next page.

<The allocation of the alarm >

Bit	Data			EMU4-FD1-MB
	Content	OFF(0)	ON(1)	
b0	Alarm of Pulse	Non-Alarm	Alarm	○
b1	Reserved	—	—	—
b2	Alarm of Demand current	Non-Alarm	Alarm	○
b3	Alarm of Demand Active power	Non-Alarm	Alarm	○
b4	Contact Input	OFF(Open)	ON(Close)	○
b5	Alarm (total)	Non-Alarm	Alarm	○
b6	Reserved	—	—	—
b7	Reserved	—	—	—
b8	Alarm of Voltage	Non-Alarm	Alarm	○
b9	Reserved	—	—	—
b10	Reserved	—	—	—
b11	Reserved	—	—	—
b12	Reserved	—	—	—
b13	Alarm of Power factor	Non-Alarm	Alarm	○
b14	Reserved	—	—	—
b15	Reserved	—	—	—

Note1: b0 (Pulse count) is available only when external input signal setup is Pulse input in EMU4-FD1-MB.

Note2: b4 (Contact input) is available only when external input signal setup is Contact input in EMU4-FD1-MB.

Table 7.7 Data Format (4/6)

Data	Data Format ④																				
<p>Set-up</p> <p>Primary current Secondary current Primary voltage Secondary voltage</p> <p>Format④</p>	<p>Data Format ④</p> <p>Multiplicand</p> <p>Numerical value</p> <p>b15 b8 b7 b0</p> <p>Index number</p> <p>Low data</p> <p>High data</p> <p>b31 b24 b23 b16 b15 b8 b7 b0</p> <p>High data</p> <p>Low data</p> <p>Numerical value: 32-bit integer with a sign -2147483648~2147483647 (80000000H~7FFFFFFFH)</p> <p><Multiplicand></p> <p>Multiplicand is fixed for every item according to settings of primary current, primary voltage, Secondary current, Secondary voltage, and phase wiring. (Refer to 7.2.4 Significant digits and Multiplying factor)</p> <p>Index number = 00H: The actual value is the numeric value. Index number = FFH: The actual value is 10^{-1} times the numeric value.</p> <p><Example: Primary current, Primary voltage></p> <table border="1"> <thead> <tr> <th>Set-up value</th> <th>Multiplicand</th> <th>Numeric value</th> <th>Data</th> </tr> </thead> <tbody> <tr> <td>Set-up value = 100.0A (Effective range = one place of decimals)</td> <td>$\times 10^{-1} \Rightarrow FFH$</td> <td>1000 $\Rightarrow 03E8H$</td> <td>000003E8H</td> </tr> <tr> <td>Set-up value = 400A (Effective range = Integer)</td> <td>$\times 1 \Rightarrow 00H$</td> <td>400 $\Rightarrow 0190H$</td> <td>00000190H</td> </tr> <tr> <td>Set-up value = 110.0V (Effective range = one place of decimals)</td> <td>$\times 10^{-1} \Rightarrow FFH$</td> <td>1100 $\Rightarrow 044CH$</td> <td>0000044CH</td> </tr> <tr> <td>Set-up value = 3300V (Effective range = Integer)</td> <td>$\times 1 \Rightarrow 00H$</td> <td>3300 $\Rightarrow 0CE4H$</td> <td>00000CE4H</td> </tr> </tbody> </table>	Set-up value	Multiplicand	Numeric value	Data	Set-up value = 100.0A (Effective range = one place of decimals)	$\times 10^{-1} \Rightarrow FFH$	1000 $\Rightarrow 03E8H$	000003E8H	Set-up value = 400A (Effective range = Integer)	$\times 1 \Rightarrow 00H$	400 $\Rightarrow 0190H$	00000190H	Set-up value = 110.0V (Effective range = one place of decimals)	$\times 10^{-1} \Rightarrow FFH$	1100 $\Rightarrow 044CH$	0000044CH	Set-up value = 3300V (Effective range = Integer)	$\times 1 \Rightarrow 00H$	3300 $\Rightarrow 0CE4H$	00000CE4H
Set-up value	Multiplicand	Numeric value	Data																		
Set-up value = 100.0A (Effective range = one place of decimals)	$\times 10^{-1} \Rightarrow FFH$	1000 $\Rightarrow 03E8H$	000003E8H																		
Set-up value = 400A (Effective range = Integer)	$\times 1 \Rightarrow 00H$	400 $\Rightarrow 0190H$	00000190H																		
Set-up value = 110.0V (Effective range = one place of decimals)	$\times 10^{-1} \Rightarrow FFH$	1100 $\Rightarrow 044CH$	0000044CH																		
Set-up value = 3300V (Effective range = Integer)	$\times 1 \Rightarrow 00H$	3300 $\Rightarrow 0CE4H$	00000CE4H																		

Table 7.8 Data Format (5/6)

<Details of 16bit set register>

Bit	Content	EMU4-FD1-MB	Note
b16	Alarm reset	○	
b17	All measurement data reset	○	Note1
b18	Reserved	—	
b19	Reserved	—	
b20	Reserved	—	
b21	Reserved	—	
b22	Reserved	—	
b23	Reserved	—	
b24	Contact input latch clear	○	
b25	External input reset	○	Note2
b26	Reserved	—	
b27	Reserved	—	
b28	Reserved	—	
b29	Reserved	—	
b30	Active energy / Reactive energy reset	○	
b31	Reserved	—	

Note 1: Reset value is showed in below table.

	Integral value
EMU4-FD1-MB	Electric energy, Reactive power, Pulse count, Operating time Periodic electric energy, CO2 conversion

Note 2: Reset value is showed in below table.

	Value
EMU4-FD1-MB	Electric energy, Reactive power, Pulse count, Operating time Periodic electric energy, CO2 conversion

Table 7.9 Data Format (6/6)

Data	Data Format ⑥												
<p>Measurement Pulse Operating time</p> <div style="border: 1px solid black; padding: 5px; margin-top: 10px;">Format⑥</div>	<p style="text-align: center;">Data Format ⑥</p> <p>Multiplicand</p> <p>Numerical value</p> <p>b15 b8 b7 b0</p> <p>Index number</p> <p>High data</p> <p>Low data</p> <p>High data</p> <p>b31 b24 b23 b16 b15 b8 b7 b0</p> <p>Low data</p> <p>Numerical value: 32-bit integer with a sign However, the effective numerical value is 0~999999 (0H~F423FH)</p> <p><Multiplicand></p> <p>Multiplicand is fixed for every item according to settings of primary current, primary voltage, and phase wiring. (Refer to 7.2.4 Significant digits and Multiplying factor)</p> <p><Example: Measurement value></p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="text-align: center;">Item</th> <th style="text-align: center;">Multiplicand</th> <th style="text-align: center;">Numeric value</th> <th style="text-align: center;">Actual value</th> </tr> </thead> <tbody> <tr> <td>Pulse</td> <td>00H⇒1</td> <td>000000FFH⇒255</td> <td>255×1 = 255[pulse]</td> </tr> <tr> <td>Operating time</td> <td>00H⇒1</td> <td>0000003CH⇒60</td> <td>60×1 = 60[hour]</td> </tr> </tbody> </table>	Item	Multiplicand	Numeric value	Actual value	Pulse	00H⇒1	000000FFH⇒255	255×1 = 255[pulse]	Operating time	00H⇒1	0000003CH⇒60	60×1 = 60[hour]
Item	Multiplicand	Numeric value	Actual value										
Pulse	00H⇒1	000000FFH⇒255	255×1 = 255[pulse]										
Operating time	00H⇒1	0000003CH⇒60	60×1 = 60[hour]										

7.2.4 Significant digits and Multiplying factor

(1) Electric power and Reactive power data

Vertical axis: Primary current setting value Horizontal axis: Primary voltage setting value, Phase wire system setting value.

Phase Wire system	1P2W								1P3W	3P3W							
	110	220	440	690	1100	2200	3300	6600		110	220	440	690	1100	2200	3300	6600
V A	3digit	3digit	3digit	3digit	3digit	2digit	2digit	3digit	2digit	2digit							
5	3digit	3digit	3digit	3digit	3digit	2digit	2digit	3digit	2digit	2digit							
6	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	3digit	2digit	2digit						
7.5	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit
8	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit
10	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit
12	3digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit
15	3digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	3digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit
20	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	2digit	1digit
25	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit	1digit
30	3digit	3digit	2digit	2digit	2digit	2digit	2digit	1digit	3digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit	1digit
40	3digit	3digit	2digit	2digit	2digit	2digit	1digit	1digit	3digit	3digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit
50	3digit	3digit	2digit	2digit	2digit	2digit	1digit	1digit	3digit	3digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit
60	3digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	3digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit
75	3digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
80	3digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
100	3digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
120	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	x1	
150	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	x1	
200	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	
250	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	
300	2digit	2digit	1digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	
400	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	
500	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	
600	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	2digit	1digit	1digit	1digit	1digit	1digit	x1	x1
750	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	x1	x1	x1	
800	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	x1	x1	x1	
1000	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	x1	x1	x1	
1200	1digit	1digit	1digit	1digit	x1	x1	x1	x1	1digit	1digit	1digit	1digit	x1	x1	x1	x10	
1500	1digit	1digit	1digit	1digit	x1	x1	x1	x1	1digit	1digit	1digit	1digit	x1	x1	x1	x10	
1600	1digit	1digit	1digit	1digit	x1	x1	x1	x1	1digit	1digit	1digit	1digit	x1	x1	x1	x10	
2000	1digit	1digit	1digit	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x10	
2500	1digit	1digit	1digit	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x10	
3000	1digit	1digit	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x10	x10	
4000	1digit	1digit	x1	x1	x1	x1	x10	x10	1digit	1digit	x1	x1	x1	x1	x10	x10	
5000	1digit	1digit	x1	x1	x1	x1	x10	x10	1digit	1digit	x1	x1	x1	x1	x10	x10	
6000	1digit	x1	x1	x1	x1	x10	x10	x10	x1	1digit	x1	x1	x1	x1	x10	x10	

Phase Wire system	3P4W															
V A	63.5 110	100 173	105 182	110 190	115 199	120 208	127 220	200 346	220 380	230 400	240 415	242 420	250 430	254 440	265 460	277 480
5	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
6	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
7.5	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
8	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
10	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
12	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit
15	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit
20	3digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit								
25	3digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit								
30	3digit	3digit	3digit	3digit	3digit	3digit	3digit	2digit								
40	3digit	2digit														
50	3digit	2digit														
60	3digit	2digit														
75	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
80	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
100	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
120	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
150	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit
200	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
250	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
300	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
400	2digit	1digit														
500	2digit	1digit														
600	2digit	1digit														
750	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
800	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
1000	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
1200	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
1500	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1
1600	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1	x1	x1
2000	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
2500	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
3000	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
4000	1digit	x1														
5000	1digit	x1														
6000	1digit	x1														

Note : 3 digit means three decimal places ($\times 10^{-3}$) and 2 digit means two decimal places ($\times 10^{-2}$) and 1 digit means 1 decimal places ($\times 10^{-1}$)

Note : x1 means integer×1 and x10 means integer×10.

Note : Reply error of out of range of channel according upper table.

(2) Current and harmonics current data

Primary current	EMU4-FD1-MB
Less than 40A	Decimal 2 digit
40A to 400A	Decimal 1 digit
400A to 4000A	Integer×1
More than 4000A	Integer×10

(3) Voltage and harmonics voltage data

Primary voltage (Note1)	EMU4-FD1-MB
Less than 300V	Decimal 1 digit
More than 300V	Intenger×1

Note1: Primary voltage is phase voltage when phase wire system is 3P4W.

(4) Electric energy, reactive energy and electric energy conversion

Phase wire system	1P2W								1P3W	3P3W							
V A	110	220	440	690	1100	2200	3300	6600	110	110	220	440	690	1100	2200	3300	6600
5	2digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit
6	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit
7.5	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
8	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
10	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit
12	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1
15	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	2digit	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1
20	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	1digit	x1
25	2digit	2digit	2digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	1digit	x1
30	2digit	2digit	1digit	1digit	1digit	1digit	1digit	x1	2digit	2digit	2digit	1digit	1digit	1digit	1digit	1digit	x1
40	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	x1
50	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	2digit	2digit	1digit	1digit	1digit	1digit	x1	x1	x1
60	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	2digit	1digit	1digit	1digit	1digit	x1	x1	x1
75	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	1digit	x1	x1	x1
80	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	1digit	x1	x1	x1
100	2digit	1digit	1digit	1digit	1digit	x1	x1	x1	1digit	1digit	1digit	1digit	1digit	1digit	x1	x1	x1
120	1digit	1digit	1digit	1digit	x1	x1	x1	x1	1digit	1digit	1digit	1digit	x1	x1	x1	x1	x10
150	1digit	1digit	1digit	1digit	x1	x1	x1	x1	1digit	1digit	1digit	1digit	x1	x1	x1	x1	x10
200	1digit	1digit	1digit	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x1	x10
250	1digit	1digit	1digit	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x10	x10
300	1digit	1digit	x1	x1	x1	x1	x1	x10	1digit	1digit	1digit	x1	x1	x1	x1	x10	x10
400	1digit	1digit	x1	x1	x1	x1	x10	x10	1digit	1digit	1digit	x1	x1	x1	x10	x10	x10
500	1digit	1digit	x1	x1	x1	x1	x10	x10	1digit	1digit	1digit	x1	x1	x1	x10	x10	x10
600	1digit	x1	x1	x1	x1	x10	x10	x10	x1	1digit	x1	x1	x1	x1	x10	x10	x10
750	1digit	x1	x1	x1	x1	x10	x10	x10	x1	x1	x1	x1	x1	x10	x10	x10	x10
800	1digit	x1	x1	x1	x1	x10	x10	x10	x1	x1	x1	x1	x1	x10	x10	x10	x10
1000	1digit	x1	x1	x1	x1	x10	x10	x10	x1	x1	x1	x1	x1	x10	x10	x10	x10
1200	x1	x1	x1	x1	x10	x10	x10	x10	x1	x1	x1	x1	x10	x10	x10	x10	x100
1500	x1	x1	x1	x1	x10	x10	x10	x10	x1	x1	x1	x1	x10	x10	x10	x10	x100
1600	x1	x1	x1	x1	x10	x10	x10	x10	x1	x1	x1	x10	x10	x10	x10	x10	x100
2000	x1	x1	x1	x10	x10	x10	x10	x100	x1	x1	x1	x10	x10	x10	x10	x10	x100
2500	x1	x1	x1	x10	x10	x10	x10	x100	x1	x1	x1	x10	x10	x10	x10	x100	x100
3000	x1	x1	x10	x10	x10	x10	x10	x100	x1	x1	x1	x10	x10	x10	x10	x100	x100
4000	x1	x1	x10	x10	x10	x10	x100	x100	x1	x1	x10	x10	x10	x10	x10	x100	x100
5000	x1	x1	x10	x10	x10	x10	x100	x100	x1	x1	x10	x10	x10	x10	x10	x100	x100
6000	x1	x10	x10	x10	x10	x100	x100	x100	x10	x1	x10	x10	x10	x10	x100	x100	x100

Phase wire system	• 3P4W															
V A	63.5 110	100 173	105 182	110 190	115 199	120 208	127 220	200 346	220 380	230 400	240 415	242 420	250 430	254 440	265 460	277 480
5	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
6	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
7.5	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
8	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
10	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
12	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit
15	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit
20	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
25	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
30	2digit	2digit	2digit	2digit	2digit	2digit	2digit	1digit								
40	2digit	1digit														
50	2digit	1digit														
60	2digit	1digit														
75	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
80	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
100	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
120	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit
150	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1
200	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
250	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
300	1digit	1digit	1digit	1digit	1digit	1digit	1digit	x1								
400	1digit	x1														
500	1digit	x1														
600	1digit	x1														
750	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1
800	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1
1000	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1
1200	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1
1500	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x10
1600	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x1	x10	x10	x10
2000	x1	x1	x1	x1	x1	x1	x1	x10								
2500	x1	x1	x1	x1	x1	x1	x1	x10								
3000	x1	x1	x1	x1	x1	x1	x1	x10								
4000	x1	x10														
5000	x1	x10														
6000	x1	x10														

Note : 2 digit means two decimal places ($\times 10^{-2}$) and 1 digit means 1 decimal places ($\times 10^{-1}$)

Note : x1 means integer×1 and x10 means integer×10 and x100 means integer×100.

Effective Range and Multiplicand <For EMU4-FD1-MB>

The conditions of multiplying factor by setup of each element are shown below.

Element	Condition	Multiplying factor
Voltage Harmonics voltage	Primary voltage (Note1)	0V~300V less than $\times 10^{-1}$
		300V or more $\times 1$
Current Current demand	Primary current	0A~40A less than $\times 10^{-2}$
		40A~400A less than $\times 10^{-1}$
Harmonics current		400A~4000A less than $\times 1$
Active power Active power demand Reactive power Apparent power	Full load power(Note2)	0kW~12kW less than $\times 10^{-3}$
		12kW~120kW less than $\times 10^{-2}$
		120kW~1200kW less than $\times 10^{-1}$
		1200kW~12000kW less than $\times 1$
		12000kW~120000kW less than $\times 10^1$
		120000kW or more $\times 10^2$
Active energy Reactive energy	Full load power (Note2)	0kW~12kW less than $\times 10^{-2}$
		12kW~120kW less than $\times 10^{-1}$
		120kW~1200kW less than $\times 1$
		1200kW~12000kW less than $\times 10$
		12000kW~120000kW less than $\times 10^2$
		120000kW or more $\times 10^3$
Active energy (extended) Reactive energy (extended)	Full load power (Note2)	0kW~12kW less than $\times 10^{-5}$
		12kW~120kW less than $\times 10^{-4}$
		120kW~1200kW less than $\times 10^{-3}$
		1200kW~12000kW less than $\times 10^{-2}$
		12000kW~120000kW less than $\times 10^{-1}$
		120000kW or more $\times 1$
Frequency	—	— $\times 10^{-1}$
Power factor	—	— $\times 10^{-1}$
Harmonics distortion	—	— $\times 10^{-1}$

Note1: At 3P4W, primary voltage is phase to neutral voltage.

Note2: How to calculate Full load power is the following.

$$\text{Full load power [kW]} = \frac{\alpha \times (\text{Primary voltage}) \times (\text{Primary current})}{1000}$$

α : 1 at 1P2W

2 at 1P3W (Primary voltage is 110V)

$\sqrt{3}$ at 3P3W

3 at 3P4W (Primary voltage is phase to neutral voltage)

7.2.5 Error Occurrence

When the command and related data transmitted to Measuring Unit is improper or Measuring Unit is in H/W error, RX(n+1)A (Error status flag) becomes 1(ON), the error code shown in Table 7.10 is returned as reply data.

Table 7.10 Error Code

Error Description	Error Code (Hex.)	EMU4-FD1-MB
Undefined command or Illegal command or packet length	40H	○
Invalid group number	41H	○
Invalid channel number	42H	○
Measuring Unit is in set-up mode	43H	○
	44H	○
Invalid unit number	45H	○
Invalid data for set-up	51H	○
Invalid channel number	C1H	○
Invalid data for set-up	C2H	○

If an error occurs, the error code is written into the RWrn as shown in the figure below, and RX(n+1)A (error status flag) is turned on (error occurrence) and RX(n+1)B (remote READY) is turned off (normal communication stop).

For the error resetting method, refer to "6.3 Error Communication".

- (1) At the command No. is in range

Remote register RWrn			
	b15	b8	b7 b0
n	Channel No.	Group No.	
n+1	00H	00H	
n+2	00H	Error code	
n+3	00H	00H	

- (2) At the command No. is out of range

Remote register RWrn			
	b15	b8	b7 b0
n	00H	Error code	
n+1	00H	00H	
n+2	00H	00H	
n+3	00H	00H	

8. Abbreviations and Special Terms

Abbreviations and special terms used in this manual are shown below:

Abbreviation and Special Terms	Description
Master station	Station which controls remote stations and local stations. One station is required for one system.
Local station	Station with the CPU which can communicate with master station and other local stations.
Remote I/O station	Remote station which deals with bit information only.
Remote device station	Remote station which deals with bit information and word information.
Remote station	General name for remote I/O station and remote device station. Controlled by a master station.
Intelligent device station	Station that can perform transient transmission.
RX	Remote input
RY	Remote output
RWw	Remote resister (write area)
RWr	Remote resister (read area)
Command	Identification code allocated to items to be monitored or set. Measuring Unit uses a special-purpose command that is transmitted to monitor each measurement value or set each parameter.
Demand value	The demand value is an approximate average value during the demand time period. When it is set to 0, each demand present value becomes equivalent to the present value.

9. Program Example

This chapter provides example programs of two types. One is the program to monitor only active energy from a Measuring Unit. Another is the program to monitor the multi-items from two units of Measuring Unit.

*1. Sample programs are for Q series programmable controller.


*2. Sample programs are created by using "SW8D5C-GPPW GX Developer".

*3. The refresh set with the automatic refresh parameters and the refresh executed with the FROM/TO instructions cannot be performed simultaneously.

9.1 Program Example 1

9.1.1 Program Content

This section shows an example the program to monitor only active energy from a Measuring Unit whose station number is 1. This program example is assumed the system configuration in below and the I/O number of the master station is X/Y00 to X/Y 1F.




9.1.2 Parameter Settings

Parameter settings are set as following with GX Developer.

(1) Network Parameter Settings and Auto Refresh Parameter Settings


The following is shown CC-Link network parameter settings and auto refresh parameter settings.



Setting Item	Description	Example for settings	Remarks
No.of boards in Module	Set the "No. of boards in module" for which the network parameters are to be set.	1	
Start I/O No	Set the "Start I/O No." for the master station	0000	Set the same setting of Start XY in PC parameter setting
Type	Set the station type.	Master station	
Mode	Set the CC-Link mode.	Remote net (Ver.1 mode)	"Remote net ver.2 mode" and "Remote net additional mode" can be also used in case of the QJ61BT11N.
All connect count	Set the total number of connected stations in the CC-Link system including reserved stations	1	
Remote input (RX)	Set the remote input (RX) refresh device.	X100	Device name - Select from X, M, L, B, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote output (RY)	Set the remote output (RY) refresh device.	Y100	Device name - Select from Y, M, L, B, T, C, ST, D, W, R or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RW _r)	Set the remote register (RW _r) refresh device.	W300	Device name - Select from M, L, B, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Remote register (RW _w)	Set the remote register (RW _w) refresh device.	W400	Device name - Select from M, L, B, T, C, ST, D, W, R, or ZR. Device number - Within the range of the device points that the CPU has.
Special relay (SB)	Set the link special relay (SB) refresh device.	SB0	Device name - Select from M, L, B, D, W, R, SB or ZR. Device number - Within the range of the device points that the CPU has.
Special register (SW)	Set the link special register (SW) refresh device.	SW0	Device name - Select from M, L, B, D, W, R, SW or ZR. Device number - Within the range of the device points that the CPU has.
Retry count	Set the number of retries for "Retry count", when a communication error occurs.	1	
Automatic reconnection station count	Set the number of modules that can return to system operation by a single link scan.	1	
Standby master station No.	Set the station number for the standby master station	Blank	Blank: No standby master station specified.
PLC down select	Set the data link status for "PLC down select", when a master station programmable controller CPU error occurs	Stop	
Scan mode setting	Set whether the link scan for the sequence scan is synchronous or asynchronous	Asynchronous	
Delay information setting	Set for the link scan delay time.	0	50μs


(2) Operational Settings

Operational settings are as follows.



(3) Station Information Settings

Station information settings are as follows.



(4) File Register Settings


This program example uses file registers R (ZR). The procedures of file register settings are as follows.

1) Double-click "PLC parameter".

2) Select "PLC file".

3) Select "Use the same file name as the program" or "Use the following file" and set the each item.

In details, refer to the manual for the CPU module used.




- If you use the CPU module which doesn't have file registers (ex. Q00UJCPU), replace the file register (R) with other device (ex. Data register (D))

9.1.3 Program example

(1) Example of Send Data Setting

This program describes an example of setting commands which are sent to Measuring Unit to devices.



(i) Device Allocation

The following table lists devices used above the example.

Device No.	Setting data	Descriptions	Note
D400	H8011	Send data for monitoring. (Group No.:H80, Unit No.:H1, Command No.: H1)	Group No. changes depending on the data which you want to monitor. Unit No. changes depending on the Measuring Unit. •Unit No. is H1 when use EMU4-FD1-MB
D401	H1	Send data for monitoring. (Channel No.: H01)	It changes depending on the data which you want to monitor.
D402	H0	Send data for monitoring. (H0 fixed.)	
D403	H0	Send data for monitoring. (H0 fixed.)	

Note: Set the D400 to D403 same as that set device in "(iii) Example of Normal Communication". Depending on the data that you want to monitor, the setting data vary.


The following table lists the examples of setting data.

Command	Descriptions	Device No.	Setting data	Descriptions of setting data.
Data monitor	Phase 1 current	D400	H0111	Group No. :H01, Unit No.:H1, Command No.: H1
		D401	H0021	Channel No.: H21
		D402	H0000	H0 fixed.
		D403	H0000	H0 fixed.
	Total active power	D400	H0711	Group No. :H07, Unit No.:H1, Command No.: H1
		D401	H0001	Channel No.: H01
		D402	H0000	H0 fixed.
		D403	H0000	H0 fixed.
Data set	Phase wiring (Set to 3P3W)	D400	HE012	Group No. :HE0, Unit No.:H1, Command No.: H2
		D401	H0013	Index No.: H00, Channel No.: H13
		D402	H0003	Low data
		D403	H0000	High data

For details, refer to "7.2.3.Details of Commands"

(2) Example of Initial

After confirming if data link is normal or not, the initial process is performed only when the connection status is normal.



(i) Device Allocation


The following table lists devices used above the example.


Device No.	Descriptions	Note
X0	This signal indicates whether the module is normal or faulty. OFF: Module normal ON: Module error	Depending on the start I/O number of the master/local module, the devices No. vary. <Example> When the start I/O number of the master/local module is 0030: X0→X30 X1→31 X0F→X3F
X1	This signal indicates the data link status of the host station. OFF: Data link stopped ON: During data link	
X0F	This signal indicates whether the module is ready for operation. When the module becomes ready, this signal turns on. This signal turns off under either condition. <ul style="list-style-type: none">• An error has been detected in the switch setting of the module.• Module error (Xn0) turns on.	
X118	Remote input (RX). Initial data processing request flag.	Depending on the setting of refresh device and the station number of Measuring Unit, the devices No. vary. (In details, refer to "7.1.1 Remote input RX")
X11A	Remote input (RX). Error status flag.	
X11B	Remote input (RX). Remote READY.	
Y118	Remote output (RY). Initial data setting completion flag.	Depending on the setting of refresh device and the station number of Measuring Unit, the devices No. vary. (In details, refer to "7.1.2 Remote Output RY")
Y11A	Remote output (RY). Error reset request flag.	
W300 to W303	Remote register (RW _r) Receiving data.	Depending on the setting of refresh device and the station number of Measuring Unit, the devices No. vary. (In details, refer to "7.2 Remote Register (RW _r , RW _w)")
SW80 to SW83	Data link status of each station. OFF: Normal ON: Error	Depending on the setting of refresh device, the devices No. vary.
M0 to M63	Data link status of each station. OFF: Normal ON: Error	Devices in a CPU module. (User selectable)
D500 to D503	Error code receiving data.	Devices in a CPU module. (User selectable) About error code, refer to "7.2.4 About Error Occurrence".
T10	Timer for error canceling wait.	Devices in a CPU module. (User selectable)

(3) Example of Normal Communication

This program describes an example of monitoring of measurement values.

* Data sending and receiving





(i) Device Allocation

The following table lists devices used above the example.

Device No.	Descriptions	Note																							
X10F	Remote input (RX) of measuring unit. Command completion reply flag.	Depending on the setting of refresh device and the station number, the devices No. vary. (In details, refer to "7.1.1 Remote input RX")																							
X11A	Remote input (RX) of measuring unit. Error status flag.																								
X11B	Remote input (RX). Remote READY.																								
Y10F	Remote output (RY) of Measuring Unit. Command execution request flag.	Depending on the setting of refresh device and the station number, the devices No. vary. (In details, refer to "7.1.2 Remote Output RY")																							
W300 to W303	Remote register (RW _r) receiving data	Depending on the setting of refresh device and the station number, the devices No. vary. (In details, refer to "7.2 Remote Register (RW _r , RW _w)")																							
W400 to W403	Remote register (RW _w) sending data.																								
D300 to D303	Reading device of receiving data	Devices in a CPU module. (User selectable) The following table lists the description. <table border="1" style="margin-left: 20px;"> <tr> <td>D300</td> <td>Channel No. Group No.</td> </tr> <tr> <td>D301</td> <td>Multiplying factor</td> </tr> <tr> <td>D302</td> <td>Low data</td> </tr> <tr> <td>D303</td> <td>High data</td> </tr> </table>	D300	Channel No. Group No.	D301	Multiplying factor	D302	Low data	D303	High data															
D300	Channel No. Group No.																								
D301	Multiplying factor																								
D302	Low data																								
D303	High data																								
D600 to D602	Checking device for match/mismatch of sending data and receiving data.	Devices in a CPU module. (User selectable)																							
M0	Data link status of station 1.	Devices in a CPU module. (User selectable) Set the same device of data link status which set in "(ii) Example of Initial".																							
M100	Command setting completion flag.	Devices in a CPU module. (User selectable)																							
M101	Transmitting completion flag.	Devices in a CPU module. (User selectable)																							
T11	Transmission starts time.	Devices in a CPU module. (User selectable)																							
T12	Time-out.	Devices in a CPU module. (User selectable)																							
R0	Receiving data (Index number)	Devices in a CPU module. (User selectable) The following table lists the description of index number. <table border="1" style="margin-left: 20px;"> <tr> <th>Index number</th> <th>Multiplicand</th> <th>Remarks</th> </tr> <tr> <td>03H</td> <td>x 10³</td> <td rowspan="8">Actual value = Numerical value × Multiplicand</td> </tr> <tr> <td>02H</td> <td>x 10²</td> </tr> <tr> <td>01H</td> <td>x 10</td> </tr> <tr> <td>00H</td> <td>x 1</td> </tr> <tr> <td>FFH</td> <td>x 10⁻¹</td> </tr> <tr> <td>FEH</td> <td>x 10⁻²</td> </tr> <tr> <td>FDH</td> <td>x 10⁻³</td> </tr> <tr> <td>FCH</td> <td>x 10⁻⁴</td> </tr> <tr> <td>FBH</td> <td>x 10⁻⁵</td> <td></td> </tr> </table> On the basis of the index number, multiply the numerical value by the multiplicand in the host side.	Index number	Multiplicand	Remarks	03H	x 10 ³	Actual value = Numerical value × Multiplicand	02H	x 10 ²	01H	x 10	00H	x 1	FFH	x 10 ⁻¹	FEH	x 10 ⁻²	FDH	x 10 ⁻³	FCH	x 10 ⁻⁴	FBH	x 10 ⁻⁵	
Index number	Multiplicand	Remarks																							
03H	x 10 ³	Actual value = Numerical value × Multiplicand																							
02H	x 10 ²																								
01H	x 10																								
00H	x 1																								
FFH	x 10 ⁻¹																								
FEH	x 10 ⁻²																								
FDH	x 10 ⁻³																								
FCH	x 10 ⁻⁴																								
FBH	x 10 ⁻⁵																								
R1, R2	Receiving data (numerical value)	Devices in a CPU module. (User selectable) Numerical value is 32-bit integer with a sign. However, the effective numerical value is 0～999999(0H～F423FH). Data changes 999998 → 999999 → 0 → 1																							

Note: In details of index number and numerical value, refer to "7.2.3Details of Commands".

Depending on the sending data (D400 to D403), the receiving data (D300 to D303) vary. The following describes the receiving data in case of example in "(i) Example of Send Data Setting".


Command	Descriptions	Receiving data device No.	Setting data	Stored device No.
Data monitor	Phase 1 current	D300	Channel No., Group No.	-
		D301	Index number.	R0
		D302, D303	Receiving data	R1, R2
	Total active power	D300	Channel No., Group No.	-
		D301	Index number.	R0
		D302, D303	Receiving data	R1, R2
	Index number		Depending on the index number (R0), the multiplicand of the measuring data varies. The following table lists the description of index number.	
	Receiving data		On the basis of the index number, multiply the numerical value by the multiplicand in the host side. In details of index number and numerical value, refer to "7.2.3Details of Commands".	
	Receiving data		Numerical value is 32-bit integer with a sign. -2147483648～2147483647 (80000000H～7FFFFFFFH)	

Command	Descriptions
Data Set	<p>Data set is the command that changes setting data of Measuring Unit. The following is an example of modifying at a data set.</p> <p>After setup is completed, please not to setup again</p> <p>M0 X11A X11B Y10F X10F M200 Data link error: station 1 Error status flag: station 1 Remote R EADY: station 1 Command execution request flag:1 Command completion reply flag:1 Setting command completion T11 Transmission start time :1 K10 Transmission start time :1</p> <p>M101 Transmitting completion: station1</p> <p>WAND HOFF00 W400 RWcm Station 1 D600 Group of sending data (tmp)</p> <p>WAND HOFF W401 RWcm+1 Station 1 D601 Channel of sending data (tmp)</p> <p>WOR D600 D601 D602 Check device of matching</p> <p>ROR D602 Check device of matching K8</p> <p>X11A D602 Check device of matching W300 RWcm station 1</p> <p>SET M200 Setting command completion</p> <p>Set M200 after setting. After M200 turns on, please Confirm whether setting is Done correctly in measuring unit.</p>

9.2 Program Example 2

9.2.1 Program Content

This section shows an example the program to monitor only active energy from a Measuring Unit whose station number is 1. This program example is assumed the system configuration in below and the I/O number of the master station is X/Y00 to X/Y 1F.



*1: Reading data


Station number	Model	Reading data
Station number 1	EMU4-FD1-MB	Phase 1 current, Phase 2 current, Phase 3 current 1-2 voltage, 2-3 voltage, 3-1 voltage, Total active power, Active energy(import)
Station number 2	EMU4-FD1-MB	Phase 1 current, Phase 2 current, Phase 3 current 1-2 voltage, 2-3 voltage, 3-1 voltage, Power factor

9.2.1 Parameter Settings

Parameter settings are set as following with GX Developer.


(1) Network Parameter Settings and Auto Refresh Parameter Settings

The following is shown CC-Link network parameter settings and auto refresh parameter settings.



(2) Operational Settings

Operational settings are as follows.



(3) Station Information Settings

Station information settings are as follows.

CC-Link station information. Module 1								
Station No.	Station type	Expanded cyclic setting	Exclusive station count	Remote station points	Reserve/invalid station select	Intelligent buffer select(word)		
						Send	Receive	Automatic
1/1	Remote device station	single	Exclusive station 1	32 points	No setting			
2/2	Remote device station	single	Exclusive station 1	32 points	No setting			


At the bottom are buttons: Default, Check, End, Cancel.

(4) File Register Settings

This program example uses file registers (R). The procedures of file register settings are as follows.

- 1) Double-click "PLC parameter".
- 2) Select "PLC file".
- 3) Select "Use the same file name as the program" or "Use the following file" and set the each item.

In details, refer to the manual for the CPU module used.




- If you use the CPU module which doesn't have file registers (ex. Q00UJCPU), replace the file register (R) with other device (ex. Data register (D))

9.2.2 Device Allocation

The following table lists devices used above the example.

Items	Descriptions	Station No.	Device No.	Note
Remote input(RX)	Remote input (RX00 to RX1F)	1	X100 to X11F	Set X100 to remote input (RX) refresh device.
	Remote input (RX20 to RX3F)	2	X120 to X13F	
Remote output(RY)	Remote output (RY00 to RY1F)	1	Y100 to Y11F	Set Y100 to remote output (RY) refresh device.
	Remote output (RY20 to RY3F)	2	Y120 to Y13F	
Remote register(RWr)	Remote register(RWr0 to RWr3)	1	W300 to W303	Set W300 to remote register (RWr) refresh device.
	Remote register(RWr4 to RWr7)	2	W304 to W307	
Remote register(RWw)	Remote register (RWw0 to RWw3)	1	W400 to W403	Set W400 to remote register (RWw) refresh device.
	Remote register (RWw4 to RWw7)	2	W404 to W407	
Link special relay (SB)	Link special relay of master station (SB0 to SB01FF)	SB0 to SB01FF		Set SB0 to link special relay (SB) refresh device.
Link special register (SW)	Link special register of master station (SW0 to SW01FF)	SW0 to SW01FF		Set SW0 to link special register (SW) refresh device.
Number of taking items	Number of monitoring items	1	D0	Number of items is mentioned in section 9.2.1Parameter Settings
		2	D1	
Number of taken items	For calculation of number of taken items.	1	D10	
		2	D11	
Send data items	Send data for monitoring	1	D100 to D115	Content of items are mentioned in section 9.2.1Parameter Settings.
		2	D120 to D133	
Writing sending data	Writing device of sending data	1	D400 to D403	
		2	D404 to D407	
Reading receiving data	Reading device of receiving data	1	D300 to D303	
		2	D304 to D307	
Error code	Error code receiving data.	1	D500 to D503	
		2	D504 to D504	
Checking device	Checking device for match/mismatch of sending data and receiving data.	1	D600 to D602	
		2	D604 to D606	
Monitor data	Index number of item 1	1	R0	
	Numerical value of item 1		R1, R2	
	to		to	
	Index number of item 8		R21	
	Numerical value of item 8		R22, R23	
	Index number of item 1	2	R40	
	Numerical value of item 1		R41, R42	
	to		to	
	Index number of item 7		R58	
	Numerical value of item 7		R59, R60	
Data link status	Data link status of each station.	1	M0	
Command setting	Command setting completion flag.	2	M1	
		1	M100	
Transmitting completion	Transmitting completion flag.	2	M110	
		1	M101	
Select for receiving data	Index register for selecting of sending command.	2	M111	
	Index register for selecting of storage location of receiving data.	1	Z0	
		2	Z2	
		1	Z1	
		2	Z3	


9.2.3 Program Example



(Continued from the previous page)

* Set the sending data (station 1)

38



(Continued from the previous page)



(Continued from the previous page)

* Set the sending data (station 2)

298

SM402

Turn-on
for one
scan aft
er run

<I1:station2 (Group,Unit) >

H111 D120
I1:
station
2

<I1:station2 (Channel) >

H21 D121

<I2:station2 (Group,Unit) >

H111 D122
I2:
station
2

<I2:station2 (Channel) >

H41 D123

<I3:station2 (Group,Unit) >

H111 D124
I3:
station
2

<I3:station2 (Channel) >

H61 D125

<V12:station2 (Group,Unit) >

H511 D126
V12:
station
2

<V12:station2 (Channel) >

H21 D127

<V23:station2 (Group,Unit) >

H511 D128
V23:
station
2

<V23:station2 (Channel) >

H41 D129


<V31:station2 (Group,Unit) >

H511 D130
V31:
station
2


<V31:station2 (Channel) >

H61 D131


(Continued from the previous page)




(Continued from the previous page)




(Continued from the previous page)




(Continued from the previous page)




(Continued from the previous page)



(Continued from the previous page)



(Continued from the previous page)



10. Test Mode

Measuring Unit has the test mode which the fixed values are replied even if the voltage and current are not input. It can be used to check the communication to programmable controller.

10.1 How to Test

To do the test, it is necessary to operate the Measuring Unit.

About how to use the test mode, refer to the each instrument manual of Measuring Unit.