MELSOFT

CommDTM/IODD DTM Configurator for IO-Link

Installation Instructions

Before Using the Product

Please read this document before use. Keep the document in a safe place for future reference. Make sure that the end users read the document.

⚠ Notice

● Reprinting or reproducing the part or all of the contents of this document in any form for any purpose without the permission of Mitsubishi Electric Corporation is strictly forbidden.

● Although we have made the utmost effort to follow the revisions of the software and hardware, in some cases, unsynchronized matter may occur.

● The information in this document may be subject to change without notice.

Operating Environment

Item	Contents
Personal computer	A personal computer on which Microsoft® Windows® operates
CPU	Intel® Core™2 Duo Processor 2GHz or more
Required memory	Recommended 2GB or more
Available hard disk capacity[5]	• CommDTM for IO-Link: 250MB or more • IODD DTM Configurator: 10MB or more
Monitor	Resolution 1024 × 768 pixels or higher
OS (32/64-bit edition) (English version, Japanese version)	• Windows 10 (Home, Pro, Enterprise, Education)[1] • Windows 8.1, Windows 8.1 (Pro, Enterprise)[1] • Windows 8, Windows 8 (Pro, Enterprise)[1] • Windows 7 (Starter, Home Premium, Professional, Ultimate, Enterprise)[1] • Windows Vista® (Home Basic, Home Premium, Ultimate, Business, Enterprise)[2][3] • Windows XP® (Professional SP3, Home SP3)[2][3]
Interface for communications	• USB port: USB2.0 Full Speed (compatible with USB 1.1) compliant • Ethernet port: 10BASE-T, 10BASE-TX
FDT frame application	FDT framework application compatible with FDT specification V1.2
Required software	• .NET Framework (2.0 or more)[4] • Microsoft XML parser (V4.0 SP2 or more)[4] • Easysocket (13.48 or more)[4]

[1] If .NET Framework 3.5 is invalid, it needs to be valid.
[2] Install .NET Framework 3.5.
[3] 64-bit Edition is not supported.
[4] If the required version is not installed, the software is automatically installed by installer of CommDTM for IO-Link.
[5] 350MB or more of free space is required to install .NET Framework 3.5.

• When the following functions are used, this product may not run properly.
  • Application start-up in Windows compatibility mode
  • Fast user switching
  • Remote desktop
  • Windows XP Mode
  • Windows Touch or Touch
  • Modern UI
  • Client Hyper-V
  • Tablet mode
  • Virtual desktops
• In the following cases, the screen of this product may not work properly.
  • The size of the text and/or other items on the screen are other than default (such as 96DPI, 100%, and 9pt).
  • The resolution of the screen is changed in operation.
  • The desktop theme for Windows is changed in operation.
  • The multi-display is set.
• Use the product as a standard user or administrator for Windows 10, Windows 8.1, Windows 8, Windows 7, or Windows Vista.

Installation/Uninstallation

■ Confirm before installation
• Log on to the personal computer as an administrator.
• Close all applications running before installation. If the product is installed while other applications are running, it may not operate normally.

■ Acknowledgements
• Do not shift to the power save mode (standby, hibernate, sleep) while installing software.
• When a warning message of the security software appears, continue installing by following the on-screen instructions.
• This software's copyright is owned by Mitsubishi Electric Corporation.
• This product (including manual) can be used under the Software License Agreement only.
• We do not take any responsibilities for the consequences of operating this product (including manual).

■ Installation
1. Unzip the compressed file of this product (SW1DNN-IOLCDTM-BD). For details, please consult your local Mitsubishi Electric representative.
2. Double-click "setup.exe" in the unzipped folder.
3. Select or enter the necessary information by following the on-screen instructions.
4. Install CommDTM for IO-Link first, then install IODD DTM Configurator[1].
   [1] IODD DTM Configurator is included in installer of CommDTM for IO-Link.

■ Uninstallation
Uninstall CommDTM for IO-Link and IODD DTM Configurator from the control panel of Windows.